

862 American Rd

Memorandum

To: John Rosebrock, Rupp/Rosebrock
From: Brent N Damman, Zoning Adm. BND
Date: Wednesday, September 25, 2002
Subject: Napoleon Harley Davidson new facility @ 862 American Rd.

Could you please convey to the Fire Suppression contractor that the Napoleon Fire Department requires a single 5" 30 degree downturn Stortz connection for the exterior fire department connection on the subject building.