

PERMIT
 CITY OF NAPOLEON, OHIO - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - (419) 592-4010

Permit No. 2833 Issued 5-3-93

	FEES	BASE	PLUS	TOTAL
Job Location <u>303 Appian</u>	<input type="checkbox"/> Building	\$	\$	\$
Lot _____	<input checked="" type="checkbox"/> Electrical	\$ 15.00	\$ 6.00	\$ 21.00
Issued by <u>Brent N. Damman</u>	<input type="checkbox"/> Plumbing	\$	\$	\$
Owner <u>Mary K. Walker</u>	<input type="checkbox"/> Mechanical	\$	\$	\$
Address <u>195 Harmony Dr., Napoleon, Ohio</u>	<input type="checkbox"/> Demolition	\$	\$	\$
Agent <u>Jim Speiser & Sons 599-1846</u>	<input type="checkbox"/> Zoning	\$	\$	\$
Address <u>Rt. 2, Napoleon, Ohio</u>	<input type="checkbox"/> Sign	\$	\$	\$
Use Type - Residential <u>xxx</u>	<input type="checkbox"/> Water Tap	\$	\$	\$
Other - Describe _____	<input type="checkbox"/> Sew. Insp.	\$	\$	\$
No. Dwelling Units _____	<input type="checkbox"/> Sewer Tap	\$	\$	\$
New _____ Replacement <u>xxx</u>	<input type="checkbox"/> Temp. Water	\$	\$	\$
Add'n. <u>Alter</u> <u>Remodel</u>	<input type="checkbox"/> Temp. Elec.	\$	\$	\$
Mixed Occupancy _____	TOTAL FEES.....\$ 21.00			
Change of Occupancy _____	LESS FEES PAID.....\$			
Estimated Cost \$ <u>600.00</u>	BALANCE DUE.....\$ 21.00			

ZONING INFORMATION

district	lot dimensions		area	front yd	side yd	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd		date appr

WORK INFORMATION

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
 Height _____ Building Volume (for Demo. Permit) _____
 Electrical: New 100 amp service and two (2) new circuits
 Plumbing: _____
 Mechanical: _____

Additional Information: _____


Date 5-3-93 Applicant Signature _____

James C. Speiser

PAID
MAY 03 1993

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
			Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					


 CITY OF MADISON
 WATER & SEWER DEPARTMENT
 515 EAST MAIN STREET
 MADISON, WI 53702
 (608) 263-3000

APPLICATION FOR

Residential, Building, Electrical, Plumbing, Mechanical, and Demolition Permit

FROM - The City of Napoleon, Ohio, Building Department

255 West Riverview Avenue; P.O. Box 151; Napoleon, Ohio 43545 - Telephone (419) 592-4010

ENTRY NO. _____

PERMIT NO. 2833 ISSUED 5-3-93

JOB LOCATION 303 Appian

LOT _____
(Subdivision or Legal Description)

ISSUED BY BND
(Building Official)

OWNER Mary K Walker PHONE _____

ADDRESS 195 Harmony Dr. App.

AGENT Jim Spiser + sons PHONE 597-1846

ADDRESS Rt 2 Napoleon, Ohio

USE: Residential () Commercial () Industrial
() Other _____

WORK: () New () Addition Replacement () Remodel

ESTIMATED COST = \$ 600.00

Base Plus Total

() Building \$ _____ \$ _____ \$ _____

Electrical \$ 15.00 \$ 6.00 \$ 21.00

() Plumbing \$ _____ \$ _____ \$ _____

() Mechanical \$ _____ \$ _____ \$ _____

() Demolition \$ _____ \$ _____ \$ _____

() Zoning \$ _____ \$ _____ \$ _____

() Sign \$ _____ \$ _____ \$ _____

() Water Tap \$ _____ \$ _____ \$ _____

() Sewer Tap \$ _____ \$ _____ \$ _____

() Temp Water \$ _____ \$ _____ \$ _____

() Temp Elec. \$ _____ \$ _____ \$ _____

Additional Plan Review: Structure _____ Hours _____
Electric _____ Hours _____

TOTAL FEES \$ 21.00

Less Fees Paid \$ _____

BALANCE DUE \$ 21.00

ZONING INFORMATION

District	Lot Dimensions	Area	Front Yard	Side Yard	Rear Yard

Max Height	No. Pkg. Spaces	No. Ldg. Spaces	Max Cover	Petition or Appeal Required-Date

WORK INFORMATION

Building: Ground Floor Area _____ sq. ft. Basement Floor Area _____ sq. ft.

Garage Floor Area _____ sq. ft. 2nd Floor Area _____ sq. ft. Other _____ sq. ft.

Size: Width _____ Length _____ Stories _____ Height _____

Building Volume (for Demolition Permit) _____ cubic feet

Description of Work: New ^{100amp} Service + 2 new Cir.

ELECTRICAL: Contractor _____ Phone _____
Address _____ ESTIMATED COST = \$ _____

Type of Work: ()New ()Service Change ()Rewiring ()Add'l Wiring TEMPORARY ELEC. REQUIRED - ()Yes ()No
Size of Service _____ Underground _____ Overhead _____ Number of New Circuits _____

Description of Work: _____

PLUMBING: Contractor _____ Phone _____
Address _____ ESTIMATED COST = \$ _____

WATER TAP REQUIRED -- ()Yes ()No Size _____ Type of Pipe _____ Water Dist. Pipe _____

SANITARY SEWER TAP REQUIRED - ()Yes ()No Size _____ Type of Pipe _____ Dr. Waste Vt. Pipe _____

STREET SEWER TAP REQUIRED - ()Yes ()No Type of Pipe _____ STREET TO BE OPENED - ()Yes ()No
Main Building Drain Size = _____ Main Vent Pipe Size = _____

LIST NUMBER OF PLUMBING FIXTURES BELOW:

Water Closets = _____ Bathtubs = _____ Showers = _____ Lavatories = _____ Kitchen Sinks = _____ Disposal = _____
Clothes Washer = _____ Floor Drains = _____ Dishwasher = _____ Other _____ Total = _____

Description of Work: _____

MECHANICAL: Contractor _____ Phone _____
Address _____ ESTIMATED COST = \$ _____

HEATING SYSTEM - ()Forced Air ()Gravity ()Hot Water ()Steam ()Unit Heaters ()Radiant ()Baseboard

TYPE OF FUEL - ()Electric ()Natural Gas ()Propane ()Wood ()Coal ()Solar ()Geothermal Other _____

NUMBER OF HEAT ZONES = _____ HOT WATER - ()One (1) Pipe ()Two (2) Pipes ()Series Loop

ELECTRIC HEAT - Number of Circuits _____ Number of Furnaces _____ Number of Hot Air Runs _____

Number of Hot Water Radiators _____ Total Heat Loss _____ Rated Capacity of Furnace/Boiler _____

LOCATION OF HEATING UNITS - ()Crawl Space ()Floor Level ()Attic ()Suspended ()Roof ()Outside

Description of Work: _____

DRAWINGS REQUIRED: All applications must be accompanied by two (2) complete sets of Drawings including Site Plans, Foundation Plans, Floor Plans, Structural Framing Plans, Exterior Elevations, Section and Details, Stair Details, Electrical Layout, Plumbing Isometric, Heating Layout, etc. All Plans shall be drawn to scale, show all existing structure on the Site Plans, and show electric panel and furnace locations.

READ AND SIGN BELOW: The undersigned hereby makes application for a Permit for all work described herein and agrees to complete the work in strict accordance with all applicable provisions of the current edition of the C.A.B.O. Building Code, the Napoleon Building and Zoning Codes, the Napoleon Engineering Department Rules and Regulations, Standard Specifications and other pertinent sections of the Napoleon Code of Ordinances.

Signature of Applicant _____ Date _____

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name
Address
Builder Name
Address Tel.

Lot Information:

Street No. 299 APPIAN
Lot Subdivision
Lot Dimensions Lot Area Sq. Ft.
Yard Set Back: Front Rear
Side Side

Sidewalk required in accordance with Ordinance
No.

Building Information:

Residence Commercial Industrial
Single Double Multiple New Construction Addition Remodel
Size: Length Width No. of Stories
Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
Unfinished Attic Garage
Foundation: Piers Full Basement Part Basement
Concrete Block
Walls: Frame Block Brick Other
Electrical Outlets: 120v 240v
Plumbing: Fixtures Traps Vents Heating Air Conditioning

Date Applicant Signature E. J. ...
Owner - Builder - Agent

Inspection Record:

Work Started Foundations in 5-10-74 Plumbing, Heating
Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
Excavation 5-15-74 Erecting Frame Complete 7-3-74 Roof
Footing 4 1/2 yds 5-15-74 Electrical Work

Comments:

Certificate of Occupancy Issued

Pink - Engineer Inspector

Permit No.
Issued
By Building Inspector
Estimated Cost 7,000

Fees	Base	Plus	Total
Construction			
Basement			
Detached Garage			
Plumbing			
Electrical			
Heating			
Air Conditioning			
Water Tap			
Sewer Tap			
Temporary Electric			
Total			

CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT

Owner Name MARY K. WALKER
 Address 419 SHEFFIELD STREET
 Builder Name HAROLD BASTELMAN ELECTRICIAN
 Address 618 PARK STREET Tel. 592-7383

Lot Information:

299 APPIAN
 Street No. FRONT
 Lot Subdivision
 Lot Dimensions Lot Area Sq. Ft.
 Yard Set Back: Front Rear
 Side Side

Sidewalk required in accordance with Ordinance
 No.

Building Information:

Residence Commercial RESTAURANT Industrial
 Single Double Multiple New Construction X Addition X Remodel
 Size: Length Width No. of Stories
 Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
 Unfinished Attic Garage
 Foundation: Piers Full Basement Part Basement
 Concrete Block
 Walls: Frame Block Brick Other
 Electrical Outlets: 120v 30 240v
 Plumbing: Fixtures Traps Vents Heating Air Conditioning
 Additional Information: BUILDING PERMIT #33 ISSUED FOR CONSTRUCTION ONLY 4-30-74
 Date 5-16-74 Applicant Signature Harold Bastelman Electrician
 Owner - Builder - Agent

Inspection Record:

Work Started Foundations Plumbing, Heating
 Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
 Excavation Erecting Frame Roof
 Footing Electrical Work

Comments:

Certificate of Occupancy Issued

Pink - Engineer

Inspector

Permit No. 33-A
 Issued MAY 14 1974
 By Robert P. ...
 Building Inspector
 Estimated Cost 51,000

Fees	Base	Plus	Total
Construction			
Basement			
Detached Garage			
Plumbing			
Electrical	<u>5.00</u>	<u>3.00</u>	<u>8.00</u>
Heating			
Air Conditioning			
Water Tap			
Sewer Tap			
Temporary Electric			
Total	<u>5.00</u>	<u>3.00</u>	<u>8.00</u>

July 19, 1974

Permit No. 33-A

Electrical Inspection, Frosty Whip Bldg

Following Conditions Noted:

1. Exit light must be wired directly to Main Panel
2. Conduit Strips Required @ Ceiling Area
3. Must have OZ bushing metal with fiber insert @ main panel.
4. Additional white wire ground from light panel to main panel
5. Must caulk upper + lower main panel conduit to roof, mask. (duct-seal)
6. Assure proper wire size within A/C + Heating panel so as not to allow over-fusing.

Note: Any wire size #4 or over must have fiber bushings + lock-nuts, with ground wire, #4 strand

P. W. L.

Thomas W. Loran
City Building Inspector

CITY OF NAPOLEON
115 W. Main St.
NAPOLEON, OHIO 43545

message

reply

to: Harold Bostelman
618 Park Street
Napoleon, Ohio 43545

subject *Elect. Inspection, Frosty Whip, Permit No. 33-A*

ON Friday, July 19, 1974 an inspection was conducted on the new electrical work and the following conditions noted:

As per discussed with you on Monday, July 22, 1974.

date July 25, 1974 signed *Thomas W. Linnon*
City Building Inspector date _____ signed _____

SENDER: Mail white and pink copies with carbon intact.

RECEIVER: Reply, retain white copy, return pink copy.

33990. Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

