

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 838-77 Issued 9/29/77
date

Job Location 515 Appian Avenue
address

Lot in NW 1/4 Sec. 19 Harrison Twp
sub-div or legal discript

Issued By Ronald D. Sonnenberg
building official

Owner Kenneth Coleman 592-4613
name tel.

Address 515 Appian Ave.

Agent Self Same
builder-eng.-etc. tel.

Address Same

Description of Use Carport

Residential XX(1)
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. XX Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 800.00

ZONING INFORMATION

district "GB"	lot dimensions	area SEE SITE PLAN	front yd NA	side yds 16.5' N OK	rear yd Min 15' OK
max hgt 60' OK	no pkg spaces na	no ldg spaces na	max cover OK	petition or appeal req'd NA	date appr ---

FEES	BASE	PLUS	TOTAL			
<input checked="" type="checkbox"/> BUILDING	\$6.00	---	\$6.00			
<input type="checkbox"/> ELECTRICAL	/	/	/			
<input type="checkbox"/> PLUMBING						
<input type="checkbox"/> MECHANICAL						
<input type="checkbox"/> DEMOLITION						
<input checked="" type="checkbox"/> ZONING				---	---	---
<input type="checkbox"/> SIGN						
WATER TAP						
SEWER TAP						
TEMP. ELECT.						
ADDITIONAL PLAN REVIEW				Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$6.00			
LESS MIN. FEES PAID _____			---0---			
BALANCE DUE.....			\$6.00			

WORK INFORMATION:

Size: Length 24' Width 11'6" Stories 1 Ground Floor Area 276 sq'

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: na brief description

Plumbing: na brief description

Mechanical: na brief description

Sign: _____ Dimensions _____ Sign Area _____

Additional Information: See attached addendum!

Date 9-30-77 Applicant Signature Kenneth Coleman
owner-agent

INSPECTION RECORD

UNDERGROUND			ROUGH-IN						FINAL			
Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By	
PLUMBING	Building Drains		Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping			
	Water Piping								Backflow Prevention			
	Building Sewer		Water Piping			Condensate Lines			Water Heater			
	Sewer Connection								FINAL APPROVAL			
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s)			Grease Exhaust System			
			Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)			
	Ducts/Plenums		Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment			
			Duct Insulation			Pool Heater			Furnace(s)			
			Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL			
ELECTRICAL	Conduits & or Cable		Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting			
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders			
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs			
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance			
	Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL			
BUILDING	Location, Set-backs, Esmt(s)		Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector			
	Excavation					Exterior Lath			Demolition (sewer cap)			
	Footings & Reinforcing					<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard						
	Floor Slab		Interior Wall Construction			Fire Wall(s)			Building or Structure			
	Foundation Walls		Columns & Supports			Fireplace Chimney						
	Sub-soil Drain		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access						
	Piles		Floor System(s)						FINAL APPROVAL BLDG. DEPT.	5/22/19	RLJ	
			Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON, Building Dept.
 255 West Riverview Avenue
 Napoleon, Ohio 43545
 (419) 592-4010

ADDENDUM to Permit No. 838-77
Owner K. COLEMAN
Location 515 APPIAN AVE.

Please note the Items checked below and incorporate them into your plans as indicated: Permit not yet issued
 Correct Plans and Re-Submit. Permit Issued Incorporate the Items during construction.

<p style="text-align: center;">GENERAL</p> <p>Provide 1 approved smoke detector.</p> <p>Provide 1 hour fire wall and/or ceiling between garage and dwelling.</p> <p>Provide (Class B) 1 hour fire rated door from garage to dwelling.</p> <p>Submit fully dimensioned plot plan.</p> <p>Provide 1-3'0" x 6'8" exit door.</p> <p>Provide min. 22" x 30" attic access.</p> <p>Provide min. 18" x 24" crawl space access opening.</p> <p style="text-align: center;">LIGHT AND VENTILATION:</p> <p>Provide mechanical exhaust or window in bathroom.....</p> <p>Provide Min. _____ sq. in. net free area attic ventilation.</p> <p>Provide min. _____ sq. in. net free area crawl space ventilation.</p> <p style="text-align: center;">FOUNDATION:</p> <p>Min. depth of foundation below finished grade <u>30"</u>.</p> <p>Min. size of footer " x "</p> <p>Provide anchor bolts 1/2" @ 8' o.c. 1' from each corner. Embedded 8" concrete and 15" in masonry.</p> <p>Show size of basement columns.</p> <p style="text-align: center;">FRAMING:</p> <p>Show size of wood girder in.....</p> <p>Provide design data for structural member in</p> <p>Floor joists under sized in.....</p> <p>Provide double joists under parallel partitions.</p> <p>Provide 1" x 4" let in corner bracing or approved sheathing.</p> <p>Show size of headers for openings over 4' wide.</p>	<p>Show size of members supporting porch roof.</p> <p>Provide double top plate.</p> <p>Provide design data for pre-fab. wood truss/members.</p> <p>Ceiling joists undersized in.....</p> <p>.....</p> <p><input checked="" type="checkbox"/> Roof rafters undersized in <u>USE 2" X 6" @ 16" O.C.</u></p> <p style="text-align: center;">PLUMBING AND MECHANICAL:</p> <p><input checked="" type="checkbox"/> Terminate all exhaust systems to outside air.</p> <p>Insulate ducts in unheated areas.</p> <p>Provide back flow device on all hose bibs.</p> <p style="text-align: center;">ELECTRICAL:</p> <p>Show location of service entrance and service equipment panel.</p> <p>G.F.C.I. req'd. on Temp. Electric.</p> <p>Outdoor and bathroom receptacles shall be protected by G.F.C.I.</p> <p style="text-align: center;">METAL VENEERS:</p> <p>Contact City Utilities Dept. to remove conductors and/or meter.</p> <p>Provide 18" x 18" x 3/4" wood backer for meter base.</p> <p>Provide approved system of grounding and bonding.</p> <p style="text-align: center;">MISCELLANEOUS:</p> <p>Provide backwater valve in sub-soil drain tile.</p> <p>Provide approved sheathing and flashing behind masonry veneer.</p> <p><input checked="" type="checkbox"/> Provide 15# felt underlayment on roof.</p> <p>Provide adequate fireplace hearth extensions</p> <p>Install factory built fireplaces/stoves according to manufacturers recommendations.</p> <p>Terminate chimney 3' above roof or 2' above highest point of building within 10' of chimney.</p>
--	---

ADDITIONAL CORRECTIONS: TREAT STUDS TO 18" ABOVE GRADE AND BOTTOM PLATE TO RESIST DECAY.

The approval of plans and specifications does not permit the violation of any section of the Building Code, or other City Ordinance or State Law. This addendum is attached to Permit No. 838-77 and made a part thereof.

Date Approved or Disapproved 9-29-77
 Date Rechecked and Approved _____

Checked By Ronald D. Sonnenberg
 Plan Examiner
 Checked By _____

#6.00

The undersigned having made an inspection of the construction, foundation, roof, replacement or addition of windows, doors, ventilation, etc. all work in strict accordance with the provisions of the Building Code of the City of Chicago, Illinois.

Owner's Name Kenneth Cohen AN Address RFD #3 NAPERCON. D

Builder's Name Same Address Same Tel. 592-4613

Occupancy Residential

Location of 615 Appian Ave. Lot 1

Subdivision 1st Prec Sq. Ft.

Front Set Back Front Left Side

Width 16.5' Street District "GB"

PLUMBING THEORIES

Water Sewer Gas Dry Construction

Plumbing Electrical

Refrigeration Heating Replacement

Work Required CARPENT

Height 24" Width 11'6" No. of Stories

Floor Area 1st Floor Sq. Ft. 2nd Floor Sq. Ft.

Basement Sq. Ft. Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Thickness Block Size

Walls: Frame Brick Other


Specific Dept. of Exemption SOLID VYNAL

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETE PROJECT 800.00


DATE 9-29-77 APPLICANT'S SIGNATURE Kenneth Cohen AN
OWNER-BUILDER-AGENT

2x6 Raf.



STUDS - 4x4 + 2x4

2x6 Raf.



STUDS - 4x4 + 2x4

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

766-77
\$6.00

The undersigned hereby makes application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name X Kenneth Cokeman Address X 515 APPAIN

Builder's Name X Same Address X NAPOLEON RD 3 Tel. X 592-4613

LOT INFORMATION: (Not required for roofing or siding job.)

Location of Project X 515 APPAIN NAP, OHIO Lot #

Subdivision Lot Area Sq. Ft.

Yard Set Back: Front Rear Left Side

Right Side Zoning District

BUILDING INFORMATION:

X Single ✓ Double Multiple New Construction

Addition Remodel Attached Garage

Detached Garage Accessory Building Replacement

Brief Description of Work: X New ROOF ON GARAGE

Size: Length Width No. of Stories X One

Floor Area: 1st Floor Sq. Ft. 2nd Floor Sq. Ft.

3rd Floor Sq. Ft. Basement Sq. Ft.

Unfinished Attic Garage

X Foundation: Piers Full Basement Part Basement

Concrete ✓ Thickness Block Size

Walls: Frame Block Brick Other


Specific Type of Exterior Siding

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: X 1200 DOLLARS

DATE X 6-28-77 APPLICANT'S SIGNATURE X Kenneth Cokeman
OWNER-BUILDER-AGENT

79 79 79 79 79 79 79 79 79 79
 79 79 79 79 79 79 79 79 79 79



2" x 6" - 16" o.c, CHG. 1ST,
 2" x 4" - 16" o.c, RAFTERS
 1/2" PLY SHEATHING