

CITY OF NAPOLEON INSPECTION FORM

PERMIT #: 98070

DATE ISSUED: 03-27-98

JOB LOCATION: 533 APPIAN AVE

OWNER: CARSON TERRY

OWNER PHONE: 419-592-3297

CONTRACTOR: ERIE CONSTRUCTION MID WEST INC

CONTRACTOR PHONE: 419-472-4000

WORK DESCRIPTION: REPLACEMENT OF ROOF, WINDOW, AND STORM DOOR

PLUMBING: UNDGR \_\_\_\_\_ RGHIN \_\_\_\_\_ FINAL \_\_\_\_\_

SEWER INSP \_\_\_\_\_

MECHANICAL: UNDGR \_\_\_\_\_ RGHIN \_\_\_\_\_ FINAL \_\_\_\_\_

FURNACE REPLC \_\_\_\_\_ AIR COND \_\_\_\_\_

ELECTRICAL: UNDGR \_\_\_\_\_ RGHIN \_\_\_\_\_ FINAL \_\_\_\_\_

SERV UPGR \_\_\_\_\_

BUILDING: SITE \_\_\_\_\_ FTG \_\_\_\_\_ FNDT \_\_\_\_\_

STRUC \_\_\_\_\_ ROOF 4-3-98 EXT \_\_\_\_\_

VENT \_\_\_\_\_ ACCES \_\_\_\_\_ EGRS \_\_\_\_\_

SMKDT \_\_\_\_\_ FINAL \_\_\_\_\_

ISSUE TEMP OCCUP \_\_\_\_\_ ISSUE OCCUP \_\_\_\_\_

STRG SHED: SITE \_\_\_\_\_ FINAL \_\_\_\_\_

SIGN: FTG \_\_\_\_\_ FINAL \_\_\_\_\_

FENCE: SITE \_\_\_\_\_ FINAL \_\_\_\_\_

MISC INSP: \_\_\_\_\_

NOTES: Checked 4-3-98, Contractor told to lay tar paper 50% overlapped on all pitch's 2/12 + less.

INSPECTOR INITIALS: \_\_\_\_\_