

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**  
**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

Permit No. 120 Date August 28, 1980  
Job Location 535 Appian Avenue Valuation \$ 70,000.00  
Owner James I. Shadle Address 1320 Ohio St.  
Contractor Robert Lenhart Telephone No. 599-4330  
Address Rt. 5 Napoleon  
Electric Contractor Jim Speiser & Sons  
Plumbing Contractor Standard Plbg. & Htg.  
Mechanical Contractor Robert Lenhart

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**Work Information:**

Residential XX 1 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
New Construction XX Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
Brief Description of Work New single family residence

ISSUED BY Richard G. Hayman Building Official  
*B.W.*

**PAID**  
DEPT. OF BUILDING & ZONING  
AUG 28 1980  
CITY OF NAPOLEON

**It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:**

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

**PERMIT & FEES**

Building Permit	\$ 114.00
Electrical Permit	\$ 35.00
Plumbing Permit	\$ 12.00
Mechanical Permit	\$ 6.00
Demolition Permit	\$
Zoning Permit	\$ -0-
Sign Permit	\$
Water Tap W80-10	\$ 300.00
Sewer Tap S80-9	\$ 60.00
Temp. Elec. E80-7	\$ 10.00
Other	\$
TOTAL FEES	\$ 537.00
LESS FEES PAID	\$ -0-
BALANCE DUE	\$ 537.00

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**

150

... of the County of Dallas, State of Texas, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the County of Dallas, State of Texas, this 15th day of ... 1950.

... of the County of Dallas, State of Texas, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the County of Dallas, State of Texas, this 15th day of ... 1950.

... of the County of Dallas, State of Texas, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the County of Dallas, State of Texas, this 15th day of ... 1950.

... of the County of Dallas, State of Texas, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the County of Dallas, State of Texas, this 15th day of ... 1950.

... of the County of Dallas, State of Texas, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the County of Dallas, State of Texas, this 15th day of ... 1950.

100 mm 7-28-76

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR HEATING PERMIT  
(PLEASE PRINT OR TYPE)

535 Appian

The undersigned hereby makes application for the installation, replacement or alteration of a heating system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name James F. Shadle Address 1320 Ohio St.  
Contractor's Name Robert Seonhart Address \_\_\_\_\_ Tel. \_\_\_\_\_

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction   
Addition \_\_\_\_\_ Remodel \_\_\_\_\_ Replacement \_\_\_\_\_ No. of Stories 1

DESCRIPTION OF WORK

Heating System - Warm Air \_\_\_\_\_ Hot Water \_\_\_\_\_ Steam \_\_\_\_\_ Electric \_\_\_\_\_

Unit Heaters \_\_\_\_\_ Unit Gas Heaters  Other \_\_\_\_\_

Type - Gravity \_\_\_\_\_ Forced  Radiant \_\_\_\_\_

No. of Thermostatical Heating Zone \_\_\_\_\_

Hot Water - One Pipe \_\_\_\_\_ Two Pipe \_\_\_\_\_ Series Loop \_\_\_\_\_

Electric Heat - No. of Circuits \_\_\_\_\_ Other \_\_\_\_\_

Total Heat Loss of Area to be Heated \_\_\_\_\_ Btu.

Rated Capacity of Furnace/Boiler 125,000 Btu.

No. of Furnaces \_\_\_\_\_ No. of Hot Air Runs 9

No. of Hot Water Radiators \_\_\_\_\_ Type of Fuel \_\_\_\_\_

Heating Units Located: BASINMENT Crawl Space  Floor Level \_\_\_\_\_ Suspended \_\_\_\_\_

Roof or Exposed to Outside Air \_\_\_\_\_ Attic \_\_\_\_\_ Other \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION OF FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: 70,000

DATE 8-25-80 APPLICANT'S SIGNATURE James F. Shadle  
OWNER-CONTRACTOR-AGENT

6.00



CITY OF NAPOLEON  
DEPARTMENT OF BUILDING & ZONING  
APPLICATION FOR  
CERTIFICATE OF OCCUPANCY

Address 535 APPAIN AVE Date 8-25-80

Zoning District \_\_\_\_\_

I, James I. Shadle owner hereby request that a Certificate of Occupancy be issued for the above address, more particularly described as follows: Lot 39 - New Ranch Dwelling

Building Area 2112.67 Occupancy Area 1465.59  
Prop. Parking Spaces 2 Exist. Parking Spaces —

Reason for Request

New Residence  
\_\_\_\_\_ Change in use or type of business from \_\_\_\_\_ to \_\_\_\_\_

Signed James I. Shadle  
Date August 25, 1980

Inspection Report: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Approved \_\_\_\_\_ CO# \_\_\_\_\_ Not Approved \_\_\_\_\_  
Reasons for not being approved \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signed \_\_\_\_\_  
Date \_\_\_\_\_



# APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

11/66  
12/66  
1/67  
2/67  
3/67

Owner JAMES SHADLE NO. 580-9  
 Address 1320 OHIO BLDG. PERMIT 120  
 Contractor LENHART PERMIT FEE \$ 60<sup>00</sup>  
 Address Rt. 5 TEL. 599-4330 DATE PAID 8-28-80

for office use only

LOCATION OF CONNECTION  
 Street and No. 535 Appian Sanitary  Storm   
 Lot No. 38-39 Subdivision Kimdale village Size of Tap 1  
 Size and Type of Sewer \_\_\_\_\_ ALL WORK MUST BE INSPECTED


I certify that the sewer will be used only as indicated and no other Drainage will be connected.  
 Date \_\_\_\_\_ Signature \_\_\_\_\_  
 owner-builder-agent  
 do not write below this line

## INSPECTION RECORD

Date Inspected 8-29-80 Size and Type of Sewer 4" PVC  
 Location Side to front Depth See Drawg Type of Test N/A  
 Inspected and Approved By: Bruce W. Mansch 8-29-80  
 Inspector Date  
 Additional Information \_\_\_\_\_

Send copy to \_\_\_\_\_

## SKETCH OF INSTALLATION







# PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING  
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 120 Date August 28, 1980  
Job Location 535 Appian Avenue Valuation \$ 70,000.00  
Owner James I. Shadle Address 1320 Ohio St.  
Contractor Robert Lenhart Telephone No. 599-4330  
Address Rt. 5 Napoleon  
Electric Contractor Jim Speiser & Sons  
Plumbing Contractor Standard Plbg. & Htg.  
Mechanical Contractor Robert Lenhart

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

### Work Information:

Residential XX 1 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
New Construction XX Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
Brief Description of Work New single family residence

ISSUED BY Richard C. Haysman DEPT. OF BUILDING & ZONING  
Building Official B.W.

**PAID**  
AUG 28 1980

*BASEMENT OMITTED DUE TO QUICK SAND*

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES		CITY OF NAPOLEON
Building Permit	\$ 114.00	
Electrical Permit	\$ 35.00	
Plumbing Permit	\$ 12.00	
Mechanical Permit	\$ 6.00	
Demolition Permit	\$ -0-	
Zoning Permit	\$	
Sign Permit	\$ 300.00	
Water Tap	\$ 60.00	
Sewer Tap	\$ 10.00	
Temp. Elec.	\$	
Other	\$ 537.00	
TOTAL FEES	\$ 937.00	
LESS FEES PAID	\$ -0-	
BALANCE DUE	\$ 937.00	

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

# INSPECTION RECORD

UNDERGROUND		ROUGH-IN				FINAL	
Type	Date	By	Type	Date	By	Type	Date
PLUMBING	Sewer Connection		Drainage, W. & Vent	11/13/82		Drainage, W. & Vent	
	Building Sewer		Water Piping	11/13/82		Water Heater	
	Water Piping		Condensate Lines			Backflow Prevention	
			Indirect Waste				
ELECTRICAL	Floor Ducts Raceways		Rough Wiring	11/24/82		FINAL APPROVAL	11/24/82
	Conduits & Cable		Conduits/Cable			Electric Mtr. Clearance	OK P4
	Grounding & Bonding		Service Panel	OK P4		Signs	
			Subpanels	OK P4			
MECHANICAL	Refrigerant Piping		Range & Dryer	OK P4		FINAL APPROVAL	11/24/82
	Ducts/Plenums		Refrigerant Piping			Duct Insulation	
			Ventilation & Supply			Chimney(s)	
			Exhst.			Furnace(s)	OK
BUILDING	Location, Set-backs, Esmt(s)	OK P4	Wall Construction	OK P4		FINAL APPROVAL	11/24/82
	Excavation	OK P4	Crawl Space	OK P4		Fireplace Chimney	
	Footings & Reinforcing	OK P4	Vent & Access			Attic	
	Sub-soil Drain		Floor System(s)			Special Insp Reports Rec'd	
	Foundation Walls	OK P4	Roof System	OK P4		Smoke Detector	OK P4
	Floor Slab		Fire Wall(s)			Demolition (sewer cap)	
		Roof Cover	OK P4		Building or Structure	OK P4	
		Roof Drain					
FINAL APPROVAL BLDG. DEPT.			Certificate of Occupancy Issued		#		

1. GFCI BATH-GARAGE EXTERIOR

2. STOPPER PUT ON CLOSURE ENCLOSURE BY CIRCUIT PANEL

3. FURNICE DOOR SOLID CORE

CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR PLUMBING PERMIT  
 (Please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only).

Owner's Name James T. Shadle Address 1370 Ohio

Plumbing Contractor STANDARD P.L.B. + H.T. Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

General Contractor Robert Lambert Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 535 Apair Ave Lot 39 Cost of Project 70,000

Work Information:

No. of dwelling units 1 New  Replacement \_\_\_\_\_ Addition \_\_\_\_\_

Brief description of work: \_\_\_\_\_

Is water tap required yes Size 1 Type of Pipe Copper

Is sewer tap required yes Size 4" Type of Pipe PVC

Type of Water Distribution pipe ~~PVC~~ Copper

Type of Drainage, Waste and Vent Pipe PVC

Size of main building drain 4 Size of main vent pipe 3

Water closets 2 Bathtubs 1 1 1/2 Shower 1 2"  
No. Trap Size No. Trap Size

Lavatories 2 1 1/4 Kitchen Sink 1 1 1/2 Disposal 1 1 1/2  
No. Trap Size No. Trap Size No. Trap Size


Dishwasher 1 NA. Clothes Washer 1 3" Other F.D. 3"  
No. Trap Size No. Trap Size No. Trap Size

PERMIT NO. \_\_\_\_\_  
 PERMIT FEE \$ 12.00

All installations are subject to plumbing tests and/or inspections.

Date 8-25-80 Applicant's Signature James T. Shadle







Plan review for James Shadle - Lot 39 - Appian Avenue

1. Backfilling shall not be commenced until after the walls are anchored to the floor.
2. Walls over 10-12 ft. in length shall have two No. 4 horizontal bars in the upper 12 inches of wall and No. 3 bars 18" on center running vertical.
3. Footer drains shall be provided around foundations enclosing habitable or usable spaces, located below grade 2" of crushed rock shall be provided under footer drains and strips of building paper shall protect joints and perforation of drain tiles and 6 inches of crushed rock shall cover the tile.
4. Smoke detector shall be installed in hall outside of bedroom.

