

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name T. W. Robus

Address 622 Arden Ct.

Builder Name Ronan Ruttle

Address 851 West Main St. Tel. 592-6671

Lot Information:

Street No. 622 Arden Ct.

Lot 41 Subdivision Outlot #1

Lot Dimensions Lot Area Sq. Ft.

Yard Set Back: Front Rear

Side Side

Zoning "B" Intended use of Building: Installing in the same location

Building Information:

Single Double Multiple New Construction Addition Remodel

Size: Length Width No. of Stories 2

Floor Area: 1st Floor 2nd Floor 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical: Wiring 100AMP Electric Heating Electrical Appliances

Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date Applicant Signature

Owner - Builder - Agent

Inspection Record:

Work Started Foundations Plumbing, Heating

Set Back, Side Lines Plumbing (Rough In) And Air Conditioning

Excavation Erecting Frame Roof

Footing Electrical Work 7/10/75 disapproved by Howes.

Comments: Final Electrical Approved by Howes 7/17/75

Certificate of Occupancy Issued

Pink - Engineer

Inspector

Permit No.	<u>203-75</u>		
Issued	<u>6/2/75</u>		
By	<u>Anna W. Serantora</u>		
	Building Inspector		
Valuation	<u>\$300.00</u>		
	Fees	Base	Plus
	Total		
Construction	---	---	---
Plumbing	---	---	---
Electrical	<u>\$3.00</u>	---	<u>\$3.00</u>
Heating	---	---	---
Water Tap	---	---	---
Sewer Tap	---	---	---
Temporary Elec.	---	---	---
TOTAL	<u>\$3.00</u>	---	<u>\$3.00</u>

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 7-10-75

Permit No. 293-75

Type of Inspection Elect Roughin

Type of Occupancy Dwelling

Project Name Roman 27' U

Address 622 Appen Ct

City NAP State Ohio

Approved

Violation

Electrical Contractor R. Tuttle

Remarks:

Code Reference

- ① Continuity of bonding must be assured at service equipment, use two locknuts at all terminations of conductors use bonded bushing at main C/B enclosure or in panel boards and attach ground conductors to bonded bushing 250-91d
- ② Prevent condensation building up in C/B fitting in basement on SA conductors 300-6
- ③ Neutral bus in main C/B below meter must be bonded to panel enclosure 380-2
- ④ Seal all unused openings in Panel Cabinets & etc 373-4

Corrected

Inspected by N. Howes 7/17/75

Compliance Time at once

Inspectors Signature N. Howes

Copies To:

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 5-15-75

Permit No. 308-75

Type of Inspection Rough-in

Type of Occupancy Residence

Project Name T.W. Rohrs

Address 622 ARDEN Ct.

City NAPOLEON State OHIO

Approved

Violation

Electrical Contractor

Remarks:

Code Reference

DURING AN ELECTRICAL INSPECTION RELATIVE TO AN INSTALLATION OF AIR CONDITION EQUIPMENT IN YOUR RESIDENCE AT THE ABOVE ADDRESS ON THE ABOVE MENTIONED DATE, THE FOLLOWING WAS NOTED-

1 Present service of 60A 120/230V 1φ not adequate to handle load, due to installation of air condition equipment. SEE ATTACHED SHEET.

2 SEVERAL HAZARDOUS CONDITIONS IN ELECT. WIRING IN BASEMENT SHOULD BE CORRECTED AT ONCE. SEE LIST BELOW:

A - REMOVE ALL ABANDONED WIRING.

B TYPE SE CABLE TO RANGE SPliced.

C SERVICE CABLE FROM MAIN CIR not suitable for condition.

D GROUND ELECT. SYSTEM TO CITY WATER LINE

Compliance Time 10 DAYS FROM RECEIPT Inspectors Signature T. Houtman

Copies To: Chief of Napoleon Fire Dept.

Given To Mrs Rohrs 5/29

White - Applicant

Yellow - Engineering

Pink - Electrical Inspector

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name T.W. Rohrs Address 622 Arden Ct.

Contractor's Name Roger Tuttle Address 851 West Main Tel. 5926671

LOT INFORMATION:

Location of Project _____ Zoning District _____

BUILDING INFORMATION:

Single Family X Double Family _____ Multiple Family _____

New Construction _____ Existing X Addition _____

Replacement X Remodel _____ Service Change X

Size: Total Square Foot Per Floor _____ No. of Stories 2

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only Yes (Yes or No)

Total Number of New Circuits none Total Number of New Circuits Excluding Appliance Circuits none

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric _____ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL TYP-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$ 160.00

DATE 6/10 75 APPLICANT'S SIGNATURE Roger Tuttle

OWNER CONTRACTOR-AGENT

Rohrs

Same location
of existing

NEW SERVICE
ENTRANCE
T.W. IRON S

