

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419) 592-4010

Electrical Permit

Permit Number: EL2008-18

Page 1 of 1

Printed: 5/8/2008

ADDRESS:

622 Arden Ct.

Applicant

Name: CV Electric
Address: Q 696 Co Rd 17 Rt 4

Approval Date: 5/7/2008
419--572-7957

Owners

Name: Mr. Tony Weiss
Address: 622 Arden St
Napoleon, OH 43545

Contractors

Contractor Type: Electrician
Name: CV Electric
Address: Q 696 Co Rd 17 Rt 4

Napoleon, OH 43545

Phone: 419--572-7957

Fees and Receipts:

Number	Description	Amount
FEE2008-248	electrical	\$15.00
FEE2008-249	State 1% fee (Calc)	\$0.15
Total Fees:		\$15.15
RCPT2008-166		\$15.00
RCPT2008-167		\$0.15
Total Receipts:		\$15.15

Service upgrade to 200 amp

APPLICANTS SIGNATURE: _____ DATE: _____

REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION





CITY OF NAPOLEON



BUILDING & ZONING DEPARTMENT
255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545
Telephone: 419/592-4010 Fax: 419/599-8393
www.napoleonohio.com

ELECTRIC METER BASE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" ELECTRIC METER BASE
(Please pickup at the City Operations Garage 1775 Industrial Drive)

Permit # EL2008-18

Date Issued: 5/7/2008

Job Location 922 Arden Ct.

Work Description: upgrade

Owner: Tony & Tammy Weiss
Address: 622 Arden Ct
Owner Phone:

Contractor: CV Electric
Contractor Phone: 419-572-7957

Electric Service Upgrade New Service Installation:

Industrial: Commercial Residential: 1 Phase 3 Phase

Size of Service: 100 Amps: 150 Amps: 200 Amps: 400 Amps Other

Hub Size: 1 1/4" 1 1/2" 2"
Desired Voltage: 120/240: Other: _____

Underground Service Overhead Service

Date Completed: _____ Approved By: _____

Old Meter Number: _____ New Meter Number: _____

Comments: _____

F

**THE CITY OF NAPOLEON
BUILDING & ZONING DEPARTMENT
255 W. RIVERVIEW
(419)592-4010**



Inspections

Page 1 of 1

Address: 622 Arden Ct.
Napoleon, OH 43545

Printed: 5/8/2008

Applicant: CV Electric

Permit Number: EL2008-18

Inspection Date: 5/8/2008

Inspector: Tom

Inspection Number: INSP2008-85

Status: Denied

Inspection Type: Electric Final

Passed?

Required Steps:

Comments: oked service change

Other Fields:

POHRS Residence

677 ARDEN Ct.

Napoleon, OHIO

LOAD CALCULATION TO DETERMINE
SERVICE,

APPROX. OR ESTIMATED LIVING SPACE
IN Sq ft.

1600 x 3W = 4800

2-APPL. CIRS 3000

LAUNDRY CIR 1500

RANGE 12000

A.C. & BLOWER - 6150

27450 W

FIRST 10K @ 100% 10,000

REMAINDER @ 40% 6980

16,980

74 Amps -

230 | 16,980

1610

880

(74)