

APPLICATION FOR PERMIT TO TAP SEWER

No. 706 Date May 13, 1976
Name Robert Beck (Gary Franz)
Address RT. 3 Napoleon

LOCATION OF CONNECTION

Street and Number 40 Bordesud Drive
Lot No. 11 Addition Riviera Heights

Date work will start _____ (All work must be inspected)

Work will be done by _____

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Bldg. Permit No. # 518-76
pa 5-29-76

Applicant _____

Date _____ Address _____

Permit Fee \$ 60.00 R. W. Schweinhagen (JC)
Certification by City Clerk

Work inspected By Tom Terranova

Work Completed June 18, 1976

Remarks Tested by means of 5 psi air test which dropped 2 psi in specified time period. All indications are drop is due to pin holes in pipe net installation.

Copy to: Robert Beck
R.R. #3
Napoleon, Ohio 43545

Name of contractor: Ron Meyers Size of Tap # 4" Date June 18, 1976

Street 40 Bordeaux Drive Size and Kind of Sewer 4" Vit. Clay

Old No. ----- Location of Sewer Front of House

New No. ----- Depth of Sewer 7'-6" @ Tap

Crossover ----- Distance to Curb Stop -----

Remarks Tested and approved June 18, 1976 By: *Donald D. ...*

