

629

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Colum S. Hurst
Address E SRIP Hickoryville D
Builder Name Watson Builders
Address Tel.

Permit No.
Issued 11-25-74
By [Signature]
Building Inspector
Estimated Cost 82,750

Lot Information:

Street No. 90 Bordeaux
Lot 16 Subdivision Riviera Hts - 6
Lot Dimensions 125 X 80 Lot Area 10,000 Sq. Ft.
Yard Set Back: Front 25 Rear 72
Side 17 Side 17

Sidewalk required in accordance with Ordinance No.

Fees	Base	Plus	Total
Construction		<u>72</u>	<u>72</u>
Basement			
Detached Garage			
Plumbing	<u>300</u>	<u>90</u>	<u>390</u>
Electrical	<u>320</u>	<u>675</u>	<u>995</u>
Heating	<u>60</u>		<u>60</u>
Air Conditioning			
Water Tap			
Sewer Tap			
Temporary Electric			
Total			<u>2117</u>

Building Information:

Residence L Commercial Industrial
Single ✓ Double Multiple New Construction ✓ Addition Remodel
Size: Length 41 Width 23-0 No. of Stories
Floor Area: 1st Floor 1027 2nd Floor 864 3rd Floor Basement
Unfinished Attic Garage
Foundation: Piers Full Basement Part Basement
Concrete Block
Walls: Frame Block Brick ✓ Other
Electrical Outlets: 120v 60 240v 3
Plumbing: Fixtures Traps 9 Vents Heating Air Conditioning
Additional Information:

Date 11-25-74 Applicant Signature [Signature]
Final Electrical inspected & approved by N. Howes 2/6/75
Final Plumbing approved and tested by Auf. on 11-25-74 1" water Col.

Inspection Record:

Work Started Foundations Poor found. Plumbing, Heating
Set Back, Side Lines Plumbing (Rough In) tested and approved by TWT 10/10/74 And Air Conditioning
Excavation Erecting Frame started 8-9-74 Roof Completed 8/22/74 P.W.P.
Footing 8 Cuyde 12-5-73 Electrical Work rough-in approved by Bob Meyers 8/29/74

Comments: Rough-in plumbing 10 Foothead test on waste lines and 80 P.SIG on water lines, P.W.P.

Certificate of Occupancy Issued on 2/7/75 No. 018
by [Signature] Inspector
Pink - Engineer

APPLICATION FOR PERMIT TO TAP SEWER

No. 629 Date 11-8, 19 73

Name Corinna C. Hurri

Address ESR18 Hixsville

LOCATION OF CONNECTION

Street and Number Bordeaux

Lot No. 16 Addition Riviera Heights

Date work will start _____ (All work must be inspected)

Work will be done by _____

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Applicant _____

Date 11-2-73 Address _____

Permit Fee \$60.00 Rupert W. Schmitzberger TC
Certification by City Clerk


pd 11-2-73
Bldg permit #120

Work Inspected _____

Work Completed _____

Remarks _____

Name _____ Size of Tap _____ Date _____
Street _____ Size and Kind of Sewer _____
Old No. _____ Location of Sewer _____
New No. _____ Depth of Sewer _____
Crossover _____ Distance to Curb Stop _____
Remarks _____



ST.




ST.



ST.

ST.



ST.



APPLICATION FOR PERMIT TO TAP SEWER

No. 629 Date 11-8, 19 73

Name Corinna C. Hurri

Address ESR18 Hicksville

LOCATION OF CONNECTION

Street and Number 90 Bordeaux

Lot No. 16 Addition Riviera Heights

Date work will start _____ (All work must be inspected)

Work will be done by _____

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Applicant _____

Date 11-2-73 Address _____

Permit Fee \$60.00 Rupert W. Schweinhagen J.C.
Certification by City Clerk

pd 11-2-73
Bldg Permt #120

Work Inspected _____

Work Completed _____

Remarks _____

Name _____ Size of Tap _____ Date _____

Street _____ Size and Kind of Sewer _____

Old No. _____ Location of Sewer _____

New No. _____ Depth of Sewer _____

Crossover _____ Distance to Curb Stop _____

Remarks _____



ST.




ST.



ST.

ST.



ST.



APPLICATION FOR PERMIT TO TAP SEWER

629

Date 11-8, 1973

Corinna C. Hurni

St. Rd. 18 East

LOCATION OF CONNECTION

16 Bordeaux Drive

Addition Riviera Heights

16

(All work must be inspected)

The sewer will be used only as indicated and no other
connections will be connected.

Applicant

Address

11-2-73

#60.00

Rupert W. Schweinhagen
Certification by City Clerk

pd 11-2-73

City Permit #120

and

approved by Tom Terranova on 9/20/74

Size of Tap 2 6"

Sept. 20, 1974

Size and Kind of Sewer

6" Clay Viti.

Location of Sewer

Front of Dwelling

Depth of Sewer


8' @ Tap

Distance to Curb Stop

Air tested and approved by Tom Terranova on 9/20/74

M

ST. M



ST.

M

Bordeaux Drive

M

Duquesne Drive ST. M

CITY OF NAPOLEON
Engineering Department
255 Riverview Avenue
NAPOLEON, OHIO 43545

DATE Jan 6, 1975	JOB NO. Permit No. 120-73
PROJECT New Home - Final Inspection	
LOCATION 90 Bordeaux Drive Riviera Heights Lot # 16	
CONTRACTOR Frank Watson Inc.	OWNER Corinne Hurm
WEATHER _____	TEMP. _____ ° at _____ AM _____ ° at _____ PM
PRESENT AT SITE Tom Terranova - Bldg. Insp. Norman Howes - Elect. Insp.	

TO Frank Watson Inc.
742 Coliseum Blvd. North
Fort Wayne, Indiana, 46805

THE FOLLOWING WAS NOTED:

On Jan 2, 1975 during "Final Inspection" and requires your attention before a "Certificate of Occupancy" shall be issued:

- 1) Provide any one of the three approved methods for handling run-off from downspouts. Attached you will find a sketch of the three approved methods.
- 2) Correct the two outlets on the second floor which has improper grounding. So indicated by red sticker. Art. 250 N.E.C.
- 3) Provide protection of nonmetallic sheathed cable for hot water heater. (Greenfield) Art. 300-4N

- Please contact the Engineering Dept. when ready for reinspection.

COPIES TO Frank Watson Inc. and on record with Bldg. permit No. 120-73

FIELD REPORT

SIGNED Tom W. Terranova
City Building Inspector

