

**CITY OF NAPOLEON**

**Engineering Department**

**ELECTRICAL INSPECTION FIELD REPORT**

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date 11-12-75

Permit No. 279-75E

Type of Inspection \_\_\_\_\_

Type of Occupancy Single Family Dwelling

Project Name Wayne Glore

Address 500 Briarcliff Dr.

City Napoleon State Ohio

Approved \_\_\_\_\_

Violation \_\_\_\_\_

Electrical Contractor Speiser Electric

**Remarks:**

**Code Reference**

Basement	45 x 31	-	1395	
1st Floor	45 x 24	-	1080	
"	41 x 21	-	861	
"	45 x 41	-	1845	
"	4 x 14	-	56	
Total sq. ft.	5237 @ 3 watt = 15,711			
General Ltg Load	15,711 watt			
Sm. Appl. Load	3,000 "			
Laundry Circuit	1,200 "			
Elect. Dryer	6,700 "			
Range	12,000 "			
Dishwasher	1,000 "			
Disposal	700 "			
Cent. Vac.	1,320 "			
	41,631 "			
Heat pump #1	8,000	First 10 KW @ 100%	10,000	
Heat pump #2	5,000	31631 @ 40%	12,652	
Sauna	8,000	Remainder @ 100%	23,000	
	21,000		45,652	
+25% of Demand	2,000	45,652 + 230 = 198.48 Amps.		
	23,000			

Compliance Time \_\_\_\_\_

Inspectors Signature Thomas H. Hoover

Copies To: \_\_\_\_\_

White - Applicant    Yellow - Engineering    Pink - Electrical Inspector

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name WAYNE GLOBE

Address 500 BURNING CLIFF DR.

City Napoleon State OHIO

Approved

Violation

Electrical Contractor Spoiser

Remarks:

Code Reference

1975

Installation of UF Cable, Front Entrance Not approved as such. Comply with.

Art. 300-5 (EX 3) Art. 300-5 (d)

Compliance Time Prior to Pour

Inspectors Signature

Copies To: Jim Spoiser Electric

DATE Dec. 19, 1975	JOB NO. 379-75	
PROJECT New Single Family Dwelling		
LOCATION 500 Briarcliff Drive		
CONTRACTOR Lanzer Co.	OWNER Glore	
WEATHER _____	TEMP. _____ °at	AM
	_____ °at	PM
PRESENT AT SITE Tom Terranova - Building Insp. Norman Hawes - Electrical Insp.		

TO McL Lanzer Co.  
2266 N. Scott St.  
Napoleon, Ohio, 43545

THE FOLLOWING WAS NOTED:

2/10/76 Violation - ~~Wood~~ or combustible framing shall not be placed within 2" of outside face of masonry fireplace. Sec. R-921.

Violation - All spaces between masonry fireplaces and wood beams, headers, joists or trimmers shall be firestopped by placing non-combustible material to a depth of 1" at the bottom of such spaces, Sec. R-922.

- Re-inspection required prior to enclosing.

Reminder:

- Provide not less than 1,642 sq ins of net free area ventilation, at the highest point of the attic area, Sec. 507.2

- Provide not less than 547 sq ins of net free area ventilation for crawl space area. Sec. 507.3

~~- A cleanout shall be provided at or near the foot of each vertical soil stack, Figure Not B-A~~

~~- Provide joint headers for fireplace header~~

2/10/76 Not Required, Stubb C/o. P.W.P.

2/10/76 Completed inspected by J.W.P.

COPIES TO McL Lanzer Co. And  
Mr. Wayne Glore

FIELD REPORT

SIGNED Thomas D. Shaver

CITY OF NAPOLEON  
ENGINEERING DEPARTMENT  
APPLICATION FOR PLUMBING PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of plumbing system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Code for 1, 2 and 3 Family Building.

Owner's Name Melmas Wayne Glone Address Napoleon, O

Contractor's Name Stanley P.H. Address Napoleon Tel. 5925906

LOT INFORMATION:

Location of Project \_\_\_\_\_ Lot # 59

Subdivision ANTHONY WAYNE #4 Zoning District 5

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple Family \_\_\_\_\_ New Construction

Addition \_\_\_\_\_ Remodel \_\_\_\_\_ Replacement \_\_\_\_\_ No. of Stories 1

DESCRIPTION OF WORK

Drainage Pipe of: Cast Iron \_\_\_\_\_ Copper \_\_\_\_\_ Other PVC.

Size of Main Building Drain: 4"  Other \_\_\_\_\_

Size of Main Vent Stack: 3" \_\_\_\_\_ 4"  Other \_\_\_\_\_

Require Water Tap: yes. (Yes or No) Require Sewer Tap: yes. (Yes or No)

Size and Type of Water Tap 3/4" Type K Copper

Size and Type of Sewer Tap \_\_\_\_\_ Type of Joints \_\_\_\_\_

No. of Water Closets 4 No. of Sump Pumps \_\_\_\_\_

No. of Bathtubs 2 No. of Lavatories 6

No. of Kitchen Sinks 3 No. of Automatic Washers 1

No. of Disposals 1 No. of Hot Water Heaters 1

No. of Dishwashers \_\_\_\_\_ No. of Shower Receptors 1

No. of Floor Drains 3 Other (specify) \_\_\_\_\_

Storm Drainage Outlet to: Storm Sewer \_\_\_\_\_ Other Link

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF A DRAINAGE ISOMETRIC, WITH ALL PIPES AND TRAPS PROPERLY SIZED. MUST INDICATE TOTAL DRAINAGE FIXTURE UNIT VALUE (dfu).

ESTIMATED COST OF COMPLETED PROJECT: 3500.00

DATE SEP 7, 1976 APPLICANT'S SIGNATURE Harold Nelson  
OWNER-CONTRACTOR-AGENT

Name of Contractor: McL Lanzer Co. Size of Map 6" Date 10-10-75

Street 500 Briarcliff Drive Size and Kind of Sewer 6" Vitrified

Old No. \_\_\_\_\_ Location of Sewer in front of hse.

New No. \_\_\_\_\_ Depth of Sewer @ Man hole 9'-6"

Crossover \_\_\_\_\_ Distance to Curb Stop \_\_\_\_\_

Remarks: Tested and Approved by: [Signature] 10-10-75

