

DATE	JULY 26, 1976	JOB NO.	565-76
PROJECT	SINGLE FAMILY DWELLING		
LOCATION	485 BUCKEYE LANE		
CONTR. CYOR	ZACHRICH	OWNER	HERSHBERGER
WEATHER		TEMP.	° at AM ° at PM
PRES. AT SITE			
ADDENDUM "B" TO PLAN			
APPROVAL			

TO
RON ZACHRICH
R.R.#2
NAPOLEON, OHIO

THE FOLLOWING WAS NOTED:

- 1) PROVIDE APPROVED FLASHING WITH PROPER LAPPING TO PROTECT FLOOR JOIST HEADER, SEC. R-503
- 2) PROVIDE AT LEAST ONE (1) APPROVED SMOKE DETECTOR IN HALL ON THE CEILING NEAR BEDROOMS, SEC. R-216
- 3) MAINTAIN NOT LESS THAN 16" FROM FIREPLACE OPENING TO EDGE OF HEARTH, SEC. R-924
- 4) A LANDING SHALL BE PROVIDED ON EACH SIDE OF STAIRS TO BASEMENT HAVING A MIN. WIDTH AND DEPTH OF 3' IF DOOR SWINGS OVER STAIRS, EXCEPTION: A LANDING IS NOT REQUIRED WHERE THE DOOR DOES NOT SWING OVER STAIRS, SEC. R-213
- 5) SPAN OF GARAGE CEILING JOIST ~~23'-6"~~, THEREFORE PROVIDE NOT LESS THAN 2"X10" SPACED 24" O.C. TABLE NO 7-B
- 6) ATTIC ACCESS SHALL BE NOT LESS THAN 22"X30". SEC. R-706
- 7) STAIRS RISE, RUN AND HEADROOM TO CONFORM TO SEC. R-215
- 8) PLUMBING AND HEATING PERMIT SHALL BE OBTAINED PRIOR TO STARTING INSTALLATION.
- 9) PROVIDE NOT LESS THAN 274 SQ. IN.'S NET FREE VENTILATION IN CRAWL SPACE, SEC. 507.3

COPIES TO _____

SIGNED _____