

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT  
(1, 2 or 3 Family Dwelling)**

Owner Name Robert Hershberger

Address 622 Strong St.

Builder Name Van Deylen Plg. & Htg.

Address 1080 Glenwood Ave. Tel. 592-4756

**Lot Information:**

Street No. 485 Buckeye Lane.

Lot 106 Subdivision Anthony Wayne 5th

Lot Dimensions See plats Lot Area 27,498 Sq. Ft.

Yard Set Back: Front Conform to Dist. "B" Rear Min. 20'

Each Side 10' Total Side Min. 25.6'

Zoning "B" Intended use of Building: Plumbing permit for new single family dwelling

**Building Information:**

Single  Double \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction  Addition \_\_\_\_\_ Remodel \_\_\_\_\_

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ No. of Stories \_\_\_\_\_

Floor Area: 1st Floor \_\_\_\_\_ 2nd Floor \_\_\_\_\_ 3rd Floor \_\_\_\_\_ Basement \_\_\_\_\_

Unfinished Attic \_\_\_\_\_ Garage \_\_\_\_\_

Foundation: Piers \_\_\_\_\_ Full Basement \_\_\_\_\_ Part Basement \_\_\_\_\_

Concrete \_\_\_\_\_ Block \_\_\_\_\_

Walls: Frame \_\_\_\_\_ Block \_\_\_\_\_ Brick \_\_\_\_\_ Other \_\_\_\_\_

Electrical: Wiring \_\_\_\_\_ Electric Heating \_\_\_\_\_ Electrical Appliances \_\_\_\_\_

Plumbing: Fixtures or Traps  (11) Warm Air Heating \_\_\_\_\_ Hot Water Heating \_\_\_\_\_

Additional Information: \_\_\_\_\_

Date 5-12-76 Applicant Signature Edward Van Deylen

Owner - Builder - Agent

**Inspection Record:**

Work Started 8-5-76 Foundations \_\_\_\_\_ Plumbing, Heating \_\_\_\_\_

Set Back, Side Lines \_\_\_\_\_ Plumbing (Rough In) APR 30 1976 And Air Conditioning \_\_\_\_\_

Excavation \_\_\_\_\_ Erecting Frame \_\_\_\_\_ Roof \_\_\_\_\_

Footing \_\_\_\_\_ Electrical Work \_\_\_\_\_

Comments: \_\_\_\_\_

Certificate of Occupancy Issued \_\_\_\_\_

Pink - Engineer

Inspector

Permit No. 585-767

Issued August 5, 1976

By Thomas W. Stranov  
Building Inspector

Valuation \$2,567.00

Fees	Base	Plus	Total
Construction			
Plumbing	\$3.00	\$11.00	\$14.00
Electrical			
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
<b>TOTAL</b>	<b>\$3.00</b>	<b>\$11.00</b>	<b>\$14.00</b>

12/16/76: FINAL PLUMBING TESTED AND APPROVED BY A.P.P.

BELOW SLAB ONLY APPROVED BY A.P.P. 3/5/76  
ABOVE SLAB APPROVED BY A.P.P. 9/30/76

# APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

Owner Robert Hershberger NO. 715  
Address 622 Strong Street BLDG. PERMIT 565-76  
Contractor Ren Zachrish PERMIT FEE \$ 60.00  
Address R.R. #2 Napoleon, Ohio Tel. X 762-5277 DATE PAID 8-3-76  
for office use only

## LOCATION OF CONNECTION

Street and No. 485 Buckeye Lane Sanitary  Storm   
Lot No. 106 Subdivision Anthony Wayne Acres 5th Size of Tap 4"  
Size and Type of Sewer 4" Vit. Clay ALL WORK MUST BE INSPECTED

I certify that the sewer will be used only as indicated and no other Drainage will be connected.


Date \_\_\_\_\_ Signature \_\_\_\_\_ owner-builder-agent  
do not write below this line

## INSPECTION RECORD

Date Inspected OCTOBER 25, 1976 Size and Type of Sewer 4" VIT. CLAY PREM. JOINT  
Location FRONT OF HSE Depth 9' @ TAP Type of Test 10' HEAD WATER  
Inspected and Approved By: Thomas W. Branda OCT. 25, 1976  
Inspector Date  
Additional Information \_\_\_\_\_

Send copy to: ROBERT HERSHBERGER

## SKETCH OF INSTALLATION



December 23, 1976

SUBSTANTIAL QUALIFICATION OF OCCUPANCY  
SINGLE FAMILY DWELLING

Location: 485 Buckeye Lane  
Building Permit No. 565-76  
Certificate of Occupancy No. 093

This Substantial Qualification of Occupancy is attached to and made a part hereof. The following item requires your attention in order to comply with the National Electrical Code:

Receptacle outlet mounted in the medicine cabinet located in the half bath shall be protected by means of a ground-fault circuit (G.F.C.I.) or completely disconnected from power source.  
Article 210-8 of N.E.C. 75'

Compliance Time: Thirty (30) days from the date of this notice.

Please call for re-inspection when this condition has been corrected. Acceptance and approval by an inspector of the Building Department is required.

cc: Ron Zachrich

CONNECTIONS DISCONNECTED  
OUTLET, 1/13/77 J.M.F.

Ron Zachrich

Robert Hershberger

