

**PERMIT**

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 29-79 Issued 3-27-79  
date

Job Location 525 Buckeye Lane  
address

Lot 102 Anthony Wayne 5th Addition  
sub-div or legal discript

Issued By R.E. Johnson  
building official

Owner Dennis Krupinski 592-6983  
name tel.

Address 525 Buckeye Lane

Agent Rausch Lumber Co. 592-3866  
builder-eng.-etc. tel.

Address 118 W. Front St.

Description of Use Garage

Residential XX one  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. XXX Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 5,000.00

**ZONING INFORMATION**

district <u>S</u>	lot dimensions <u>SEE SITE PLAN</u>	area	front yd <u>n/a</u>	side yds <u>30' E</u>	rear yd <u>Min 20' OK</u>
max hgt <u>---</u>	no pkg spaces <u>OK</u>	no ldg spaces <u>n/a</u>	max cover <u>---</u>	petition or appeal req'd <u>---</u>	date appr <u>---</u>

**WORK INFORMATION:**

Size: Length 26' 4" Width 22' Stories 1 Ground Floor Area 520sq'

Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: 4 new circuits.  
brief description

Plumbing: \_\_\_\_\_  
brief description


Mechanical: \_\_\_\_\_  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
type

Additional Information: CALL FOR REQUIRED INSPECTIONS:

Date 4/4/79 Applicant Signature Ronald F. Rausch  
owner-agent

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$16.50		\$16.50
<input checked="" type="checkbox"/> ELECTRICAL	5.00	\$4.00	9.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING	0		0
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$25.50
LESS MIN. FEES PAID			0
		date	
BALANCE DUE.....			\$25.50





CITY OF NAPOLEON  
Engineering Department  
APPLICATION FOR

ELECTRICAL PLAN APPROVAL  
(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.  
FOR ENGINEERING OFFICE USE ONLY.

App. No. 29-79

Date Received .....

Received By .....

Estimated Cost \$5,000.00

Minimum Fees

A. Structural .....

B. At ..... Per 100 Ft.<sup>2</sup> .....

A. plus B. \$16.50

3. Plans Prepared By: ELEC. 9.00

A. Architect .....

B. Engineer .....

C. Other RAUSCH LBR. CO.

1. Owner's Name MR. DENNIS KRUPINSKI

Address 525 BUCKEYE LANE

NAPOLEON, OHIO 43545 Tel. 592-6983

2. Owner's Agent or Submitter .....

RAUSCH LUMBER CO. INC.

Address 118 W. FRONT ST.

NAPOLEON, OHIO 43545 Tel. 592-3866

4. Name of Job and Description of Building, Store, Church, Etc. ....

GARAGE ADDITION TO THE EXISTING HOUSE.

5. Location of Project: 525 BUCKEYE LANE Zone: .....

Lot # 102 Subdivision A.W. 5th. add. Section .....

6. Building Information:

Commercial ..... Industrial ..... New Construction .....

Addition X Remodel .....

7. Size: Length 22'-0" Width 20'-4" with a 6'-0" x 12'-0" storage area.

Total Square Ft. Per Floor 512

8. Size Service Entrance 200 Amp. Existing.

9. All electrical wiring shall be installed in accordance with the National Fire Protection Association, Bulletin No. 70, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.

10. Additional Information: 4 CIRCUITS.

Signature of Applicant Ronald F. Rousell Date March 15, 1979

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - Plan Examiner

METROPOLITAN PLANNING APPROVAL  
Application No. 1000-17-0000

1. General description of the proposed project  
2. Description of the site and its location  
3. Description of the existing conditions  
4. Description of the proposed conditions  
5. Description of the proposed improvements  
6. Description of the proposed landscaping  
7. Description of the proposed parking  
8. Description of the proposed signage  
9. Description of the proposed lighting  
10. Description of the proposed security

1. General description of the proposed project  
2. Description of the site and its location  
3. Description of the existing conditions  
4. Description of the proposed conditions  
5. Description of the proposed improvements  
6. Description of the proposed landscaping  
7. Description of the proposed parking  
8. Description of the proposed signage  
9. Description of the proposed lighting  
10. Description of the proposed security

1. General description of the proposed project  
2. Description of the site and its location  
3. Description of the existing conditions  
4. Description of the proposed conditions  
5. Description of the proposed improvements  
6. Description of the proposed landscaping  
7. Description of the proposed parking  
8. Description of the proposed signage  
9. Description of the proposed lighting  
10. Description of the proposed security

1. General description of the proposed project  
2. Description of the site and its location  
3. Description of the existing conditions  
4. Description of the proposed conditions  
5. Description of the proposed improvements  
6. Description of the proposed landscaping  
7. Description of the proposed parking  
8. Description of the proposed signage  
9. Description of the proposed lighting  
10. Description of the proposed security

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 6-23-79

Permit No. 29-79

Type of Inspection Rough

Type of Occupancy Garage

Project Name Krupinski

Address 525 Buckeye Lane

City Nap State Oh

Approved [Signature] for covering

Violation \_\_\_\_\_ Electrical Contractor \_\_\_\_\_

Remarks:

Code Reference

All receptacles except for those open inside garage & receptacles on outside of garage must be GFCI protected

210-8 NEC

Compliance Time \_\_\_\_\_

Inspectors Signature N. Hines

Copies To: \_\_\_\_\_



September 14, 1976

SUBSTANTIAL QUALIFICATIONS OF OCCUPANCY  
SINGLE FAMILY DWELLING @ 525 BUCKEYE LANE  
CERTIFICATE OF OCCUPANCY NO. 078

Mr. Joseph Fortner  
525 Buckeye Lane  
Napoleon, Ohio 43545

This substantial qualifications of occupancy is attached and made a part hereof. The following items require your attention:

- 1) Upon completing installation of all lighting fixtures, please contact the Building Department for final electrical inspection.
- 2) Second floor, master bedroom bathroom ceiling mount fan remains to be connected to exhaust duct in attic. Also, where the exhaust duct terminates outside, a screen should be installed to prevent insects from entering the dwelling.

*10/29/76 RE-INSPECTED  
AND APPROVED  
BY [Signature]*

*3/17/77 RE-INSPECTED & APPROVED  
BY [Signature]*

