

APPLICATION FOR PERMIT TO TAP SEWER

No. 673 Date 8/5, 1975  
Name Bill Frible  
Address 324 Maumee Lane

LOCATION OF CONNECTION

Street and Number 585 Buckeye Lane  
Lot No. 96 Addition Anthony Wayne Ave 5th  
Date work will start \_\_\_\_\_ (All work must be inspected)  
Work will be done by \_\_\_\_\_

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Bldg. Permit # 346.75  
8/4/75  
pd 8/5/75

Date \_\_\_\_\_ Applicant \_\_\_\_\_  
Address \_\_\_\_\_

Permit Fee \$60.00 R.W. Schweinhager (J.C.)  
Certification by City Clerk

Work inspected by Thomas W. Terranova - Bldg. Inspector

Work Completed And Tested ON 8/11/75 (5psi. Air Test, 15 mins.)

Remarks Contractor, Ron Meyers PLL & Ht. Co.

Name \_\_\_\_\_ Size of Tap 4" Date 8/1/75


Street \_\_\_\_\_ Size and Kind of Sewer \_\_\_\_\_

Old No. \_\_\_\_\_ Location of Sewer Front of Bldg.

New No. \_\_\_\_\_ Depth of Sewer @ Tap 10'

Crossover \_\_\_\_\_ Distance to Curb Stop \_\_\_\_\_

Remarks 4" Vitrified Clay Sewer Pipe with  
Precast plastic joints.



Name \_\_\_\_\_ Size of Tap **4** Date **8/1/75**


Street \_\_\_\_\_ Size and Kind of Sewer \_\_\_\_\_

Old No. \_\_\_\_\_ Location of Sewer **Front of Bldg.**

New No. \_\_\_\_\_ Depth of Sewer **@ Tap 10'**

Crossover \_\_\_\_\_ Distance to Curb Stop \_\_\_\_\_

Remarks **4" Vitrified Clay Sewer Pipe with  
Precast plastic joints.**





Residential

# Meyers Heating

Commercial

NAPOLEON, OHIO

www

PHONE 592-6771

Beck Const. Inc.

2 story

