

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 1066 Chelsea Ave. ZIP: 43545
 Business Name: George Cochran DDS.

DEVICE INFORMATION

Type (circle one) **RP** DC VB RPDA DCDA

Manf/Model: Wilkins 975 XL Size: 1" Serial No. 1043516

Location of Device: Furnace room

Type of Test: Differential Gauge Sight Tube

Outlet valve holding RP <input checked="" type="checkbox"/> DC <input type="checkbox"/> failed RP <input type="checkbox"/> DC <input type="checkbox"/>	Reduced Pressure Assembly ↓			Pressure Vacuum Breaker	
	Double Check Valve ↓		Relief Valve ↓	Air Inlet	Check Valve
	1st Check	2nd Check			
Test Results Pass	DC _____ psi RP <u>9.2</u> psi	DC _____ psi	opened at <u>2.8</u> psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date: <u>4-24-02</u>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>
Repairs & Materials					
Test After Repairs	DC _____ psi RP _____ psi	DC _____ psi RP _____ psi	opened at _____ psi did not open <input type="checkbox"/>	opened at _____ psi did not open <input type="checkbox"/>	held at _____ psi leaked <input type="checkbox"/>
Date:	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>	Pass <input type="checkbox"/> Failed <input type="checkbox"/>

Tester Signature: Brian Jeff Certification No. 611
 Owner/Representative Signature: Nicole W. Jiehelm