

City of Napoleon Inspection Form

Permit #002205

Date Issued: 06-01-2004

Job Location: 935 CLAIRMONT AVE

Owner: SICKMILLER, JAMES

Owner Phone: 419-592-3371

Contractor: SELF 256-6139

Contractor Phone:

Work Description: ELECTRIC SERVICE UPGRADE

Plumbing: UNDGR _____ RGHIN _____ FINAL _____
 SEWER INSP _____

Mechanical: UNDGR _____ RGHIN _____ FINAL _____
 FURNACE REPLAC _____ AIR COND _____

Electrical: UNDGR _____ RGHIN _____ FINAL _____
 SEVR UPGR _____

Building: Site _____ FTG _____ FNDDT _____
 STRU _____ ROOF _____ EXT _____
 VENT _____ ACCES _____ EGRS _____
 SMKDT _____ FINAL _____
 ISSUE TEMP OCCUP _____ ISSUE OCCUP _____

STGE Shed: SITE _____ FINAL _____

Sign: FTG _____ FINAL _____

Fence: SITE _____ FINAL _____

MISC INSP: _____

NOTES: 6-18-04
Mounted too high @ 6.5' to center Specs call for
5' to center of meter base.

INSPECTORS INITIALS: _____