

Certificate of Occupancy

Wood County Building Inspection

Address: BUSCH EVENTS CENTER 130 EAST CLINTON STREET NAPOLEON, OH 43545 County: Henry		Stipulations, Conditions, & Variances: Alterations. All Inspections Completed. Occupancy Approved. Maximum Occupancy is 195.				
Approved As:		This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.				
	Use Groups:				Occupancy Description:	
Primary	A-2				Banquet Center	
Accessory	B				Business Center	
Accessory	R-2				Residential Occupancy	
Accessory	0					
Mixed Use	0					
Attached Floor Plan: <input type="checkbox"/>						
Construction Type: 3B						
Sprinklers						
System Type: NFPA 13		Demand:				
Standpipe:		Demand:				
Location: Throughout						
Specific Hazards: Note: All Fire Sprinklers and Fire Alarm systems are required to be tested, monitored, and certified annually for this Occupancy Approval to remain valid. Existing Kitchen area is only approved for warming of food, cooking is prohibited.		OBC Ed. 2017	OMC Ed. 2017	OPC Ed. 2017		
		Health and Safety OBC Section 111.1				
		Plan Approval/Building Permit No: B19-000095				
		Date: 09/24/2019				
		Chief Building Official: Michael J. Rudey				