

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name St. Augustine Church
 Address 221 E. Clinton St. (Rectory)
 Builder Name Jim Speiser Electric
 Address Napoleon, Ohio Tel. 599-1846

Lot Information:

Street No. 221 E. Clinton St. (Rectory)
 Lot 103 Subdivision Original Plat
 Lot Dimensions n/a Lot Area n/a Sq. Ft.
 Yard Set Back: Front n/a Rear n/a
 Side n/a Side n/a

Zoning "GB" Intended use of Building: Service Change & Rewiring

Building Information:

Single Double Multiple New Construction Addition Remodel
 Size: Length Width No. of Stories 2
 Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
 Unfinished Attic Garage
 Foundation: Piers Full Basement Part Basement
 Concrete Block
 Walls: Frame Block Brick Other
 Electrical: Wiring New 200 Amp Electric Heating Electrical Appliances
 Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating
 Additional Information:

Date 1-5-77 Applicant Signature [Signature]

NOTE: 1/27/77 SERVICE EQUIPMENT AND BASEMENT INSPECTED AND APPROVED BY HOWES. IMPROPER WIRING OF RECEPTACLE OUTLETS IN THE NORTH EAST AND SOUTH WEST BEDROOMS ON 2ND FLOOR. I INFORMED JIM SPEISER TODAY AND ASKED HIM TO INFORM DEPT WHEN CORRECTED FOR RE-INSPECTION. [Signature]

Inspection Record:

Work Started Foundations Plumbing, Heating
 Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
 Excavation Erecting Frame Roof
 Footing Electrical Work

Comments: HOWES SENT LETTER TO SIREKER ABOUT REVIEWING ART. 230-24 NEC. 2/17/77. RE-INSPECTED AND APPROVED BY HOWES. MIKE SPEISER INFORMED ABOUT FILLING BLANKS IN PERM.

Certificate of Occupancy Issued

| | | | | |
|-----------------|---|---------------|-------------|---------------|
| Permit No. | <u>649-77</u> | | | |
| Issued | <u>January 5, 1978</u> | | | |
| By | <u>Ronald D. Sonnenberg</u> Building Inspector | | | |
| Valuation | <u>\$800.00</u> | | | |
| | Fees | Base | Plus | Total |
| Construction | | | | |
| Plumbing | | | | |
| Electrical | <u>\$3.00</u> | <u>\$1.75</u> | | <u>\$4.75</u> |
| Heating | | | | |
| Water Tap | | | | |
| Sewer Tap | | | | |
| Temporary Elec. | | | | |
| TOTAL | <u>\$3.00</u> | <u>\$1.75</u> | | <u>\$4.75</u> |

CITY OF NAPOLEON

BUILDING

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date January 21, 1977

Permit No. 649-77

Type of Inspection Service Only

Type of Occupancy Dwelling

Project Name St. Augustine Church

Address 221 E. Clinton St. (Rectory)

City Napoleon State Ohio

Approved

Violation

Electrical Contractor Jim Spelser Electric

Remarks:

Code Reference

please review Article 230-24 N.E.C. and comply in the future.

Compliance Time

Inspectors Signature Thomas A. Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

649-77

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name St. Augustine Church ^{Rectory} Address E. Clinton Street Napoleon

Contractor's Name Jim Speiser Electric Address Napoleon Tel. 599-1846

LOT INFORMATION:

Location of Project E. Clinton Street Zoning District

BUILDING INFORMATION:

Single Family Double Family Multiple Family

New Construction Existing Addition

Replacement Remodel Service Change

Size: Total Square Foot Per Floor No. of Stories 2

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only (Yes or No)

Total Number of New Circuits 6 Total Number of New Circuits Excluding Appliance Circuit

APPLIANCE CIRCUITS: (Indicate quantity)

Electric Range 1 Range Hood 1 Clothes Dryer 1 Dishwasher 1

Air Conditioner 2 Attic Fan Blower Room Exhaust Fan

Disposal Hot Water Heater 1 Electric Oven

Require Temporary Electric No (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$ 800.00

DATE 1/5/77


APPLICANT'S SIGNATURE

JIM SPEISER ELECTRIC
James C. Speiser
XXXXX - CONTRACTOR - XXXXX

4.00
3.75
#4.75


POWER COMPANY
SERVICE DROP

3-3/8 THW IN 2" CONDUIT



200A. METER

3-3/8 THW IN 2" CONDUIT



SERVICE EQUIPMENT
200A. MAIN 125/230V 1 ϕ 3WS
WITH 40 BRANCH CIRCUITS
TOTAL OF 42 CIRCUITS

#4 BARE STRANDED
UPPER GROUND



JIM SPEISER ELECTRIC
R. R. 2 BOX 201
PH. 599 1846 NAPOLEON, OHIO 43545

