

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01089 Issued Sept. 11, 1985
date

Job Location 221 E. Clinton
address

Lot _____
sub-div or legal discript

Issued By Richard G. Hayman
building official

Owner St. Augustine School
name tel.

Address 221 E. Clinton

Agent Mike Speiser 592-8356
builder-eng.-etc. tel.

Address 1048 E. Riverview

Description of Use Temporary service pole for
educational vehicle

Residential _____
no. dwelling units

Commercial XXXX Industrial _____

New _____ Add'n. _____ Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 300.00

FEE'S	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	5.00	1.00	<u>86.00</u>
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			<u>80.00</u>
LESS MIN. FEES PAID <u>SEPT 12/85</u> date			<u>6.00</u>
BALANCE DUE.....			<u>74.00</u>

ZONING INFORMATION

district GB	lot dimensions		area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr	

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: _____

Date _____ Applicant Signature _____
owner-agent

PAID
SEP 12 1985
CITY OF NAPOLEON

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping	9/13/85 8/5/85		Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		<i>9/13/85</i>
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		<i>9/13/85</i>
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		<i>9/13/85</i>
BUILDING	Location, Set-backs, Esmi(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
			Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued			
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01089 Issued Sept. 11, 1985 date

Job Location 221 E. Clinton address

Lot _____ sub-div or legal discript

Issued By Richard G. Hayman building official

Owner St. Augustine School name tel.

Address 221 E. Clinton

Agent Mike Speiser 592-8356 builder-eng.-etc. tel.

Address 1048 E. Riverview

Description of Use Temporary service pole for educational vehicle

Residential _____ no. dwelling units

Commercial XXXX Industrial _____

New _____ Add'n. _____ Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 300.00

FEES	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	<u>5.00</u>	<u>1.00</u>	<u>80.00</u>
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			<u>80.00</u>
LESS MIN. FEES PAID _____ date			<u>-0-</u>
BALANCE DUE.....			<u>80.00</u>

ZONING INFORMATION

district <u>GB</u>	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____ brief description _____

Plumbing: _____ brief description _____

Mechanical: _____ brief description _____

Sign: _____ type _____ Dimensions _____ Sign Area _____

Additional Information: _____

Date _____ Applicant Signature _____ owner-agent

PAID

SEP 12 1985

CITY OF NAPOLEON

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name St Augustine School Address 221 E Clinton Monroe

Electrical Contractor Mike's Electric Telephone No. 592-8856
Address 1048 E Riverview

General Contractor _____ Telephone No. _____
Address _____

Location of Project Monroe St Cost of Project \$300.00

Work Information:

Residential _____ Commercial School Industrial _____
No. Units _____
New Service Change _____ Rewiring _____ Additional Wiring _____

Brief Description of Work: Temporary service to
special service trailer

Size of proposed service entrance 50 Number of new circuits 01

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric no (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 9-11-85 Applicant's Signature Mike's Electric

PERMIT NO. 1089
PERMIT FEE \$ 6.00

