

# PERMIT

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 210-78 Issued 11-29-78  
date

Job Location 318 E. Clinton St.  
address

Lot n/a  
sub-div or legal discript

Issued By R.D. Sonnenberg  
building official

Owner Robert Kolbe  
name tel.

Address 980 Glenwood Ave.

Agent Self  
builder-eng.-etc. tel.

Address \_\_\_\_\_

Description of Use Split Elec. Service in Duplex

Residential two  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. \_\_\_\_\_ Alter ~~XXXX~~ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 50.00

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

### WORK INFORMATION:

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ Stories \_\_\_\_\_ Ground Floor Area \_\_\_\_\_

Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: Split Existing elec. Service for duplex.  
brief description

Plumbing: \_\_\_\_\_  
brief description

Mechanical: \_\_\_\_\_  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
type

Additional Information: CALL FOR INSPECTIONS MARKED ON ATTACHED SHEET:

Date 11-29-78 Applicant Signature Robert Kolbe  
owner-agent

FEES	BASE	PLUS	TOTAL
BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$5.00	0	\$5.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$5.00
LESS MIN. FEES PAID _____			0
			<small>date</small>
BALANCE DUE.....			\$5.00

PAID  
 NOV 29 1978  
 CITY OF NAPOLEON

# INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
<b>PLUMBING</b>	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
<b>MECHANICAL</b>	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/ Plenums			Ducts/ Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
<b>ELECTRICAL</b>	Conduits & or Cable			Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampolders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
<b>BUILDING</b>	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
<b>ADDITIONAL</b>	<b>INSPECTIONS, CORRECTIONS, ETC.</b>						<b>INSPECTIONS, CORRECTIONS, ETC.</b>					
	<i>100 amp service required - Art-230-41 b</i>											
	<i>Insulated neutral from service disconnect (see) to - Panel per: Article 338-3 b</i>											
	<i>Grounding Conductor #6 Table 250-94</i>											

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)

210-78  
\$5.00

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Robert V. Kolbe Address 980 Glenwood  
Contractor's Name SELF Address \_\_\_\_\_ Tel. \_\_\_\_\_

LOT INFORMATION:

Location of Project 318 E. CLenton Zoning District RENTel

BUILDING INFORMATION:

Single Family \_\_\_\_\_ Double Family  Multiple Family \_\_\_\_\_  
New Construction \_\_\_\_\_ Existing  Addition \_\_\_\_\_  
Replacement \_\_\_\_\_ Remodel \_\_\_\_\_ Service Change   
Size: Total Square Foot Per Floor \_\_\_\_\_ No. of Stories 2

DESCRIPTION OF WORK

Size of Service \_\_\_\_\_ AMP. Service Change Only YES (Yes or No)

Total Number of New Circuits NONE Total Number of New Circuits Excluding Appliance Circuits NONE

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range NONE Range Hood NONE Clothes Dryer NONE Dishwasher NONE

Air Conditioner NONE Attic Fan Blower NONE Room Exhaust Fan NONE

Disposal NONE Hot Water Heater NONE Electric Oven NONE

Require Temporary Electric NO (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

Estimated cost of completed project: \$50.00

DATE 11-29-78 APPLICANT'S SIGNATURE Robert V. Kolbe  
OWNER-CONTRACTOR-AGENT





CITY OF NAPOLEON  
Engineering Department  
255 Riverview Avenue  
NAPOLEON, OHIO 43545

DATE	12-14-78	JOB NO.	210-78
PROJECT	SPLIT ELECT. SERVICE		
LOCATION	318 E. CLINTON ST. 980 GLENWOOD AVE		
CONTRACTOR	OWNER		
WEATHER	TEMP.	° at	AM
		° at	PM
PRESENT AT SITE			
ELECTRICAL INSPECTION			

TO

Robert Kolbe  
980 Glenwood Ave,  
Napoleon, Ohio

THE FOLLOWING WAS NOTED:

- 1) MINIMUM 100 A SERVICE REQUIRED, ART-230-41 NEC
- 2) INSULATED NEUTRAL REQUIRED FROM SERVICE DISCONNECT TO PANEL BOARD. ART. 338-3 NEC
- 3) MINIMUM #6 CU GROUNDING ELECTRODE CONDUCTOR REQUIRED AT SERVICE. TABLE 250-94 NEC
- 4) SERVICE CONDUCTORS TO BE SIZED AS OUTLINED IN NOTES TO TABLES 310-16 THROUGH 310-19 NEC.
- 5) DISTRIBUTION PANEL TO BE SIZED IN ACCORDANCE WITH 100 A. SERVICE ART 220- NEC

CALL FOR INSPECTION WHEN VIOLATIONS  
HAVE BEEN CORRECTED.

COPIES TO ROBERT KOLBE

FIELD REPORT

SIGNED N. Hovens

