

City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

June 30, 1982



Mayor
Robert G. Heft

Mr. Don W. Rohrs
918 Woodlawn
Napoleon, OH 43545

Clerk-Treasurer
Rupert W. Schweinhagen

Dear Mr. Rohrs:

Members of Council
Lawrence Haase, President
James Jackson
William Young
Darel Auster Miller
Darrell Fox
James Zumfelde

It has come to my attention that your house at 323 E. Clinton has a sewer line break in the basement. This break shall be corrected before rental of the house. The basement floor has raw sewage laying on it and is a matter of health to any occupants.

City Manager
Richard A. Hayward

Upon inspection of the basement, it was noted that there were numerous electrical violations within the basement and that the electric service to the house is only 60 amps. The National Electric Code requires 100 amp services for residential dwellings. Correction of the electrical within the dwelling and the installation of a 100 amp service shall be required before the house is rented.

Law Director
Keith P. Muehlfeld

Your cooperation in this matter is appreciated.

Yours truly,

Richard G. Hayman
Building Commissioner

RGH:dd

*Plumbing corrected
8/30/82*

*House completely
rehabed by Jones
6/29/84*