

# METER YOKE RELEASE

This document is for the release of one (1) Water Meter Yoke for Residential water service lines.

RELEASE NO. \_\_\_\_\_

PERMIT NO. 3809 ISSUED 3-25-96

JOB LOCATION 125 W. Clinton

- Inside City Limits       - Outside City Limits

ISSUED BY BND

OWNER Family Video (810) 939-5975

ADDRESS 1022 E. Adams St. Springfield IL 62703

CONTRACTOR West Valley Develop. Inc. 865-0366

ADDRESS 5633 Aspen Suite A Toledo, Oh

CONTRACTOR'S PHONE NO. 865-0366

WATER TAP SIZE:  = 1"       = 1-1/2"       = 2"

WATER METER s# \_\_\_\_\_

- New Dwelling       - Existing Dwelling

- Lawn Meter

Water Service Line to be Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.

Watts No. 007 Dual check required  = Yes       = No

Water Meter Yoke installation is subject to the following conditions:

- 1.) Must be located in an accessible area.
- 2.) Must be in an area not subject to freezing temperatures.
- 3.) Must be eighteen inches (18") above floor level, not in crawl spaces.
- 4.) Must comply with the mounting criteria and clearances as set forth in DRAWING #04403901.