

Woodlawn

N
1"=20'

U

DATE: 9-21-12

INSPECTED BY: MATTY
CROSSLAND

INVESTIGATION OF ILLEGAL
DOWNSPOUT CONNECTIONS
AT 220 W. CLINTON ST.
FOUND TWO (2) TO BE IN
VIOLATION. ONE HAS BEEN
WAIVED FOR SAFETY PURPOSES
AT THE NOTCH EDGE OF THE
DRIVE-UP WINDOW AWNING.
THE OTHER HAS BEEN
DISCONNECTED AND REROUTED
TO THE SOUTH SIDE OF THE
BUILDING.

WAIVED
FOR SAFETY
& ICE
PROBLEMS

REROUTED

220
W. CLINTON ST.

WEST CLINTON STREET

