



City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010
FAX (419) 599-8393

November 06, 2000

Mayor
J. Andrew Small

Mr. Benny Dawson
564 Becklee Dr.
Napoleon, Ohio 43545

Members of Council
Michael J. DeWit, President
Terri A. Williams
James Hershberger
Travis B. Sheaffer
John A. Helberg
David F. Miller, Jr.
Glenn A. Miller

Re. 229 W. Clinton St.

Dear Mr. Dawson

Upon inspection of the subject home I find the following Building Code and City ordinance violations;

City Manager
Dr. Jon A. Bisher

1. Electrical service does not meet current City of Napoleon regulations.
2. There exists a storm water cistern which is not permitted in the City limits of Napoleon.
3. Numerous wiring connections and devices not up to national electric code standards.
4. Water heater relief valve does not have a down tube which is required by the plumbing code.
5. Loose plaster in various areas of the home.

Finance Director
Gregory J. Heath

Law Director
David M. Grahn

City Engineer
Joseph R. Kleiner, P.E.

Please make the corrections herein as soon as feasible.

Sincerely

Brent N. Damman
Building Commissioner

Post-it® Fax Note	7671	Date	# of pages ▶
To	Peggy Bohles	From	Brent Damman
Co./Dept.		Co.	
Phone #	256-6213	Phone #	592-4010
Fax #		Fax #	599-8393