

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 735 Date Oct. 31, 1983

Job Location 323 W. CLINTON Address Valuation \$ 890.00

Owner GUSTAV CONRAD Name Address 323 W. Clinton

Contractor Cochran Electric Telephone No. 592-0891

Address 525 N. Perry

Electric Contractor _____

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential Single Family Commercial _____ Industrial _____
No. dwelling units

New Construction _____ Addition _____ Remodel _____

Brief Description of Work Change service and add four circuits

ISSUED BY Richard A. Hayman Building Official DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- X _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- X _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>9.00</u>
LESS FEES PAID	\$ _____
BALANCE DUE	\$ _____

PAID
OCT 31 1983
CITY OF NAPOLEON

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PERMIT
CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 735
 Job Location 323 W. CLINTON Address _____ Valuation \$ 890.00 Date Oct. 31, 1983
 Owner GUSTAV CONRAD Name _____ Address 323 W. Clinton
 Contractor Coolman Electric Name _____ Address _____ Telephone No. 592-8891
 Address 525 S. Perry
 Electric Contractor _____
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:
 Residential Single Family Commercial _____ Industrial _____
No. dwelling units
 New Construction _____ Addition _____ Remodel _____
 Brief Description of Work Change service and add four circuits

ISSUED BY _____ DEPT. OF BUILDING & ZONING
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>9.00</u>
LESS FEES PAID	\$ _____
BALANCE DUE	\$ _____

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

PAID
 OCT 31 1983
 CITY OF NAPOLEON

INSPECTION RECORD

UNDERGROUND		ROUGH-IN			FINA/		
Type	Date	By	Type	Date	By	Date	
PLUMBING	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent	
	Building Sewer		Water Piping			Water Heater	
	Water Piping		Condensate Lines			Backflow Prevention	
			Indirect Waste				
ELECTRICAL	Floor Ducts Raceways		Rough Wiring			FINAL APPROVAL	
	Conduits & or Cable		Conduits/ Cable			Electric Mtr. Clearance	
	Grounding & or Bonding		Service Panel			Signs	
			Subpanels				
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer				FINAL APPROVAL
			Refrigerant Piping				Duct Insulation
MECHANICAL	Ducts/ Plenums		Ducts/ Plenums			Chimney(s)	
			Ventilation <input type="checkbox"/> Supply			Furnace(s)	
			<input type="checkbox"/> Exhst.			FINAL APPROVAL	
	Location, Set-backs, Esmt(s)		Wall Construction			Fireplace Chimney	
BUILDING	Excavation		Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access	
	Footings & Reinforcing		Floor System(s)			Special Insp Reports Rec'd	
	Sub-soil Drain		Roof System			Smoke Detector	
	Foundation Walls		Fire Wall(s)			Demolition (sewer cap)	
	Floor Slab		Roof Cover Roof Drain			Building or Structure	
	FINAL APPROVAL BLDG. DEPT.		FINAL APPROVAL				#
			Certificate of Occupancy Issued				

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name GUSTAV CONRAD Address 323 W CLINTON

Electrical Contractor COCHRAN ELECTRIC Telephone No. 592-0891

Address 525 N PERRY ST

General Contractor _____ Telephone No. _____

Address _____

Location of Project 323 W CLINTON Cost of Project 890⁰⁰

Work Information:

Residential 1 Commercial _____ Industrial _____

No. Units

New _____ Service Change X Rewiring _____ Additional Wiring 4 circuits

Brief Description of Work: CHANGE SERVICE & ADD FOUR CIRCUITS

Size of proposed service entrance 100 Number of new circuits 4

Type of proposed service entrance _____ Underground _____ Overhead X

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 10-31-83 Applicant's Signature Guyon Myers

PERMIT NO. 735
PERMIT FEE \$ 9.00

