

411 W. Clinton St.

Napoleon, Ohio, 43545

subject Electrical Inspection of 8/22/74 Permit No. 106-74

← FOLD

The following condition was noted:

One more mast strip required @ bend in conduit.

Once complied with, call in for work order to be energized.

(corrected 9/5/74 P. M. J.)

date Aug 23, 1974 signed

Thomas W. Swanson
City Building Inspector

date

signed

SENDER: Mail white and pink copies with carbon intact.

RECEIVER:

Reply, retain white copy, return pink copy.

33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010