

CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
 (1, 2 or 3 Family Dwelling)

Permit No.	318-75		
Issued	8/16/75		
By	Thomas W. Brennan Building Inspector		
Valuation	\$300.00		
Fees	Base	Plus	Total
Construction	--	--	--
Plumbing	--	--	--
Electrical	\$3.00	\$4.75	\$7.75
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
TOTAL	\$3.00	\$4.75	\$7.75

Owner Name Mrs. Walter Kossan
 Address 730 W. Clinton St.
 Builder Name Harold Bontelman Electrical Co.
 Address 618 Park St. Tel. 592-2383
Lot Information:
 Street No. 730 W. Clinton St.
 Lot ---- Subdivision Wm. Sheffield's 3rd
 Lot Dimensions ----- Lot Area ----- Sq. Ft. -----
 Yard Set Back: Front ----- Rear -----
 Side ----- Side -----

Zoning "C" Intended use of Building: Installing to the existing dwelling a new 150AMP service entrance (unground) and a new distribution panel located inside the building.

Building Information:
 Single Double Multiple New Construction Addition Remodel
 Size: Length ----- Width ----- No. of Stories -----
 Floor Area: 1st Floor ----- 2nd Floor ----- 3rd Floor ----- Basement -----
 Unfinished Attic Garage
 Foundation: Piers Full Basement Part Basement
 Concrete Block
 Walls: Frame Block Brick Other
 Electrical: Wiring Electric Heating Electrical Appliances
 Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.
 Date 8-6-75 Applicant Signature Harold Bontelman
 Owner - Builder - Agent

Note: 8/7/75 informed owner wise to installed railing to basement. A.W.F.

Inspection Record:
 Work Started ----- Foundations ----- Plumbing, Heating -----
 Set Back, Side Lines ----- Plumbing (Rough In) ----- And Air Conditioning -----
 Excavation ----- Erecting Frame ----- Roof By Howes
 Footing ----- Electrical Work 8/7/75 Service approved, but grounding of panel not, so panel requires inspection.
 Comments: 8/14/75 Panel inspected & approved by Howes

Certificate of Occupancy Issued ----- Inspector -----
 Pink - Engineer

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

ELECTRICAL PLAN APPROVAL
(Please Print or Type)

20 circuit
panel

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

1. Owner's Name WALTER-KONSEN
Address 734 WEST CLINTON
NAPOLEON Tel. 592-6456

1.75
6.00
7.75

App. No.
Date Received
Received By
Estimated Cost

Minimum Fees

A. Structural
B. At Per 100 Ft.²
A. plus B.

2. Owner's Agent or Submitter
HAROLD BOSTELMAN
Address 618 PARK
..... Tel. 592-2383

3. Plans Prepared By:
A. Architect
B. Engineer
C. Other

4. Name of Job and Description of Building, Store, Church, Etc. HOUSE

5. Location of Project: 734 WEST-CLINTON Zone:
Lot # Subdivision Section

6. Building Information:
Commercial Industrial New Construction
Addition Remodel

7. Size: Length Width
Total Square Ft. Per Floor

8. Size Service Entrance 150 Amp.

9. All electrical wiring shall be installed in accordance with the National Fire Protection Association, Bulletin No. 13, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.

10. Additional Information: Replacement Present 60 Amp. Entrance

Signature of Applicant Date

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - Plan Examiner

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

ELECTRICAL PLAN APPROVAL

(Please Print or Type)

App. No. _____
Date Received _____
Received By _____
Estimated Cost _____
Minimum Fee _____
A. Structural _____
B. Air _____ Per 100 sq. ft.
A. plus B. _____
3. Plans Prepared By _____
A. Architect _____
B. Engineer _____
C. Other _____

432

216.00

A 270
B 280
C 2

564

188.00

23580

600

4. Name of Building _____
5. Location of Project _____
6. Building Information _____
7. Size: Length _____
Total Square ft. Per Floor _____
8. Size Service Entrance _____ Amps.

576

288.00

360

648

324.00

40580

9. All electrical wiring shall be installed in accordance with the National Fire Protection Association's Bulletin No. 12, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.
10. Additional Information _____
Signature of Applicant _____
Date _____

520

2600

325