

# City Of Napoleon

## FIELD SURVEY FORM

Premises Address: R-028 Corridor 12 Company Name: The Ribbon Interlock Plaza  
Contact Name: Paul Grewal Contact Phone No: 599-6065  
Service No: 4312 Service Size: 2" Meter No: 70014576 Meter Size: 2" Date Installed: 5-22-10  
Type of Inspection: Initial  Follow-Up  Date of Inspection: 1-14-98 Inspector Name: Charles  
Type of Use: Industrial  Commercial  Residential  Water Main Size: 16" System Pressure 100 PSI  
Type of Service: Domestic  Fire  Combined  Any Other Water Source: Yes  No   
If Yes, Other Type: Additional City Service  Auxiliary Source  Interconnected: Yes  No   
\*\*\*\*\*

### DOMESTIC SYSTEMS

Type of Use: Processing  Product  Potable  Sanitary  Irrigation  Limited Area Fire   
Type of Heating: Forced Air  Electric  Solar  Boilers  Chemical Treatment: Yes  No   
Type of Cooling: Cooling Tower  Chiller  Chemical Treatment: Yes  No  Direct Conn: Yes  No   
Dishwasher: Yes  No  Eductors: Yes  No  Garbage Disposal: Yes  No  Jacuzzi: Yes  No   
Swimming Pool: Yes  No  Air Gap at Supply: Yes  No  Pumps Used: Yes  No  Capacity

Keep Fire Equipment in Tallest Building System 724 9971

### INSPECTOR COMMENTS/DIAGRAMS

CO2 hooked up to fountain

Limited area Dry Chemical Fire System in kitchen

### FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler  Wet Sprinkler  Dry Riser  Wet Riser  Hydrants: Yes  No   
Hydrants Self-Draining: Yes  No  Storage Provided: Yes  No  Antifreeze Legs: Yes  No   
Auxiliary Water Storage: Yes  No  Pumps Used: Yes  No  Capacity: \_\_\_\_\_ (GPM) Pressure: \_\_\_\_\_

### INSPECTOR COMMENTS/DIAGRAMS

### BACKFLOW PREVENTION REQUIREMENTS

a 2" Reduced Pressure Assembly must be installed after your water meter.  
You may want to consider a 2 1/2" device depending on your water demand