



City of NAPOLEON

ENGINEERING DEPARTMENT

255 W. Riverview Avenue, PO Box 151, Napoleon, OH 43545
Phone: 419-592-4010 - Fax: 419-599-8393

Mayor

J. Andrew Small

April 18, 2006

Members of Council

Glenn A. Miller
President

Mr. David Geringer, P.E.
201 Ditto Street
Archbold, Ohio 43502

Terri A. Williams
Ronald Behm
Travis B. Sheaffer
John A. Helberg
Steven C. Small
Michael J. DeWit

Re: T.M.T. Warehousing Waterline Extension
P-314 County Road 12
Napoleon, Ohio 43545

City Manager
Dr. Jon A. Bisher

Dear Mr. Geringer,

Upon review of the plans for the above referenced project, the following items need to be addressed:

Drawing No. 1 of 2:

1. Call out a 12" M.J. Plug on the end of the proposed 12" waterline.

Drawing No. 2 of 2:

1. Please revise Waterline Note No. 2. The City of Napoleon only allows No. 12 stranded copper electrical wire (THHN).
2. Please revise Waterline Note No. 10. Add the sentence, "All drain holes shall be plugged by the manufacturer prior to delivery."
3. Please revise Waterline Note No. 12. The City of Napoleon only allows EBAA Iron Inc. Series 2000 PV for mechanical joints and Series 1600 Restraint Harness for PVC bell joints.
4. Waterline Note No. 29 is the same as Waterline Note No. 28. One (1) of these shall be deleted. Was an additional note omitted?
5. All valves and fire hydrants shall only be operated by authorized personnel.

If you have any questions or require additional information, please contact me at your convenience. Please note that these are the comments of the City of Napoleon. Comments from the Henry County Regional Water & Sewer District have been enclosed.


Yours truly,

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

CEL/als

Enclosure

cc: Tim Schumm, P.E., Henry County Regional Water & Sewer District Director
Jeff Marihugh, City of Napoleon Operations Superintendent
Dr. Jon A. Bisher, City of Napoleon City Manager



City of NAPOLEON

ENGINEERING DEPARTMENT

255 W. Riverview Avenue, PO Box 151, Napoleon, OH 43545
Phone: 419-592-4010 - Fax: 419-599-8393

Mayor

J. Andrew Small

April 24, 2006

Members of Council
Glenn A. Miller
President

Mr. David Geringer, P.E.
201 Ditto Street
Archbold, Ohio 43502

Terri A. Williams
Ronald Behm
Travis B. Sheaffer
John A. Helberg
Steven C. Small
Michael J. DeWit

Re: T.M.T. Warehousing Waterline Extension
P-314 County Road 12
Napoleon, Ohio 43545

Dear Mr. Geringer,

City Manager
Dr. Jon A. Bisher

Upon review of the revised plans for the above referenced project, the submitted plans are approved for construction pending approval of the Ohio E.P.A., the Henry County Regional Water & Sewer District, and City of Napoleon's review of the backflow prevention device. If you have any questions or require additional information, please contact me at your convenience.

Finance Director
Gregory J. Heath

Yours truly,

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

Law Director
David M. Grahn

City Engineer
Chad E. Lulfs, P.E., P.S.

CEL/als

cc: Tim Schumm, P.E., Henry County Regional Water & Sewer District Director
Jeff Marihugh, City of Napoleon Operations Superintendent
Dr. Jon A. Bisher, City of Napoleon City Manager

MEETING MINUTES

Date: March 31, 2006

Location: Oakwood Plaza, Henry County Commissioner's Conference Room

Attendance: Chad E. Lulfs, P.E., P.S., City of Napoleon Engineer
Lee Schroeder, C.I.C. Director
Tim Schumm, P.E., Henry County Water & Sewer District
Scott Nagel, Vernon Nagel Construction
Bob Bennett, City of Napoleon Fire Chief
Bill Meyers, TMT

Re: Expansion of TMT property on County Road 12 – Extension of water main.

Summary:

The purpose of this meeting was to discuss with TMT what the City of Napoleon requires to allow the extension of the existing twelve (12) inch waterline along County Road 12. This extension is for the proposed expansion at the TMT site. Mr. Meyers asked what he needed to do to allow Mr. Nagel to begin laying pipe on the site. I informed Mr. Meyers that the City of Napoleon requires four (4) sets of plans and a copy of the Permit to Install from the Ohio E.P.A.; the City of Napoleon would not give any sort of consent until the plans had been reviewed. Mr. Meyers accused the City of Napoleon of doing anything and everything possible to deny businesses the ability to expand operations. I explained to Mr. Meyers that the City of Napoleon would do everything it could to help business owners expand operations, but that the City of Napoleon would not bend the rules for it to happen. Mr. Meyers excused himself from the meeting to calm himself.

I contacted Mr. Bennett to see if he would be available to comment on Fire Protection issues. He arrived and explained what was necessary to have proper Fire Protection.

CEL

NEW FILE

TMT EXPANSION
(2006)