



# CITY OF NAPOLEON

**BUILDING & ZONING DEPARTMENT**  
255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545  
Telephone: 419/592-4010 Fax: 419/599-8393  
[www.napoleonohio.com](http://www.napoleonohio.com)

## WATER METER YOKE RELEASE FORM

**THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" WATER METER YOKE ASSEMBLY**  
(Please pickup at City Operations Department 1775 Industrial Drive.)

**Permit Number: out of town commercial**

**Date Issued: 12/7/2006**

**Job Location P-314 CR 12**

Owner: Bill Meyers  
Address: P-314 CR 12

Phone: 419-592-1041

Contractor: WR Meyers  
Phone:

Water Tap Size: 1" 1 1/2" 2" Other: 2"  
Water Meter Yoke Size: 5/8" 3/4" 1" Other  
New Structure: Existing Structure: Lawn Meter:

**WATER SERVICE LINE TO BE TYPE "K" COPPER OR "CTS" POLYETHELENE TUBING OF 1" MINIMUM SIZE.**

Backflow Device Required? Yes  No   
Type of Backflow Required: \_\_\_\_\_

Water Meter Yoke Installation is subject to the following conditions:

1. Must be located in an accessible area.
2. Must be in an area which is not subject to freezing temperatures.
3. Must be at least 18" above floor level (no crawl space installations.)
4. Must comply with minimum mounting requirements (drawings available).

Issued By: \_\_\_\_\_ Received By: \_\_\_\_\_

1 Copy to: Building Dept, Water Dept.

3 meters

COPY