

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON, Building Dept.
255 West Riverview Avenue
Napoleon, Ohio 43545
(419) 592-4010

ADDENDUM to Permit No. 578
Owner BRECK
Location 630 Gipple

Please note the Items checked below and incorporate them into your plans as indicated: Permit not yet issued
 Correct Plans and Re-Submit. Permit issued Incorporate the Items during construction.

GENERAL	
<input checked="" type="checkbox"/>	Provide 1 approved smoke detector.
<input checked="" type="checkbox"/>	Provide 1 hour fire wall and/or ceiling between garage and dwelling.
<input checked="" type="checkbox"/>	Provide (Class B) 1 hour fire rated door from garage to dwelling.
	Submit fully dimensioned plot plan.
	Provide 1-3'0" x 6'8" exit door.
<input checked="" type="checkbox"/>	Provide min. 22" x 30" attic access.
	Provide min. 18" x 24" crawl space access opening.
LIGHT AND VENTILATION:	
	Provide mechanical exhaust or window in bathroom.....
	Provide Min. _____ sq. in. net free area attic ventilation.
	Provide min. _____ sq. in. net free area crawl space ventilation.
FOUNDATION:	
	Min. depth of foundation below finished grade 30".
	Min. size of footer....." x"
	Provide anchor bolts 1/2" @ 8' o.c. 1' from each corner. Embedded 8" concrete and 15" in masonry.
	Show size of basement columns.
FRAMING:	
	Show size of wood girder in.....
	Provide design data for structural member in.....
	Floor joists under sized in.....
	Provide double joists under parallel partitions.
	Provide 1" x 4" let in corner bracing or approved sheathing.
	Show size of headers for openings over 4' wide.
	Show size of members supporting porch roof.
	Provide double top plate.
	Provide design data for pre-fab. wood truss/members.
	Ceiling joists undersized in.....
	Roof rafters undersized in.....
PLUMBING AND MECHANICAL:	
<input checked="" type="checkbox"/>	Terminate all exhaust systems to outside air.
<input checked="" type="checkbox"/>	Insulate ducts in unheated areas.
	Provide back flow device on all hose bibs.
ELECTRICAL:	
	Show location of service entrance and service equipment panel.
	G.F.C.I. req'd. on Temp. Electric.
<input checked="" type="checkbox"/>	Outdoor and bathroom receptacles shall be protected by G.F.C.I.
METAL VENEERS:	
	Contact City Utilities Dept. to remove conductors and/or meter.
	Provide 18" x 18" x 3/4" wood backer for meter base.
	Provide approved system of grounding and bonding.
MISCELLANEOUS:	
	Provide backwater valve in sub-soil drain tile.
	Provide approved sheathing and flashing behind masonry veneer.
	Provide 15# felt underlayment on roof.
	Provide adequate fireplace hearth extensions
	Install factory built fireplaces/stoves according to manufacturers recommendations.
	Terminate chimney 3' above roof or 2' above highest point of building within 10' of chimney.

ADDITIONAL CORRECTIONS: _____

The approval of plans and specifications does not permit the violation of any section of the Building Code, or other City Ordinance or State Law. This addendum is attached to Permit No. 578 and made a part thereof.

Date Approved or Disapproved 3/10/83

Checked By Richard A. Taylor
 Plan Examiner

Date Rechecked and Approved _____

Checked By _____