

# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01234 Issued 8-22-86  
date

Job Location 667 Cripple Creek Ct.  
address

Lot 4 Cripple Creek Sub Div.  
sub-div or legal discript

Issued By Eldon Huber  
building official

Owner Mike and Kay Lawson  
name tel.

Address 320 Maumee Lane Apt. 1

Agent Beck's Construction  
builder-eng.-etc. tel.

Address 11622 Rd. M. Napoleon, Ohio

Description of Use Residence

---

Residential 1  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New X Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 57,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	91.50	94.50
<input checked="" type="checkbox"/> ELECTRICAL	5.00	20.00	25.00
<input checked="" type="checkbox"/> PLUMBING	3.00	10.00	13.00
<input checked="" type="checkbox"/> MECHANICAL	6.00	.00	6.00
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			.00
<input type="checkbox"/> SIGN			
WATER TAP	300.00		300.00
SEWER TAP	60.00		60.00
TEMP. ELECT.			10.00
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$508.50
LESS MIN. FEES PAID _____			
BALANCE DUE.....			

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
A	100' x 102.53'				
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35' Max.	2- Min.		35%		

### WORK INFORMATION:

Size: Length 57'-2" Width 44'-4" Stories 1 Ground Floor Area 2092 S.F.

Height 16' Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: 200 Amp Service and 20 Circuits  
brief description

Plumbing: 2 - Baths, Kitchen, and Laundry 1" Water Tap  
brief description

Mechanical: 90,000 B.T.U. Gas Furnace  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
type

Additional Information: New Residence

Date Sept 3 1986 Applicant Signature Robert L Beck owner-agent

CITY OF NAPOLEON  
**SEP 3 1986**

# INSPECTION RECORD

UNDERGROUND			ROUGH-IN						FINAL			
Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By	
<b>PLUMBING</b>	Building Drains	10/21	EH	Drainage, Waste & Vent Piping	10/27	EH	Indirect Waste		Drainage, Waste & Vent Piping	12/11	EH	
	Water Piping	10/21		5"					Backflow Prevention			
	Building Sewer			Water Piping	10/27	EH	Condensate Lines		Water Heater	12/11	EH	
				80"								
	Sewer Connection								FINAL APPROVAL	12/11	EH	
<b>MECHANICAL</b>	Refrigerant Piping			Refrigerant Piping			Chimney(s)		Grease Exhaust System			
				Duct Furnace(s)			Fire Dampers		Air Cond. Unit(s)			
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)		Refrigeration Equipment			
				Duct Insulation			Pool Heater		Furnace(s)			
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.		FINAL APPROVAL	12/11	EH	
<b>ELECTRICAL</b>	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer		Temp Service Temp Lighting			
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors		Fixtures Lampholders			
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder		Signs			
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable		Electric Mtr. Clearance			
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)		FINAL APPROVAL		EH	
<b>BUILDING</b>	Location, Set-backs, Esmt(s)	8/1	EH	Exterior Wall Construction	10/5	EH	Roof Covering Roof Drainage		Smoke Detector	12/11	EH	
	Excavation	8/1	EH				Exterior Lath		Demolition (sewer cap)			
	Footings & Reinforcing	8/1	EH				<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)	GARAGE 12/11	Building or Structure	EH		
	Foundation Walls	8/1	EH	Columns & Supports			Fireplace Chimney	47' OK 12/11		EH		
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access	10/5	EH	Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)	10/5	EH			FINAL APPROVAL BLDG. DEPT.	12/11	EH	
			Roof ? FRAMING System ON CATHOL			Special Insp Reports Rec'd		Certificate of Occupancy Issued	12/11	EH		
<b>ADDITIONAL</b>	<b>INSPECTIONS, CORRECTIONS, ETC.</b>						<b>INSPECTIONS, CORRECTIONS, ETC.</b>					
	NO SOLID WD BLK BTWN FLOOR JOISTS				10/5	EH						
					11/25	EH						
	SOLID WD BLK. INSTALLED BETWEEN FLOOR JOIST				12/11	EH						

APPLICATION FOR PERMIT TO TAP SEWER

Owner MIKE & KAY LAWSON  
ADDRESS 320 MAUMEE LN. APT #1  
CONTRACTOR BECK'S CONSTRUCTION  
ADDRESS 11622 RD M NAR, OHTEL. 592-8307

NO. \_\_\_\_\_  
BLDG. PERMIT 01234  
PERMIT FEE \$ 60.00  
STREET BOND NONE REQ!  
DATE PAID \_\_\_\_\_  
For office use only

LOCATION OF CONNECTION

Street and No. 667 CRIPPLE CREEK CT, Sanitary  Storm \_\_\_\_\_  
Lot No. 4 Subdivision CRIPPLE CREEK Size of Tap 4"  
Size and Type of Sewer 4" PLASTIC P.V.C. ALL WORK MUST BE INSPECTED  
Street to be opened-Yes \_\_\_\_\_ No  Opening bond fee set by Engineer \$ N.A.  
Street opening agreement approval date \_\_\_\_\_

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Date \_\_\_\_\_ Signature \_\_\_\_\_  
Owner-Builder-Agent

DO NOT WRITE BELOW THIS LINE

INSPECTION RECORD

Date Inspected 8-22-86 Size and Type of Sewer 4" P.V.C.  
Location SEE PLOT PLAN Depth \_\_\_\_\_ Type of Test N.A.  
Inspected and Approved by: ELDON HUBER 8-25-86  
Inspector Date

Additional information \_\_\_\_\_

Send copy to: \_\_\_\_\_

SKETCH OF INSTALLATION - ON BACK





CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR HEATING PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of a heating system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_

Contractor's Name \_\_\_\_\_ Address \_\_\_\_\_ Tel. \_\_\_\_\_

BUILDING INFORMATION:

Single Family 1 Double Family \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction

Addition \_\_\_\_\_ Remodel \_\_\_\_\_ Replacement \_\_\_\_\_ No. of Stories 1

DESCRIPTION OF WORK

Heating System - Warm Air  Hot Water \_\_\_\_\_ Steam \_\_\_\_\_ Electric \_\_\_\_\_

Unit Heaters \_\_\_\_\_ Unit Gas Heaters \_\_\_\_\_ Other \_\_\_\_\_

Type - Gravity \_\_\_\_\_ Forced  Radiant \_\_\_\_\_

No. of Thermostatical Heating Zone 1

Hot Water - One Pipe \_\_\_\_\_ Two Pipe \_\_\_\_\_ Series Loop \_\_\_\_\_

Electric Heat - No. of Circuits \_\_\_\_\_ Other \_\_\_\_\_

Total Heat Loss of Area to be Heated 130,500 Btu.

Rated Capacity of Furnace/Boiler 90,000 Btu.

No. of Furnaces 1 No. of Hot Air Runs 8

No. of Hot Water Radiators \_\_\_\_\_ Type of Fuel Gas

Heating Units Located: Crawl Space \_\_\_\_\_ Floor Level \_\_\_\_\_ Suspended \_\_\_\_\_

Roof or Exposed to Outside Air  Attic \_\_\_\_\_ Other \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION OF FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: \_\_\_\_\_

DATE Aug 13 1986 APPLICANT'S SIGNATURE \_\_\_\_\_

Robert L. Best  
OWNER-CONTRACTOR-AGENT



CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR PLUMBING PERMIT  
 (Please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only).

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_

Plumbing Contractor Meyers Telephone No. 592 6771  
 Address Nap Ohio

General Contractor Beck Telephone No. \_\_\_\_\_  
 Address \_\_\_\_\_

Location of Project \_\_\_\_\_ Cost of Project \_\_\_\_\_

Work Information:

No. of dwelling units 1 New  Replacement \_\_\_\_\_ Addition \_\_\_\_\_

Brief description of work: New Ranch

Is water tap required yes Size 1 Type of Pipe plastic

Is sewer tap required yes Size 4 Type of Pipe plastic

Type of Water Distribution pipe 3/4 Copper

Type of Drainage, Waste and Vent Pipe 4" Plastic

Size of main building drain 4 Size of main vent pipe 4

Water closets X2 Bathtubs 2 1 1/2 Shower None  
 No. Trap Size No. Trap Size

Lavatories 2 1 1/4 Kitchen Sink 1 1 1/2 Disposal 1 1 1/2  
 No. Trap Size No. Trap Size No. Trap Size

Dishwasher 1 1 1/2 Clothes Washer 1 2 Other \_\_\_\_\_  
 No. Trap Size No. Trap Size No. Trap Size

All installations are subject to plumbing tests and/or inspections.

Date Aug 13 1986 Applicant's Signature Robert L Beck

PERMIT NO. \_\_\_\_\_  
 PERMIT FEE \$ \_\_\_\_\_





Lot 4  
667 CC

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_

Electrical Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project \_\_\_\_\_ Cost of Project \_\_\_\_\_

Work Information:

Residential \_\_\_\_\_ / \_\_\_\_\_ Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

No. Units \_\_\_\_\_  
New  Service Change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: New Ranch

Size of proposed service entrance 200 Number of new circuits 20

Type of proposed service entrance \_\_\_\_\_ Underground  Overhead \_\_\_\_\_

Require Temporary Electric yes (Yes or No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

PERMIT NO. \_\_\_\_\_  
PERMIT FEE \$ \_\_\_\_\_

\*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date July 13 1986 Applicant's Signature Robert S Beck



CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR BUILDING PERMIT  
 (Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 667 Cripple Creek CT. Cost of project 57,000.<sup>00</sup>  
 Owner's Name Mike + Kay Lawson Address Nap. O.  
 Contractor Beck's Const. Co Telephone No. 592-8307  
 Address 11622 Rd M Napoleon O

Lot Information: (Not required for siding job)

Lot No. 4 Subdivision Cripple Creek  
 Zoning District \_\_\_\_\_ Lot Size \_\_\_\_\_ ft. X \_\_\_\_\_ ft. Area \_\_\_\_\_ sq. ft.  
 Setbacks: Front \_\_\_\_\_ Right Side 95 site Left Side \_\_\_\_\_ Rear \_\_\_\_\_  
Plan

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
 New Construction  Addition \_\_\_\_\_ Remodel \_\_\_\_\_  
 Accessory Building \_\_\_\_\_ Siding wood  
 (Specific Type)

Brief Description of Work: ----- New Ranch

Size: Length 57'2" Width 44'4" No. of Stories 1  
 Area: 1st Floor 1432 sq. ft. Basement No sq. ft.  
 2nd Floor No sq. ft. Accessory Bldg. \_\_\_\_\_ sq. ft.  
 3rd Floor No sq. ft. Other \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date Aug 13 1986 Applicant's Signature Robert L Beck

PERMIT NO.

PERMIT FEE \$



RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON  
255 West Riverview Ave.  
Napoleon, Ohio 43545  
419/592-4010

ADDENDUM TO Permit No. 01234  
Owner MIKE & KAY LAWSON  
Contractor DECK'S CONSTRUCTION  
Location 667 CRIPPLE CR. CT.

Please note the items checked below and incorporate them into your plans as indicated:  PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL			
<input type="checkbox"/>	Provide approved smoke detector(s) as req'd.		
<input checked="" type="checkbox"/>	Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.		
<input checked="" type="checkbox"/>	Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		
<input type="checkbox"/>	Submit fully dimensioned plot plan.		
<input type="checkbox"/>	Provide min. of 1-3'0" x 6'8" exit door.		
<input type="checkbox"/>	Provide min. 22" x 30" attic access opening.		
<input type="checkbox"/>	Provide min. 18" x 24" crawl space access opening.		
<input type="checkbox"/>	Provide approved sheathing or flashing behind masonry veneer.		
<input type="checkbox"/>	Provide min. 15# underlayment on roof.		
<input type="checkbox"/>	Provide adequate fireplace hearth.		
<input checked="" type="checkbox"/>	Install factory built fireplaces/stoves according to manufacturers instructions.		
<input type="checkbox"/>	Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		
LIGHT AND VENTILATION			
<input type="checkbox"/>	Provide mechanical exhaust or window in bathroom		
<input type="checkbox"/>	Provide min. <u>1866</u> Sq. In. net free area attic ventilation.		
<input type="checkbox"/>	Provide min. <u>1356</u> Sq. In. net free area crawl space ventilation.		
FOUNDATION			
<input type="checkbox"/>	Min. depth of foundation below finished grade is 32".		
<input type="checkbox"/>	Min. size of footer _____" x _____"		
<input type="checkbox"/>	Provide anchor bolts, 1/2" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.		
<input type="checkbox"/>	Show size of basement columns.		
FRAMING			
<input type="checkbox"/>	Show size of wood girder in _____		
<input type="checkbox"/>	Provide design data for structural member in _____		
<input type="checkbox"/>	Floor joists undersized in _____		
<input type="checkbox"/>	Provide double joists under parallel bearing partitions.		
<input checked="" type="checkbox"/>	Provide 1" x 4" let in corner bracing, approved sheathing, or equal.		
<input type="checkbox"/>	Show size of headers for openings over 4' wide _____		
<input type="checkbox"/>	Show size of members supporting porch roof.		
<input type="checkbox"/>	Provide double top plate for all bearing partitions and exterior walls.		
<input type="checkbox"/>	Provide design data for prefab wood truss.		
<input checked="" type="checkbox"/>	Ceiling joists undersized in _____		
<input type="checkbox"/>	Roof rafters undersized in _____		
PLUMBING AND MECHANICAL			
<input type="checkbox"/>	Terminate all exhaust systems to outside air.		
<input checked="" type="checkbox"/>	Insulate ducts in unheated areas.		
<input checked="" type="checkbox"/>	Provide backflow prevention device on all hose bibs.		
<input type="checkbox"/>	Terminate pressure and temperature relief valve drain in an approved manner.		
<input type="checkbox"/>	Provide dishwasher drain with approved air gap device.		
METAL VENEERS			
<input type="checkbox"/>	Contact City Utilities Dept. to remove conductors and/or meter.		
<input type="checkbox"/>	Provide approved system of grounding and bonding.		
ELECTRICAL			
<input type="checkbox"/>	Show location of service entrance panel and service equipment panel.		
<input checked="" type="checkbox"/>	G. F. C. I. req'd. on temporary electric.		
<input type="checkbox"/>	Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.		
<input type="checkbox"/>	Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.		
<input type="checkbox"/>	Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.		
INSPECTIONS			
The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs prior to the time the inspection is to be made.			
<input checked="" type="checkbox"/>	Footers and Setbacks.	<input checked="" type="checkbox"/>	Building sewer.
<input checked="" type="checkbox"/>	Foundation.	<input checked="" type="checkbox"/>	HVAC rough-in.
<input checked="" type="checkbox"/>	Plumbing rough-in.	<input checked="" type="checkbox"/>	Final Building
<input checked="" type="checkbox"/>	Plumbing final.		other,
<input checked="" type="checkbox"/>	Electrical service.	<input checked="" type="checkbox"/>	<u>BUILDING FRAMING</u>
<input checked="" type="checkbox"/>	Electrical rough-in.		
<input checked="" type="checkbox"/>	Electrical final		

Additional Corrections. PROVIDE TIES AT THE TOP OF THE VAULTED CEILING BEARING WALLS AS REQ. TO PREVENT THE WALLS FROM SPREADING,

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01234 and made a part thereof. DATE APPROVED OR DISAPPROVED 8-20-06 Checked by ET Plan Examiner.  
DATE RECHECKED AND APPROVED \_\_\_\_\_ Checked by \_\_\_\_\_





FIELD CORRECTION NOTICE

LOCATION 667 CRIPPLE CREEK PERMIT NO. 01234

ISSUED TO BECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BECK'S CONSI.

Upon inspection, violations of the C.R.I.D. 01 Sec. F-602.4 were in evidence.

The following orders are hereby issued for their correction: FDD 2x - FULL HEIGHT  
SOLID WOOD BLOCKING AT THE END OF ALL  
WOOD JOISTS (FLOOR + CEILING) WHICH ARE NOT  
NAILED TO A HEADER, TRIM OR RIM JOIST.

OK  
12/11/86

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED ON OR BEFORE THE WORK IS CONCEALED OR FINAL INSPECTION IS REQUESTED.

DATE 10-7-86

BY 51 Eldon Hulme  
INSPECTOR



# PERMIT

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

01234

Permit No. 01234 Issued \_\_\_\_\_ date \_\_\_\_\_  
 Job Location 667 CRIPPLER CREEK CT. address \_\_\_\_\_  
 Lot 4 CRIPPLER CREEK SUB DIV sub-div or legal discript \_\_\_\_\_  
 Issued By FH building official \_\_\_\_\_  
 Owner MIKEY KAY LAWSON name \_\_\_\_\_ tel. \_\_\_\_\_  
 Address 320 MAUMEE W. APT 1 \_\_\_\_\_  
 Agent BECK'S CONSTRUCTION builder-eng.-etc. \_\_\_\_\_ tel. \_\_\_\_\_  
 Address 11622 RD M. NAPOLEON, OHIO \_\_\_\_\_  
 Description of Use RESIDENCE \_\_\_\_\_  
 Residential 1 no. dwelling units \_\_\_\_\_  
 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
 New X Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel \_\_\_\_\_  
 Mixed Occupancy \_\_\_\_\_  
 Change of Occupancy \_\_\_\_\_  
 Estimated Cost \$ 57,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	91.50	94.50
<input checked="" type="checkbox"/> ELECTRICAL	5.00	20.00	25.00
<input checked="" type="checkbox"/> PLUMBING	3.00	10.00	13.00
<input checked="" type="checkbox"/> MECHANICAL	6.00	.00	6.00
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			1.00
<input type="checkbox"/> SIGN			
<input checked="" type="checkbox"/> WATER TAP	300.00		300.00
<input checked="" type="checkbox"/> SEWER TAP	60.00		60.00
<input checked="" type="checkbox"/> TEMP. ELECT.			10.00
ADDITIONAL PLAN REVIEW	Struct. _____ hrs _____	Elect. _____ hrs _____	
TOTAL FEES.....			<u>508.50</u>
LESS MIN. FEES PAID _____ date _____			
BALANCE DUE.....			

### ZONING INFORMATION

district <u>A</u>	lot dimensions <u>100' x 102.53'</u>	area	front yd	side yds	rear yd
max hgt <u>35' MAX.</u>	no pkg spaces <u>2-MIN.</u>	no ldg spaces	max cover <u>35%</u>	petition or appeal req'd	date appr

### WORK INFORMATION:

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ Stories \_\_\_\_\_ Ground Floor Area \_\_\_\_\_  
 Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.  
 Electrical: 200 AMP SERVICE + 20 CIRCUITS brief description \_\_\_\_\_  
 Plumbing: 2-BATHS KITCHEN + LAUNDRY brief description \_\_\_\_\_ 1" WATER TAP  
 Mechanical: 90,000 B.T.U. GAS FURNACE brief description \_\_\_\_\_  
 Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
 Additional Information: NEW RESIDENCE  
 Date \_\_\_\_\_ Applicant Signature \_\_\_\_\_ owner-agent \_\_\_\_\_



TAPPING PERMIT

BUILD. PERMIT NO  
01232

Office Of  
Water Works  
Napoleon, Ohio

No. \_\_\_\_\_

Date 8-22-86

Received of BECK'S CONSTRUCTION

THREE HUNDRED Dollars 00/100

Charge for tapping permit to supply water services to Lot No. 4

Addition CRIPPLE CREEK SUB DIVI

Street No. 667 CRIPPLE CREEK

Tap Size 1 Inch Cost 300.00

Plumber MEYERS PL & HEATING

Street to be opened-Yes \_\_\_\_\_ No X

Opening bond fee set by Engineer \$ \_\_\_\_\_

Street opening agreement approval date \_\_\_\_\_

\_\_\_\_\_  
Clerk-Treasurer

Date completed \_\_\_\_\_

\_\_\_\_\_  
Water Distribution Department







# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

April 27, 1987

**Mayor**

Robert G. Heft

**Members of Council**

William Young, President  
Lawrence Haase  
James Hershberger  
Donald Stevens  
Donald Morford  
Steve White

**City Manager**

Richard A. Hayward

**Clerk-Treasurer**

Rupert W. Schweinhagen

**Law Director**

Keith P. Muehlfeld

Mike Lawson  
667 Cripple Creek Court  
Napoleon, Ohio 43545

Dear Mr. Lawson:

I note that you are constructing a wood deck, On the Northeast corner of your house. This work was not covered by the house Building Permit No. 01234.

You will need to submit a site-floor plan and section showing the construction and obtain a permit.

Sincerely,

*Eldon Huber*

Eldon Huber  
Building Inspector

EH:skw





# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

May 6, 1987

**Mayor**

Robert G. Heft

**Members of Council**

William Young, President

Lawrence Haase

James Hershberger

Donald Stevens

Donald Morford

Steve White

**City Manager**

Richard A. Hayward

**Clerk-Treasurer**

Rupert W. Schweinhagen

**Law Director**

Keith P. Muehfeld

Mr. & Mrs. Lawson  
667 Cripple Creek Court  
Napoleon, Ohio 43545

Re: Wood deck  
Application dated 5-2-87

Dear Mr. & Mrs. Lawson:

The following plans will be required to obtain a building permit.

1. A site plan } these may be combined
2. A floor plan } on the same drawing.
3. A section

I will hold your application until you get the required drawings to me, to make the plot plan easy you might try to obtain copies of your house site plan from your builder.

Sincerely,

Eldon Huber  
Building Inspector

EH:skw

