

FIELD CORRECTION NOTICE

LOCATION 825 CRIPPLE CREEK PERMIT NO. 01509

ISSUED TO DECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO DECK'S 101ST 11-622 CO RD M

Upon inspection, violations of the \_\_\_\_\_

Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction:

PROVIDE 101ST HANGERS  
W/IN THE FIRST FLOOR JOISTS ARE SUPPORTED  
BY THE FIRE PLACE HEADER

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 10/24/08 REPAIRMENT CEILING

DATE 5-24-08

BY FLOON HULLER  
INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY



FIELD CORRECTION NOTICE

LOCATION 825 CRIPPLE CREEK PERMIT NO. 01507

ISSUED TO HECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO HECK'S 11-622 CO ROAD

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: PROVIDE JOINT HANDLES  
UNPLUG FLOOR JOISTS ARE SUPPORTED  
BY THE FIRE PLACE HEATER  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 10-21-14 DEPARTMENT  
DATE 5-24-88

BY RECOGNITION INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY



FIELD CORRECTION NOTICE

LOCATION 825 CRIPPLE CREEK

PERMIT NO. 01509

ISSUED TO MEYER'S PL. & HEATING

PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO MEYER'S PL. & HEATING

Upon inspection, violations of the

Sec.

were in evidence.

The following orders are hereby issued for their correction:


THE ROUGH IN INSPECTION I MADE ON 4-21-88 COVERED ONLY THE KITCHEN, LAUNDRY & 1/2 BATH. YOUR DRAINAGE PLUG EFFECTIVELY CUT OFF AIR TO THE 2 BATHROOMS ON BEDROOM END. IF YOUR PLUG HAD NOT CUT OFF THE BEDROOM END YOU WOULD HAVE HAD TO PLUG THE DRAINAGE FLOOR DRAIN SINCE THEIR IS NO TIE IN THRU THE TWO VENTS.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED NO CORRECTION REQUIRED BUT THE ENTIRE SYSTEM ON OR BEFORE MUST BE CHECKED FOR THE FUTURE.

DATE 4-21-88

BY E LOON HUDER INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY



FIELD CORRECTION NOTICE

LOCATION 825 CRIPPLE CREEK PERMIT NO. 01509  
ISSUED TO MEYER'S PL & HEATING  
NOTICE DELIVERED TO MEYER'S PL & HEATING

Upon inspection, violations of the \_\_\_\_\_ Sec. \_\_\_\_\_ were in evidence.  
The following orders are hereby issued for their correction:

THE ROUGH IN INSPECTOR'S MAPS ON 4-21-89 COVERED ONLY THE KITCHEN, LAUNDRY & 1/2 BATH. YOUR DRAINAGE PLUG ENTIRELY CUT OFF AIR TO THE 2 BATHROOMS IN BEDROOM END. IF YOUR PLOG HADN'T CUT OFF THE BEDROOM END YOU WOULD HAVE HAD TO PLUG THE DIRT NEXT FLOOR DOWN SINCE THERE IS NO TIE IN THERE THE TWO WOULD

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED ON OR BEFORE 4-21-89.  
NO CORRECTIONS REQUIRED UNTIL THE ENTIRE SYSTEM BE CALLED FOR THE FUTURE.

DATE 4-21-89 BY J. COOCH INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY





FIELD CORRECTION NOTICE

LOCATION 825 CRIPPLE CREEK PERMIT NO. 01509

ISSUED TO BECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO BECK'S CONSTRUCTION

Upon inspection, violations of the

Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction: PROVIDE ADDITIONAL

SUPPORT FOR THE BEAM IN THE DARKHART

SUPPORTING THE FIRST FLOOR AT THE WOOD

STUD WAIC CORNER FOR 2X4S TO MAKE THE  
CORNER SOLID.

EXIST STUD →

ROD STUDS

FRAME KNEE WALL BEHIND THE CEILING JOISTS AND  
THE RAFTERS AS DIRECTED IN THE FIELD BY THE INSPECTOR.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE  
AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE DRYWALL IS INSTALLED.

DATE 4-21-88

BY ELDON HUDER  
INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY



FIELD CORRECTION NOTICE

LOCATION 825 CRIFFLE CREEK PERMIT NO. 01509  
ISSUED TO FICK'S CONSTRUCTION  
NOTICE DELIVERED TO FICK'S CONSTRUCTION

Upon inspection, violations of the \_\_\_\_\_

The following orders are hereby issued for their correction: \_\_\_\_\_ were in evidence.

SUPPORT FOR THE BEAM IN THE DARK WOOD  
SUPPORTING THE FIRST FLOOR BY THE WOOD  
STUD WALL CORNER FOR 2x4S TO MAKE THE  
CORNER SOLID.



FRAME FULL WALL BEHIND THE CEILING JOIST AND  
THE RAFTERS BY DIRECTOR TO THE FIELD BY THE INSPECTOR.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED ON OR BEFORE DECEMBER 15 1988.

DATE 4-21-88 BY E. COOK INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY



CITY OF NAPOLEON  
255 W. Riverview  
NAPOLEON, OHIO 43545

message

reply

to

BECK'S CONSTRUCTION

11-622 CO. RD M

NAPOLEON, OHIO 43545

▶ FOLD

subject REF: PERMIT NO 01509 - 825 CRIPPLE CREEK CT,

I NOTE THAT THE BASEMENT IS BEING DEVIDED OFF  
AND FINISHED, THIS WORK WAS NOT SHOWN ON THE  
APPROVED PLANS SO YOU WILL NEED TO SUBMIT A  
REVID BASEMENT PLAN FOR APPROVAL, ENCLOSED IS  
AN APPLICATION FOR THE ADDITIONAL WORK,  
ALSO BE AWARE THAT THE STYROFOAM INSULATION  
MUST BE COVERED WITH 1/2" DRYWALL,

date 4-18-88 signed ELDON HUTER date \_\_\_\_\_ signed \_\_\_\_\_

SENDER: Mail white and pink copies with carbon intact.

RECEIVER: Reply, retain white copy, return pink copy.

CITY OF WARREN

525 W. Riverview

WARREN, OHIO 43084

to [REDACTED] ✓

11-25-54

[REDACTED]

Warren City Council  
The undersigned hereby certifies that the above named person is a resident of Warren, Ohio, and is qualified to vote in the election of Warren City Council members to be held on November 2, 1954.

Warren City Council Clerk [REDACTED]

Warren City Council Clerk [REDACTED]

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01509 Issued 2-16-88 date

Job Location 825 Cripple Creek address

Lot 10 Cripple Creek Subdivision sub-div or legal discript

Issued By Eldon Huber building official

Owner Ed Tallman name

Address 945 Melody Lane tel.

Agent Beck's Construction 592-8307 tel.

Address 11-622 Co. Rd. M

Description of Use Residence

Residential 1 no. dwelling units

Commercial Industrial

New  Add'n.  Alter  Remodel

Mixed Occupancy

Change of Occupancy

Estimated Cost \$ 81,500.00 ~~80,000.00~~

	FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING		9.00	188.00	197.00
<input checked="" type="checkbox"/> ELECTRICAL	15.00		66.00	81.00
<input checked="" type="checkbox"/> PLUMBING	9.00		36.00	45.00
<input checked="" type="checkbox"/> MECHANICAL	18.00		10.00	28.00
<input type="checkbox"/> DEMOLITION				
<input checked="" type="checkbox"/> ZONING	5.00			5.00
<input type="checkbox"/> SIGN				
<input checked="" type="checkbox"/> WATER TAP	300.00			300.00
<input checked="" type="checkbox"/> SEWER TAP	60.00			60.00
<input checked="" type="checkbox"/> TEMP. ELECT.	10.00			10.00
ADDITIONAL PLAN REVIEW		Struct. 1-copy	hrs	.25
		Elect.	hrs	
TOTAL FEES				730.25
LESS MIN. FEES PAID				726.25
BALANCE DUE				

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
A	131.12' x 92.27'	12,098±	36'	12.3'L-12.3'R	58.45'
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35'	2-min.		35%		

WORK INFORMATION: 44'8" x 26'4"

22'8" x 23'

Size: Length 67'8" Width 32'8" Stories 1

Height 13' Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: 200 amp underground service & 22 circuits.

Plumbing: 2 1/2 bath, kitchen & laundry

Mechanical: 75,000 B.T.U. warm air furnace & 14 hot air runs.

Sign: N.A. type Dimensions Sign Area \_\_\_\_\_

Additional Information: \_\_\_\_\_

Date 3-1-88

Applicant Signature Gregory J Beck

owner-agent

MAR 0 1 1988

# INSPECTION RECORD

UNDERGROUND			ROUGH-IN			FINAL			
Type	Date	By	Type	Date	By	Type	Date	By	
PLUMBING	Building Drains	4/22	Drainage, Waste & Vent Piping	4/21	FH	Drainage, Waste & Vent Piping		FH	
	Water Piping	4/21	<i>RITZ COUNTRY ONLY COVER DAMAGED</i> Water Piping	4/21	FH	Backflow Prevention		FH	
	Building Sewer	5/1	Water Piping		FH	Water Heater		FH	
Sewer Connection						FINAL APPROVAL		FH	
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s)		Grease Exhaust System 6/10 FH	
	Ducts/Plenums		Duct Furnace(s)		FH	Fire Dampers		Air Cond. Unit(s)	
			Ducts/Plenums		FH	<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)		Refrigeration Equipment	
			Duct Insulation		FH	Pool Heater		Furnace(s)	
			Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.		FINAL APPROVAL 6/10 FH	
ELECTRICAL	Conduits & Cable		Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer		Temp Service Temp Lighting	
	Grounding & Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors		Fixtures Lampholders	
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder		Signs	
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable		Electric Mtr. Clearance	
Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)		FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)		Exterior Wall Construction		FH	Roof Covering Roof Drainage		Smoke Detector FH	
	Excavation					Exterior Lath		Demolition (sewer cap)	
	Footings & Reinforcing					<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard			
	Floor Slab		Interior Wall Construction		FH	Fire Wall(s)		Building or Structure FH	
	Foundation Walls		Columns & Supports			Fireplace Chimney			
	Sub-soil Drain		Crawl Space <input checked="" type="checkbox"/> Vent <input checked="" type="checkbox"/> Access		FH	Attic <input checked="" type="checkbox"/> Vent <input checked="" type="checkbox"/> Access			
	Piles		Floor System(s)		FH	Special Insp Reports Rec'd		FINAL APPROVAL 6/10 FH	
			Roof System		FH			Certificate of Occupancy Issued	
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.			INSPECTIONS, CORRECTIONS, ETC.			INSPECTIONS, CORRECTIONS, ETC.		
	CHECK PERMS FOR			3/24			FH		
	① UNDER FLOOR PIPE-DRAW			3/22			FH		



APPLICATION FOR PERMIT TO TAP SEWER

Owner EO TALLMAN

ADDRESS 945 MCELROY CAVE

CONTRACTOR BECK'S CONSTRUCTION

ADDRESS 11622 RD M WAP OH TEL. 592-8307

NO. 570038-88

BLDG. PERMIT 01509

PERMIT FEE \$ 60.00

STREET BOND NOT REP.

DATE PAID 2-16-88

For office use only

LOCATION OF CONNECTION

Street and No. 825 CRIPPLE CREEK Sanitary  Storm

Lot No. 10 Subdivision CRIPPLE CREEK SUB DIV. Size of Tap 4"

Size and Type of Sewer 4" S.D.R. 35 ALL WORK MUST BE INSPECTED

Street to be opened-Yes  No  Opening bond fee set by Engineer \$

Street opening agreement approval date 107 REP.

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Date 3-1-88

Signature

Gregory J. Beck  
Owner-Builder-Agent

DO NOT WRITE BELOW THIS LINE

INSPECTION RECORD

Date Inspected 3-8-88 Size and Type of Sewer 4" S.D.R. 35

Location SEE SITE PLAN Depth \_\_\_\_\_ Type of Test POUR

Inspected and Approved by: Malcolm Helberg Date 3-8-88

Inspector

Additional information

Send copy to:

SKETCH OF INSTALLATION - ON BACK



No. ...4.7.4.....

**CERTIFICATE OF OCCUPANCY**  
**THE CITY OF NAPOLEON**

ENGINEERING DEPARTMENT  
DIVISION OF INSPECTION

**This is to certify that the Building or Land as herein described complies with all the building and health laws and ordinances and with the provisions of the Zoning Ordinance.**

Location of Occupancy ...825 Cripple Creek..... Occupancy 1 - family residence  
Owner of Property ..Ed Tallman..... Address ...825 Cripple Creek  
Issued to .....Beck's Construction..... Address ...11-622 Co. Rd. M  
Zoning ..... "A" ..... Bldg. Permit No. ....01509  
Substantial qualifications of occupancy ...None.....

**This certificate is issued by the City Building Inspector, as provided by law, and is to certify that construction is completed substantially in conformity with the approved plans and permission is hereby granted to occupy such building in compliance with such legal use and occupancy as authorized under the provisions of the ordinances of the City of Napoleon.**

Issued this .....10..... day of ...January..... 19.89

This is a valuable record for owner or lessee  
and should be so preserved.

Signed *Eldon Huber*  
Eldon City Building Inspector  
Huber



PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT  
255 West RiverView Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01509 Issued 2-15-88  
date

Job Location 825 CRIPPLE CREEK  
address  
sub-div or legal district

Lot 10 CRIPPLE CREEK SUB DIV 1

Issued By FA building official

Owner ED TALLAMAN name tel.

Address 945 MELODY LAVE

Agent BECK'S CONSTRUCTION 592-8107 builder-eng.-etc. tel.

Address 11622 RP H. WARD, OH

Description of Use RESIDENCE

Residential 1 no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New X Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 80,000

	FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING		9.00	188.00	197.00
<input type="checkbox"/> ELECTRICAL		15.00	66.00	81.00
<input checked="" type="checkbox"/> PLUMBING		9.00	36.00	45.00
<input type="checkbox"/> MECHANICAL		18.00	10.00	28.00
<input checked="" type="checkbox"/> DEMOLITION				
<input checked="" type="checkbox"/> ZONING		5.00	.00	5.00
<input type="checkbox"/> SIGN				
<input checked="" type="checkbox"/> WATER TAP		300.00		300.00
<input checked="" type="checkbox"/> SEWER TAP		60.00		60.00
<input checked="" type="checkbox"/> TEMP. ELECT.		10.00		10.00
ADDITIONAL PLAN REVIEW				
Struct.	hrs			
Elect.	hrs			
TOTAL FEES				726.00
LESS MIN. FEES PAID				
BALANCE DUE				

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
A	134.12' x 92.27'	12,098 ±	36'	123' L - 123' R	58.95'
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35'	2 MIN	35%			

WORK INFORMATION: 47'-8" x 26'-4" BASEMENT 877 S.F.  
22'-8" x 23'-0" GARAGE 522 S.F.  
Size: Length 67'-8" Width 32'-8" Stories 1 Ground Floor Area 1657 S.F.

Height 13' Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: 200 AMP UNDERGROUND SERVICE + 22 CIRCUITS

Plumbing: 2 1/2 BATH KITCHEN + LAUNDRY

Mechanical: 75,000 BTU WARM AIR FURNACE + 14 HOT AIR RADI

Sign: W.A. Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: \_\_\_\_\_

Date \_\_\_\_\_ Applicant Signature \_\_\_\_\_ Owner-agent \_\_\_\_\_



CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR BUILDING PERMIT  
 (Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project Cripple Creek Sub Cost of project \$ 80,000  
 Owner's Name Ed Tallman Address 945 Melday Lane

Contractor Beck's Const Co Telephone No. 592-8307  
 Address 11622 Rd M Napoleon Ohio

Lot Information: (Not required for siding job)

Lot No. 10 Subdivision Cripple Creek Sub  
 Zoning District \_\_\_\_\_ Lot Size \_\_\_\_\_ ft. X \_\_\_\_\_ ft. Area \_\_\_\_\_ sq. ft.

Setbacks: Front \_\_\_\_\_ Right Side on plot left side Rear \_\_\_\_\_  
 Work Information: \_\_\_\_\_

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
 New Construction  Addition \_\_\_\_\_ Remodel \_\_\_\_\_

Accessory Building \_\_\_\_\_ Siding vinyl  
 Brief Description of Work: ----- New Ranch (Specific Type)

Size: Length 68 Width 36 No. of Stories 1  
 Area: 1st Floor 1647 sq. ft. Basement 832 sq. ft.  
 2nd Floor 0 sq. ft. Accessory Bldg. \_\_\_\_\_ sq. ft.  
 3rd Floor 0 sq. ft. Other \_\_\_\_\_ sq. ft.

Additional Information: Ranch home

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date Jan 28 88 Applicant's Signature Robert J Beck

PERMIT NO. \_\_\_\_\_

PERMIT FEE \$ \_\_\_\_\_





BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_  
Electrical Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
Address \_\_\_\_\_  
General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
Address \_\_\_\_\_

Location of Project \_\_\_\_\_ Cost of Project \_\_\_\_\_

Work Information: \_\_\_\_\_  
Residential  No. Units \_\_\_\_\_ Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
New  Service Change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: New Ranch

Size of proposed service entrance 200 Amp Number of new circuits 22

Type of proposed service entrance \_\_\_\_\_ Underground  Overhead \_\_\_\_\_

Require Temporary Electric YPS (Yes or No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

\*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service: and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Applicator for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

date Jan 28/88 Applicant's Signature Robert T. Bee

PERMIT NO. \_\_\_\_\_

PERMIT FEE \$ \_\_\_\_\_



CITY OF NAPOLEON  
 BUILDING INSPECTION DEPARTMENT  
 APPLICATION FOR PLUMBING PERMIT  
 (Please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only).

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_  
 Plumbing Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
 Address \_\_\_\_\_  
 General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
 Address \_\_\_\_\_  
 Location of Project \_\_\_\_\_ Cost of Project \_\_\_\_\_

Work Information:  
 No. of dwelling units    New  Replacement    Addition     
 Brief description of work: New Ranch

Is water tap required yes Size 1 Type of Pipe Plastic  
 Is sewer tap required yes Size 4 Type of Pipe Plastic  
 Type of Water Distribution pipe 3/4 Plastic  
 Type of Drainage, Waste and Vent Pipe 4" Plastic  
 Size of main building drain 4" Size of main vent pipe 3"  
 Water closets 3 Bathtubs 1 2 1/2 shower 1 No. Trap Size No. Trap Size  
 Lavatories 3 1/4 Kitchen sink 1 1 1/2 Disposal 1 1/2 No. Trap Size No. Trap Size  
 Dishwasher 1 1 1/2 Clothes Washer 1 2 Other    No. Trap Size No. Trap Size

PERMIT NO. \_\_\_\_\_  
 PERMIT FEE \$ \_\_\_\_\_

All installations are subject to plumbing tests and/or inspections.  
 Date Jan 28 1988 Applicant's Signature Robert Red



CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR HEATING PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of a heating system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name \_\_\_\_\_ Address \_\_\_\_\_

Contractor's Name \_\_\_\_\_ Address \_\_\_\_\_ Tel. \_\_\_\_\_

BUILDING INFORMATION:

Single Family \_\_\_\_\_ Double Family \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction \_\_\_\_\_

Addition \_\_\_\_\_ Remodel \_\_\_\_\_ Replacement \_\_\_\_\_ No. of Stories \_\_\_\_\_

DESCRIPTION OF WORK

Heating System - Warm Air  Hot Water \_\_\_\_\_ Steam \_\_\_\_\_ Electric \_\_\_\_\_

Unit Heaters \_\_\_\_\_ Unit Gas Heaters \_\_\_\_\_ Other \_\_\_\_\_

Type - Gravity \_\_\_\_\_ Forced  Radiant \_\_\_\_\_

No. of Thermostatical Heating Zone \_\_\_\_\_

Hot Water - One Pipe \_\_\_\_\_ Two Pipe \_\_\_\_\_ Series Loop \_\_\_\_\_

Electric Heat - No. of Circuits \_\_\_\_\_ Other \_\_\_\_\_

Total Heat Loss of Area to be Heated \_\_\_\_\_ Btu. 70,000

Rated Capacity of Furnace/Boiler \_\_\_\_\_ Btu. 75,000

No. of Furnaces \_\_\_\_\_ No. of Hot Air Runs 14 EST

No. of Hot Water Radiators \_\_\_\_\_ Type of Fuel Gas

Heating Units Located: Crawl Space \_\_\_\_\_ Floor Level  Suspended \_\_\_\_\_

Roof or Exposed to Outside Air  Attic \_\_\_\_\_ Other \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION OF FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: \_\_\_\_\_

DATE Jan 28 88 APPLICANT'S SIGNATURE [Signature]

OWNER-CONTRACTOR-AGENT



Ed Tallman

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR BUILDING PERMIT  
(Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 825 CC Cost of project \$1500  
Owner's Name Ed Tallman Address 825 CC  
Contractor Ed Tallman Telephone No. \_\_\_\_\_  
Address 825 CC

Lot Information: (Not required for siding job)

Lot No. \_\_\_\_\_ Subdivision \_\_\_\_\_  
Zoning District \_\_\_\_\_ Lot Size \_\_\_\_\_ ft. X \_\_\_\_\_ ft. Area \_\_\_\_\_ sq. ft.  
Setbacks: Front \_\_\_\_\_ Right Side \_\_\_\_\_ Left Side \_\_\_\_\_ Rear \_\_\_\_\_

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
New Construction  Addition \_\_\_\_\_ Remodel

Accessory Building \_\_\_\_\_ Siding \_\_\_\_\_

Brief Description of Work: ----- Add Wall & Ceiling  
To Basement

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ No. of Stories \_\_\_\_\_  
Area: 1st Floor \_\_\_\_\_ sq. ft. Basement \_\_\_\_\_ sq. ft.  
2nd Floor \_\_\_\_\_ sq. ft. Accessory Bldg. \_\_\_\_\_ sq. ft.  
3rd Floor \_\_\_\_\_ sq. ft. Other \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date 6/28/88

Applicant's Signature Ed Tallman

PERMIT NO. 01509

PERMIT FEE \$ \_\_\_\_\_





CITY OF NAPOLEON  
255 West RiverView AVE.  
Napoleon, Ohio 43545  
419/592-4010

ADDENDUM TO Permit No. 01509 - (1)

Owner E.O. FALLMAN  
Contractor BECK'S CONSTRUCTION  
Location 225 CRIPPLE CREEK

Please note the items checked below and incorporate them into your plans as indicated:  PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL			
<input type="checkbox"/>	Provide approved smoke detector(s) as req'd.		Show size of members supporting porch roof.
<input checked="" type="checkbox"/>	Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.		Provide double top plate for all bearing partitions and exterior walls.
<input checked="" type="checkbox"/>	Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		Provide design data for prefab wood truss.
	Submit fully dimensioned plot plan.		Ceiling joists undersized in
	Provide min. of 1-3'0" x 6'8" exit door.		Roof rafters undersized in
	Provide min. 22" x 30" attic access opening.		PLUMBING AND MECHANICAL
	Provide min. 18" x 24" crawl space access opening.		Terminate all exhaust systems to outside air
<input checked="" type="checkbox"/>	Provide approved sheathing or flashing behind masonry veneer.		Insulate ducts in unheated areas.
<input checked="" type="checkbox"/>	Provide min. 15# underlayment on roof.		Provide backflow prevention device on all hose bibs.
<input checked="" type="checkbox"/>	Provide adequate fireplace hearth.		Terminate pressure and temperature relief valve drain in an approved manner.
<input checked="" type="checkbox"/>	Install factory built fireplaces/stoves according to manufacturers instructions.		Provide dishwasher drain with approved air gap device.
<input checked="" type="checkbox"/>	Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		METAL VENEERS
	LIGHT AND VENTILATION		Contact City Utilities Dept. to remove conductors and/or meter.
	Provide mechanical, exhaust or window in bathroom		Provide approved system of grounding and bonding.
<input checked="" type="checkbox"/>	Provide min. <u>1096</u> Sq. In. net free area attic ventilation.		ELECTRICAL
<input checked="" type="checkbox"/>	Provide min. <u>75</u> Sq. In. net free area crawl space ventilation. <u>1-VENTILATE EACH CORNER</u>		Show location of service entrance panel and service equipment panel.
	FOUNDATION		G. F. C. I. req'd. on temporary electric.
	Min. depth of foundation below finished grade is 32".		Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I. <u>KITCHEN</u>
	Min. size of footer " x "		Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.
	Provide anchor bolts, 1/2" x 6" o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.		Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.
	Show size of basement columns.		INSPECTIONS
	Show size of wood girder in		The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs. prior to the time the inspection is to be made.
	Provide design data for structural member in		Footers and Setbacks. <input checked="" type="checkbox"/> Building sewer.
	Floor joists undersized in		Foundatipn. <input checked="" type="checkbox"/> HVAC rough-in.
<input checked="" type="checkbox"/>	Provide double joists under parallel bearing partitions.		Plumbing rough-in. <input checked="" type="checkbox"/> Final Building
<input checked="" type="checkbox"/>	Provide 1" x 4" let in corner bracing, approved sheathing, or equal.		Plumbing final. <input checked="" type="checkbox"/> other, <u>BUILDING FRAMING</u>
	Show size of headers for openings over 4' wide		Electrical service. <input checked="" type="checkbox"/>
			Electrical rough-in. <input checked="" type="checkbox"/>
			Electrical final <input checked="" type="checkbox"/>

Additional Corrections. PROVIDE A 1-HR RATED ATIC ACCESS STAIR  
PROVIDE 2- ADDITIONAL CRAWL SPACE VENTS @ CORNER

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01509 and made a part thereof. DATE APPROVED OR DISAPPROVED 2-15-88 Checked by ELOON HUBER Plan Examiner.

DATE RECHECKED AND APPROVED \_\_\_\_\_ Checked by \_\_\_\_\_



ADDENDUM NO. 1


TO PERMIT NO. 01509

PAGE 2 OF 2


ITEM NO. 1:

Stairway  
Maximum rise 8 1/4"  
Minimum tread 9"  
Minimum ceiling height  
From nosing 6'8"  
Railing height 30" to 34"  
From nosing





PLAN VIEW  
1/2" = 1'-0"



SECTION A-A  
1/2" = 1'-0"



ASSUMED LOADS: 30#/FT<sup>2</sup> ROOF, LIVE & DEAD  
30#/" CEILING, " "  
60#/" TOTAL w/ 11'-0"  
TRIBUTARY LOAD

LUMBER DESIGN VALUES:  
FIBER STRESS, 1400 Psi, MIN.  
MODULUS "E", 1,400,000 Psi, MIN.

*Richard F. Bertz*  
RICHARD F. BERTZ, P.E.


THIS DRAWING IS THE PROPERTY OF  
NAPOLEON ENG. & SURV., INC. AND SHALL NOT  
BE USED WITHOUT THEIR PERMISSION.













REVISED  
Amounts  
+9.00

**PERMIT**

**CITY OF NAPOLEON - BUILDING DEPARTMENT**

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01509 Issued 2-16-88 date

Job Location 825 Cripple Creek address

Lot 10 Cripple Creek Subdivision  
sub-div or legal discript

Issued By Eldon Huber  
building official

Owner Ed Tallman  
name

Address 945 Melody Lane tel.

Agent Beck's Construction 592-8307  
builder-eng.-etc. tel.

Address 11-622 Co. Rd. M

Description of Use Residence

Residential 1 no. dwelling units

Commercial Industrial

New X Add'n. Alter Remodel

Mixed Occupancy

Change of Occupancy 8/1,500.00

Estimated Cost \$ ~~80,000.00~~

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	9.00	188.00	207.00 197.00
<input checked="" type="checkbox"/> ELECTRICAL	15.00	66.00	81.00
<input checked="" type="checkbox"/> PLUMBING	9.00	36.00	45.00
<input checked="" type="checkbox"/> MECHANICAL	18.00	10.00	28.00
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING	5.00		5.00
<input type="checkbox"/> SIGN			
<input checked="" type="checkbox"/> WATER TAP	300.00		300.00
<input checked="" type="checkbox"/> SEWER TAP	60.00		60.00
<input checked="" type="checkbox"/> TEMP. ELECT.	10.00		10.00
ADDITIONAL PLAN REVIEW	Struct. 1-copy	hrs	.25
TOTAL FEES		Elect. hrs	730.25 <del>726.25</del>
LESS MIN. FEES PAID			
BALANCE DUE			

**ZONING INFORMATION**

district	lot dimensions	area	front yd	side yds	rear yd
A	131.12' x 92.27'	12,098±	36'	12.3' L-12.3'R	58.45'
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35'	2-min.		35%		

**WORK INFORMATION:** 44'8" x 26'4"  
22'8" x 23'

Size: Length 67'8" Width 32'8" Stories 1

Height 13' Building Volume (for demo permit) \_\_\_\_\_ cu. ft.

Electrical: 200 amp underground service & 22 circuits.

Plumbing: 2 1/2 bath, kitchen & laundry  
brief description

Mechanical: 75,000 B.T.U. warm air furnace & 14 hot air furnaces.  
brief description

Sign: N.A. Dimensions

Additional Information:

PAID  
AUG 0 3 1988

City of Napoleon  
AUG 0 3 1988

CITY OF NAPOLEON PAID

Date 3-1-88

Applicant Signature Dukey J Beck  
owner-agent

MAR 0 1 1988

CITY OF NAPOLEON



# DEAM IN LIVING AREA OVER BASEMENT

AREA SUPPORTED  $12' \times 10'$

SPAN  $6' - 9 \frac{1}{2}''$

LOAD	FLOOR C.C.	40
	0 C	10
	C C	20
	0 C	10
	<hr/>	
	80	# R.I.F.

$$12,8333' \times 80 \text{ \# R.I.F.} = 1026 \text{ \# P.L.F.}$$

$$M = \frac{wL^2}{8} = \frac{1026 \times 6.8' \times 6.8' \times 12}{8} = 71,163$$

$$S = \frac{M}{f} = \frac{71,163}{1080} \text{ \#2 S.P.F.} = 65,17$$

$$S = \frac{M}{f} = \frac{71,163}{1296} \text{ \#1 S.P.F.} = 54,91$$

$$S = \frac{M d^2}{S} = 5-2 \times 85 = 65,17 \quad \text{BEAM 1501C}$$



# BEAM IN BEDROOM AREA CRAWL SPACE

AREA SUPPORTED 11'-2"  
SPAN 6'-6"

LOADS  
FLOOR C.L. 40  
O.C. 10  
CEILING C.L. 20  
O.C. 10  

---

80 # P.S.F.

$$11.25' \times 80 \# \text{ P.S.F.} = 900 \# \text{ P.L.F.}$$

$$M = \frac{wL}{8} = \frac{900 \times 6.5' \times 6.5' \times 12}{8} = 57,037.5 \#$$

$$S = \frac{M}{f} = \frac{57,037.5 \#}{1080} = 52.8$$

$$S = \frac{bd^2}{6} = \frac{7.5 \times 7.25^2}{6} = 65.7$$

$$4-2 \times 8 \text{ S} = \frac{6 \times 7.25^2}{6} = 52.5$$

LOAD IS 30# BEDROOM LOAD BEAM OK

