

SEWER TAPPING PERMIT

Issued by

The City of Napoleon Engineering Dept.

255 West Riverview Ave. Napoleon, Ohio 43545 Pn. 592-4010

Entry No. _____

Permit No. _____ Issued 11-21-91 Build. Permit No. _____

Permit Fee \$ — 0 —

Job Location 815 Daggett

Street Bond \$ _____

Lot 21 W. Daggett

Date Paid _____

Issued By BND sub div. or legal disc.

Owner Margaret Peterson Pn. _____

Address 815 Daggett

Agent _____ Pn. _____

Address _____

for office use only

WORK INFORMATION

Sanitary Sewer Tap yes no Size of Tap 6" Size and Type of Sewer 12" Street to be Opened _____ yes no

Storm Sewer Tap _____ yes no Size of Tap _____ Size and Type of Sewer _____ Street to be Opened _____ yes no

Street opening Agreement Approval Date _____ Opening Bond Fee (Set by Engineer) _____

READ AND SIGN BELOW; The undersigned hereby agrees complete the work described above and to make use of said sewers only as allowed by and in strict accordance with all applicable provisions of The Napoleon Engineering Dept. Rules and Regulations, The Napoleon Standard Specification for Water Main, Sanitary Sewer and Storm Sewer Construction and other Pertinent Sections of the Napoleon Code of Ordinances.

Date _____ Signature of Applicant _____
Permit not valid without signature


INSPECTION RECORD _____ to be completed by the Field Inspector

Date Inspection is made _____ Size and Type of Sewer _____


Location _____ Depth _____ Type of Test _____ Additional Information _____

Date _____ Inspected By _____
signature of inspector

Sketch Of Installation on Back or Attached



Date — 6-10-92
Location — 815 Daggett
Owner — Margaret Peterson
Address — 815 Daggett
Contractor — Jerry Glanz
Address —
Work Discrip: New Sewer tap



c/L - Daggett

178'



