

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 58-78 Issued 4/24/78
date

Job Location 908 Daggett Ave.
address

Lot # 9 Richters 4th Add'n.
sub-div or legal discript

Issued By R.D. Sonnenberg
building official

Owner Ken Holers
name tel.

Address 908 Daggett Ave.

Agent Bergstedt Builders 592-3451
builder-eng.-etc. tel.

Address 1050 Dodd St. Napoleon, Ohio

Description of Use Addition to home

Residential XX(1)
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. XX Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 11,000.00

FEE	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$25.50	-0-	\$25.50
<input checked="" type="checkbox"/> ELECTRICAL	1.00	\$8.00	9.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING	---	---	---
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$34.50
LESS MIN. FEES PAID _____			-0-
			date
BALANCE DUE.....			\$34.50

ZONING INFORMATION

district "B"	lot dimensions 70' x 157'	area 10,990	front yd n/a	side yds 9' N 10' S OK	rear yd 80' OK
max hgt 25' OK	no pkg spaces no additional	no ldg spaces n/a	max cover 45% OK	petition or appeal req'd n/a	date appr ---

WORK INFORMATION:

Size: Length 25' Width 24' Stories 1 Ground Floor Area 600sq.ft.

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: New 200 amp service, wiring, & install heat pump
brief description

Plumbing: n/a
brief description

Mechanical: n/a
brief description

Sign: n/a Dimensions _____ Sign Area _____

Additional Information: ALL WIRING SHALL CONFORM TO THE 1978 N.E.C. - CALL FOR SERVICE, ROUGH-IN, & FINAL INSPECTIONS.

Date April 26-78 Applicant Signature Donald Bergstedt
owner-agent

PAID
APR 26 1978
CITY OF NAPOLEON

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring	6-8	NTJ	<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard	78		<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)	5/4/78	Red	Exterior Wall Construction	6/8/78	Red	Roof Covering Roof Drainage	6/4/78	Red	Smoke Detector		
	Excavation	"	Red				Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing	"	Red				<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab	Complete 6-8-78	Red	Interior Wall Construction	"	Red	Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access	6/8/78	Red	Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access	6/8/78	Red			
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System	6/8/78	Red	Special Insp Reports Rec'd			Certificate of Occupancy Issued		
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					
	Grounding & neutral not in compliance with Article						(384-27)(384-3)(250-23)					
	Grounding - (250-81)						6-8-78 - NH					
	Small app. CCTy - 320 (3 b)						Feeble effort made 6-15-78					

58-78

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name Kenn Walker's Address 908 Daggett ave.
Builder's Name Bergstedt Bldg Address 1050 Duval Tel. 592-3451

LOT INFORMATION: (Not required for roofing or siding job.)

Location of Project _____ Lot # 9
Subdivision _____ Lot Area 10990 Sq. Ft.
Yard Set Back: Front 26'0" N/A Rear 80' 104'0" Left Side 9'0"
Right Side 10'0" Zoning District _____

BUILDING INFORMATION:

Single Double _____ Multiple _____ New Construction _____
Addition Remodel _____ Attached Garage _____
Detached Garage _____ Accessory Building _____ Replacement _____

Brief Description of Work: Family and storage room.

Size: Length 24'0" Width 25'0" No. of Stories 1

Floor Area: 1st Floor 600 Sq. Ft. 2nd Floor _____ Sq. Ft.

3rd Floor _____ Sq. Ft. Basement _____ Sq. Ft.

Unfinished Attic Garage _____

Foundation: Piers _____ Full Basement _____ Part Basement _____

Concrete 4" Thickness Block 12" and 8" Size

Walls: Frame Block _____ Brick Other _____

Specific Type of Exterior Siding Brick.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO $\frac{1}{4}$ "=1'-0" SCALE. PLOT PLAN DRAWN TO $\frac{1}{8}$ "=1'-0" SCALE.

ESTIMATED COST OF COMPLETED PROJECT: 11,000.00

DATE April 21 - 1978 APPLICANT'S SIGNATURE Don Bergstedt Pres
OWNER-BUILDER-AGENT

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Ken Holers Address 908 Daggett Tel. 592-5946
Contractor's Name Bergstedt Blatz Address 1050 Doctel Tel. 592-3451

LOT INFORMATION:

Location of Project _____ Zoning District _____

BUILDING INFORMATION:

Single Family X Double Family _____ Multiple Family _____
New Construction X Existing _____ Addition _____
Replacement _____ Remodel _____ Service Change _____
Size: Total Square Foot Per Floor 600 No. of Stories _____

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only no (Yes or No)

Total Number of New Circuits 11 Total Number of New Circuits Excluding Appliance Circuits 109

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner X Attic Fan Blower X Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric no (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$ 11,000.00

DATE April 22 1978 APPLICANT'S SIGNATURE Donald Bergstedt Pres.
OWNER-CONTRACTOR-AGENT

$\frac{11}{10} \frac{2}{8}$
1.00
2.00
6.00
9.00

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date 8-17-78

Permit No. 58-78

Type of Inspection ELECTRICAL

Type of Occupancy RESIDENTIAL

Project Name KEN HOWERS

Address 908 DORSETT AVE.

City Napoleon State OHIO

Approved

SEND TO AGENT BERGSTEDT.

Violation

Electrical Contractor

Remarks:

Code Reference

① - Restricting Ground BUS ON ONE RECEPTACLE, SOUTH WALL, FAMILY ROOM (CHANGE RECEPTACLE) 210-NEC

② INDEX PNL BOARD 110-22 NEC

Compliance Time at once

Inspectors Signature Norman Howers

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

