

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**  
**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

Permit No. 277 Date June 23, 1981  
Job Location 1230 Detroit Ave. Valuation \$ 370.00  
Address  
Owner David Norton Address 1230 Detroit Ave.  
Name  
Contractor Cochran Electric. Telephone No. 592-0891  
Address 525 N. Perry St.  
Electric Contractor SAME  
Plumbing Contractor \_\_\_\_\_  
Mechanical Contractor \_\_\_\_\_

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**JUL 1 1981**

**CITY OF NAPOLEON**

**Work Information:**

Residential XX Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel XX  
Brief Description of Work Service change (60 amp to 100 amp.)

ISSUED BY Richard A. Wozniak DEPT. OF BUILDING & ZONING  
Building Official

**It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:**

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

**PERMIT & FEES**

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____
<b>TOTAL FEES</b>	<b>\$ <u>5.00</u></b>
<b>LESS FEES PAID</b>	<b>\$ <u>-0-</u></b>
<b>BALANCE DUE</b>	<b>\$ <u>5.00</u></b>

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**



# PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING  
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 277 Date June 22, 1981  
Job Location 1230 Detroit Ave. Address Valuation \$ 370.00  
Owner David Gordon Name Address 1230 Detroit Ave.  
Contractor Cochran Electric Telephone No. 592-0851  
Address 525 N. Perry St.  
Electric Contractor \_\_\_\_\_  
Plumbing Contractor \_\_\_\_\_  
Mechanical Contractor \_\_\_\_\_

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

### Work Information:

Residential XX Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. dwelling units  
New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel XX  
Brief Description of Work service change (60 amp to 100 amp.)

ISSUED BY \_\_\_\_\_ Building Official \_\_\_\_\_ DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

### PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>5.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>5.00</u>
LESS FEES PAID	\$ <u>-0.00</u>
BALANCE DUE	\$ <u>5.00</u>

PAID

JUL 1 1981

CITY OF NAPOLEON

# INSPECTION RECORD

UNDERGROUND		ROUGH-IN & FINAL				
Type	Date	By	Type	Date	By	
<b>PLUMBING</b>	Sewer Connection		Drainage, W. & Vent			
	Building Sewer		Water Piping			
	Water Piping		Condensate Lines			
			Indirect Waste			
<b>ELECTRICAL</b>	Floor Ducts Raceways		Rough Wiring		FINAL APPROVAL	
	Conduits & or Cable		Conduits/ Cable		Electric Mtr. Clearance	
	Grounding & Bonding		Service Panel Switchboard	7-30-84	Signs	
			Subpanels			
<b>MECHANICAL</b>	Refrigerant Piping		Refrigerant Piping		FINAL APPROVAL	
	Ducts/ Plenums		Ducts/ Plenums		Duct Insulation	
			Ventilation Supply		Chimney(s)	
			Exhst.		Furnace(s)	
<b>BUILDING</b>	Location, Set-backs, Esmt(s)		Wall Construction		FINAL APPROVAL	
	Excavation		Crawl Space		Fireplace Chimney	
	Footings & Reinforcing		Floor System(s)		Attic Vent Access	
	Sub-soil Drain		Roof System		Special Insp Reports Rec'd	
	Foundation Walls		Fire Wall(s)		Smoke Detector	
	Floor Slab		Roof Cover/ Roof Drain		Demolition (sewer cap)	
	FINAL APPROVAL BLDG. DEPT.		Certificate of Occupancy Issued		Building or Structure	#

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name DAVID NORTON Address 1230 DETROIT AVE

Electrical Contractor COCHRAN ELECTRIC Telephone No. 592-0891

Address 525 N PERRY ST

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project 1230 DETROIT Cost of Project 370.00

Work Information:

Residential  Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

No. Units \_\_\_\_\_  
New 100 AMP Service Change YES Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: CHANGE 60 AMP SERVICE TO  
100 AMP SERVICE

Size of proposed service entrance 100 Number of new circuits NONE

Type of proposed service entrance - Underground - Overhead

Require Temporary Electric NO (Yes of No)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

\*GROUND FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 and 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE; AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

\*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 6-22-81 Applicant's Signature Seymour Myers

PERMIT NO.

277

PERMIT FEE \$

500

