



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 South Front St.
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

MAILING ADDRESS:

Lazarus Government Center
P. O. Box 1049
Columbus, OH 43216-1049

October 1, 1999

Re: Napoleon
Henry County
Application No. 03-11969
Application for Sanitary Sewer Extension for
Glenwood Mobile Home Park on Patricia Avenue
Plans Received May 18, 1999;
Revised Plans Received September 22, 1999
From Poggemeyer Design Group, Inc.

CERTIFIED MAIL

Fox Chase, Inc.
Attn: Larry Koesters
1 Devonshire Drive
Napoleon, OH 43545

Ladies and Gentlemen:

Enclosed is the Ohio EPA Permit to Install which will allow you to install the described source in the manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

You are hereby notified that this action of the director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code by any person who was a party to this proceeding. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Review Appeals Commission within thirty (30) days after notice of the director's action. A copy of the appeal must be served on the director of the Ohio Environmental Protection Agency and the Environmental Enforcement Section of the Office of the Attorney General within three (3) days of filing with the board. An appeal must be filed with the Environmental Review Appeals Commission at 236 East Town Street, Room 300, Columbus, OH 43266-0557.

You should note that a general condition of your permit states that issuance of the permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

If you have any questions, please contact the Ohio EPA district office to which you submitted your application.

Sincerely

Martha D. Spurbeck

Martha D. Spurbeck, Supervisor
Permit Processing Unit
Division of Surface Water

MDS/kep

Enclosure

cc: Northwest District Office
Henry County Health Department
Poggemeyer Design Group, Inc.
City of Napoleon

Bob Taft, Governor
Maureen O'Connor, Lieutenant Governor
Christopher Jones, Director

Ohio Environmental Protection Agency

Permit to Install

Application No. 03-11969

Applicant's Name: Fox Chase, Inc.

Address: 1 Devonshire Drive

City: Napoleon

State: Ohio 43545

Person to Contact: Larry Koesters
Telephone: (419) 599-0301


Description of Proposed Source: Sanitary Sewer Extension for Glenwood Mobile Home Park on Patricia Avenue, Napoleon, Henry County

Issuance Date: October 1, 1999

Effective Date: October 1, 1999

The above named entity is hereby granted a permit to install for the above described source pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source of environmental pollutants will operate in compliance with applicable state and federal laws and regulations, and does not constitute expressed or implied assurance that, if constructed or modified in accordance with those plans and specifications, the above described source of pollutants will be granted the necessary operating permits. This permit is granted subject to the following conditions attached hereto.

Ohio Environmental Protection Agency



Christopher Jones
Director

P. O. Box 1049, 122 South Front Street
Columbus, OH 43216-1049

Fox Chase, Inc.
Page 2 of 3
October 1, 1999

This permit shall expire if construction has not been initiated by the applicant within eighteen months of the effective date of this permit. By accepting this permit, the applicant acknowledges that this eighteen month period shall not be considered or construed as extending or having any effect whatsoever on any compliance schedule or deadline set forth in any administrative or court order issued to or binding upon the permit applicant, and the applicant shall abide by such compliance schedules or deadlines to avoid the initiation of additional legal action by the Ohio EPA.

The director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records, or reports pertaining to the construction, modification, or installation of the above described source of environmental pollutants.

Issuance of this permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

Any well, well point, pit, or other device installed for the purpose of lowering the ground water level to facilitate construction of this project shall be properly abandoned in accordance with the provisions of this plan or as directed by the director or his representative.

Any person installing any well, well point, pit or other device used for the purpose of removing ground water from an aquifer shall complete and file a Well Log and Drilling Report form with the Ohio Department of Natural Resources, Division of Water, within 30 days of the well completion in accordance with the Ohio Revised code Section 1521.01 and 1521.05. In addition, any such facility that has a capacity to withdraw waters of the state in an amount greater than 100,000 gallons per day from all sources shall be registered by the owner with the chief of the Division of Water, Ohio Department of Natural Resources, within three months after the facility is completed in accordance with Section 1521.16 of the Ohio Revised Code. For copies of the necessary well log, drilling report, or registration forms, please contact:

Ohio Department of Natural Resources
Fountain Square
Columbus, OH 43224-1387
(614) 265-6717

The proposed wastewater disposal system shall be constructed in strict accordance with the plans and application approved by the director of the Ohio Environmental Protection Agency. There shall be no deviation from these plans without the prior express, written approval of the agency. Any deviations from these plans or the above conditions may lead to such sanctions and penalties as provided for under Ohio law. Approval of this plan and issuance of this permit does not constitute an assurance by the Ohio Environmental Protection Agency that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

This permit to install applies only to the wastewater treatment works listed above. The installation of drinking water supplies, air contaminant sources, or solid waste disposal facilities will require the submittal of a separate application to the director.

Roof drains, foundation drains, and other clean water connections to the sanitary sewer shall be prohibited by enforcement of legally adopted rules by the authority regulating the use of sanitary sewers.

No liquids, sludges, or toxic or hazardous substances other than those set forth in the approved permit shall be accepted for disposal without the prior written approval of the Ohio Environmental Protection Agency.

Sewer and manhole construction joints shall conform to standards of the Ohio Environmental Protection Agency.

When Polyvinyl Chloride or Acrylonitrile Butadiene Styrene pipe is used, it must be tested for maximum deflection of 5 percent under the supervision of a professional engineer at a time when he has determined that the backfill has settled. Pipe with a stiffness of 200 p.s.i. or greater need not be tested for deflection if all pipe between manholes is less than 12 feet below final grade. Results of these tests shall be submitted to the appropriate district office. Any lines which fail the test must be repaired and retested until they meet the requirements.

All gravity sanitary sewers which are located in well field areas shall comply with and be tested as specified in Ohio Environmental Protection Agency Policy Guideline, Gravity Sewers in Well Field Areas, February, 1983.

The owner, Fox Chase, Inc., shall be responsible for proper operation and maintenance of the sewerage system.

Special Conditions:

This permit to install (PTI) is for a sanitary sewerline extension to an existing sanitary sewer system. The sanitary sewer system to which this sewerline extension project is tributary includes combined sewers with various authorized overflows (CSOs). The owner/operator of the City of Napoleon of the existing tributary sanitary sewer system is implementing an ongoing program to minimize and/or reduce pollutant discharges through these overflows. At this time, the Permit to Install applicant has completed installation of 9 chimney seals within the same CSO tributary area. These chimney seals are expected to remove extraneous flows from the sanitary sewer system equivalent to twice the net flows being authorized by this PTI. This PTI is authorizing the addition of 3,300 GPD to the sanitary sewer system.

The applicant shall contact the appropriate district of the U.S. Army Corps of Engineers for a determination regarding potential impacts to waters of the state as well as the requirements for obtaining, if necessary, a Clean Water Act Section 404 permit and Section 401 water quality certification. The applicant shall acquire a Section 404 permit and 401 water quality certification,, if needed, before impacting any waters of the state as part of this project.