

City Of Napoleon
FIELD SURVEY FORM

Premises Address: 1006 Dcdd Company Name: Century 21
Contact Name: Phyllis Ritter Contact Phone No: 592-7653
Service No: 8202 Service Size: 2" Meter No: 4408698 Meter Size: 3/8 Date Installed: 4-13-98
Type of Inspection: Initial Follow-Up Date of Inspection: 4-13-98 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 6" System Pressure 45-55 PSI
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity: _____

INSPECTOR COMMENTS/DIAGRAMS

*This is a realty office with 2 bathrooms
has a watts 3/4" DC 007 M2-QT serial# 116029*

FIRE PROTECTION SYSTEMS

System Type: Dry Sprinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

BACKFLOW PREVENTION REQUIREMENTS

*what they have in place will be sufficient
(need to have device tested ASAP.)*