

July 16, 1976

Mr. Joel Gibson  
1021 Dodd Street  
Napoleon, Ohio 43545

Subject: Above Grade Swimming Pool

Dear Mr. Gibson:

As per discussed on July 15, 1976 during our meeting at your residence -

I understand had you known there were regulations pertaining to above grade swimming pools, all required permits would have been obtained prior to installation. That is why, in my judgement, you should not be subject to the penalties at this stage for constructing a pool without a permit. But, in order to maintain the minimum safety regulations for the protection of your family and neighbors, please make application for a zoning, construction and electrical permit no later than July 26, 1976.

In addition, correct the following conditions no later than August 26, 1976:

1. Provide suitable fence around pool of a height not less than five (5) feet above finish grade with a gate and latch.
2. Ground the metal siding of the pool with an approved ground 8' ground rod with accessories.
3. Provide proper electrical wiring for equipment in or adjacent to swimming pool (ground-fault circuit-interceptor) in accordance with the National Electrical Code 1975, Article 680.

Accompany the enclosed applications with a letter from Mr. Samuel C. Geren stating he is aware the swimming pool is only approximately three (3) feet

Mr. Joel Gibson  
July 16, 1976  
Page 2

from his South side lot line and waving the zoning code requirement of an eight (8) foot sound barrier fence along the lot line because the pool is closer than twenty-five (25) feet to his home.

If you have any further questions feel free to contact me at the City Building or phone 592-4010. Thank you for your cooperation.

Very truly yours,

Thomas W. Terranova  
Building Commissioner

TWT/cm

Enclosures

7/20/76 MR. GIBSON CALLED TODAY AND INFORMED ME POOL WILL BE DISMANTLED NO LATER THAN 7/20/76, *AJP*

7/26/76 POOL DISMANTLED, NOT REQUIRED TO MEET REQUIREMENTS OF THIS LETTER. *AJP*