

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Samuel Geran

Address 1025 Dodd St.

Builder Name VonBeylen Plumbing & Heating Co.

Address 1080 Glenwood Ave. Tel. 592-4756

Lot Information:

Street No. 1025 Dodd St.

Lot 1B Subdivision D.E. Coes Sub Lot 1B

Lot Dimensions Lot Area Sq. Ft.

Yard Set Back: Front Rear

Side Side

Zoning "R2" Intended use of Building: Replacing existing furnace with new (oil) hot water heating system.

Building Information:

Single Double Multiple New Construction Addition Remodel

Size: Length Width No. of Stories 2

Floor Area: 1st Floor 2nd Floor 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical: Wiring Electric Heating Electrical Appliances

Plumbing: Fixtures or Traps Warm Air Heating Hot Water Heating

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 8/28/75 Applicant Signature Samuel Geran

Owner - Builder - Agent

Permit No.	<u>370-75</u>			
Issued	<u>8/27/75</u>			
By	<u>Thomas W. Howes</u> Building Inspector			
Valuation	<u>1900.00</u>			
	Fees	Base	Plus	Total
Construction				
Plumbing				
Electrical				
Heating	<u>\$3.00</u>	<u>--</u>	<u>\$3.00</u>	
Water Tap				
Sewer Tap				
Temporary Elec.				
TOTAL	\$3.00	--	\$3.00	

NOTE: CONTACT THE BUILDING INSPECTOR WHEN PROJECT COMPLETED.

Note: 12/31/75 Conditions Corrected & Approved by Howes (Electrical)

Inspection Record:

Work Started Foundations Plumbing, Heating

Set Back, Side Lines Plumbing (Rough In) And Air Conditioning

Excavation Erecting Frame Roof

Footing Electrical Work 12/11/75 disapproved by Howes

Comments: 11/29/75 Not able To Enter Bldg. No one home. AWP.

Note: 12/31/75 Furnace inspected & approved by AWP.

Certificate of Occupancy Issued

Pink - Engineer

Inspector

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 12-11-75

Permit No.

Type of Inspection Electrical

Type of Occupancy Single Family

Project Name Samuel Geren

Address 1075 Ross Rd N.

City Napoleon State Ohio

Approved

Violation

Electrical Contractor Von Deylen Plumbing & Heating

Remarks:

Code Reference

1 Provide protection for exposed wires (cables Honeywell Controller) 336-6 NEC

2 Seal unused opening in disconnect switch, to prevent escape of fire 370-8 NEC

3 Overheating of conductors to Controller Type of overcurrent device 340-3 NEC 340-5X NEC


4 reroute 3/8" groundfield from Honeywell Controller to circulating pump provide adequate protection, groundfield connection at Honeywell Controller and groundfield connector at circulating pump not tight 110-12 NEC

12/31/75 Corrected Approved by Thomas Howes

Contact Engineering Dept. For Re-inspection

Compliance Time 10 days Inspectors Signature Thomas Howes

Copies To: Mr. Geren & Von Deylen Plumbing & Heating Co.



CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR HEATING PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of a heating system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name SAMUEL GEREN Address 1025 OODD St.

Contractor's Name VONDEYLEN P.H. INC. Address 1080 GLENWOOD Tel. 592 4756

LOT INFORMATION:

Location of Project _____ Lot # 1B

Subdivision D.E. Coes Sub Lt 1B Zoning District GB

BUILDING INFORMATION:

Single Family Double Family _____ Multiple _____ New Construction _____

Addition _____ Remodel _____ Replacement No. of Stories 2

DESCRIPTION OF WORK

Heating System - Warm Air _____ Hot Water Steam _____ Electric _____

Unit Heaters _____ Unit Gas Heaters _____ Other _____

Type - Gravity _____ Forced Radiant _____

No. of Thermostatical Heating Zone ONE -

Hot Water - One Pipe _____ Two Pipe TWO Series Loop _____

Electric Heat - No. of Circuits _____ Other _____

Total Heat Loss of Area to be Heated _____ Btu.

Rated Capacity of Furnace/Boiler 15000 BTU INPUT Btu.

No. of Furnances _____ No. of Hot Air Runs _____

No. of Hot Water Radiators _____ Type of Fuel OIL

Heating Units Located: Crawl Space _____ Floor Level _____ Suspended _____

Roof or Exposed to Outside Air _____ Attic _____ Other BASEMENT

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION OF FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: 900.⁰⁰

DATE 8/26/75 APPLICANT'S SIGNATURE Von Deylen P.H. & Hitz Inc
OWNER-CONTRACTOR-AGENT

