

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT  
(1, 2 or 3 Family Dwelling)**

Owner Name Walter Gathman  
 Address 749 W. Main St.  
 Builder Name Harold Bostelman Electrical Co.  
 Address 618 Park St Tel. 592-2383

**Lot Information:**

Street No. 1037 Dodd St.  
 Lot #3 Subdivision D.E. Coes Sub Lot 18  
 Lot Dimensions \_\_\_\_\_ Lot Area \_\_\_\_\_ Sq. Ft.  
 Yard Set Back: Front \_\_\_\_\_ Rear \_\_\_\_\_  
 Side \_\_\_\_\_ Side \_\_\_\_\_

Zoning "C" Intended use of Building: Installing on existing building a new 100 amp. service entrance and a new main breaker panel located in basement.

**Building Information:**

Single  Double \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel   
 Size: Length \_\_\_\_\_ Width \_\_\_\_\_ No. of Stories \_\_\_\_\_  
 Floor Area: 1st Floor \_\_\_\_\_ 2nd Floor \_\_\_\_\_ 3rd Floor \_\_\_\_\_ Basement \_\_\_\_\_  
 Unfinished Attic \_\_\_\_\_ Garage \_\_\_\_\_  
 Foundation: Piers \_\_\_\_\_ Full Basement \_\_\_\_\_ Part Basement \_\_\_\_\_  
 Concrete \_\_\_\_\_ Block \_\_\_\_\_

Walls: Frame \_\_\_\_\_ Block \_\_\_\_\_ Brick \_\_\_\_\_ Other \_\_\_\_\_  
 Electrical: Wiring new 100 amp. Electric Heating \_\_\_\_\_ Electrical Appliances new dryer  
 Plumbing: Fixtures or Traps \_\_\_\_\_ Warm Air Heating \_\_\_\_\_ Hot Water Heating \_\_\_\_\_

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 11/12/74 Applicant Signature Harold Bostelman  
 Owner - Builder - Agent

**Inspection Record:**

Work Started 11-14-74 Foundations \_\_\_\_\_ Plumbing, Heating \_\_\_\_\_  
 Set Back, Side Lines \_\_\_\_\_ Plumbing (Rough In) \_\_\_\_\_ And Air Conditioning \_\_\_\_\_  
 Excavation \_\_\_\_\_ Erecting Frame \_\_\_\_\_ Roof \_\_\_\_\_  
 Footing \_\_\_\_\_ Electrical Work \_\_\_\_\_

Comments: inspected & approved by Norman Howes 11-14-74 JWP

Certificate of Occupancy Issued \_\_\_\_\_ Inspector \_\_\_\_\_

Permit No. 172-74  
 Issued 11/11/74  
 By Thomas W. Terranova  
 Building Inspector

Fees	Base	Plus	Total
Construction			
Plumbing			
Electrical	\$3.00	\$4.00	\$7.00
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
<b>TOTAL</b>	<b>\$3.00</b>	<b>\$4.00</b>	<b>\$7.00</b>



Received 11/3/74

Permit No. 172-74

CITY OF NAPOLEON, OHIO  
ELECTRICAL PERMIT APPLICATION

OWNER Walter Gathman CONTRACTOR Harold Bostelman  
ADDRESS 1037 Dodd St ADDRESS 618 Park St Napoleon  
LOT NO. 3 ADJOINING D.E. Coes Sub Lot 18 TELEPHONE NO. 592-2383  
New Entrance

AWP Harold informed must ground on 11/3/74

PANEL INFORMATION

GROUNDING INFORMATION

Ground to water line if possible

NO.	SIZE IN INCH	NUMBER CIRCUITS	SIZE OF SERVICE WIRE
No. 1	100	1	#2
No. 2		only adding	ONE

SIZE WIRE # 6  
GROUND ROD ONLY 5/8" X 8'

COST OF PERMIT FIGURED AS FOLLOWS

DESCRIPTION	COST PER UNIT	NUMBER UNIT	DOLLAR VALUE
<u>ELECTRIC WIRING</u>			
One (1) Circuit	\$1.00	1	\$1.00
Each additional circuit	.75		
	.60		
<u>ELECTRIC HEATING</u>			
Each electric ceiling heating area	1.00		
Electric furnace (See back of Sheet) Ind. 1	6.00		
Each additional unit over size 41	.75		
<u>ELECTRICAL APPLIANCES</u>			
Electric Range	1.00	1	1.00
Range top	1.00		
Wash/Dryer	1.00	1	1.00
Dishwasher	1.00		
Air Conditioner	1.00		
Attic fan blower	1.00		
Room Exhaust Fan	1.00		
Disposal	1.00		
Water Heater	1.00		
Change Entrance (Only)	5.00	1	5.00
GRAND TOTAL (Minimum \$3.00)			\$7.00
For each additional reinspection there will be a cost of \$5.00			

I, the undersigned, state that I am well informed on the current NATIONAL ELECTRIC CODE (National Fire Protection Association) and agree that all wiring, fixtures and electrical appliances will meet the minimum requirements of the above mentioned Code.

Date 11-7-74 Signature Harold Bostelman  
(Owner or Contractor)

6-24-74 by RHB

cost. of job \$200.00

Entrance Northwest  
Corner of House

1 1/4" Conduit

3 # 2 T.H.W. Wire Copper

METER

← 3-2 Cable

100 A. Main Breaker

12 Cir. Panel

Inside  
basement

3rd Rod



# CITY OF NAPOLEON WORK ORDER

No 15705

Dept. Electric

Name Walter Gathman

Date Ordered 11-11-74

Address 1037 Dodd St.

By Harold Bostelman

LOCATION	Remove			Install		
	No.	Date	Rdg.	No.	Date	Rdg.
Electric						
Water						
Water Hr.						

Request: On Thurs 11/14 between 8-8<sup>30</sup> AM remove one of the service entrances from wall for installation of new one. Return same day @ 1<sup>30</sup> PM for transfer of power only. IF approved by Electrical Inspector who will be there @ 1<sup>30</sup> PM to conduct the inspection.  
Poin Bureau 11/11/74

Date Completed .....By .....

