

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Donald Bergstadt
 Address 1050 Dodd St.
 Builder Name Lyaa Wohltmann
 Address _____ Tel. _____

Lot Information:

Street No. 1050 Dodd St.
 Lot B Subdivision E.S. Dorkin 1st Addition
 Lot Dimensions 60x132 Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning "C" Residence
 Sidewalk required in accordance with Ordinance
 No. _____

Building Information:

Residence Commercial _____ Industrial _____
 Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length _____ Width _____ No. of Stories _____
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical Outlets: 120v _____ 240v _____
 Plumbing: Fixtures _____ Traps _____ Vents _____ Heating _____ Air Conditioning _____

Additional Information: to install a new 100 amp service entrance
D/P IN garage.
 Date _____ Applicant Signature _____
 Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work _____
 Comments: Completed 12-19-74 Inspected & approved by N. Howes 12/19/74

Certificate of Occupancy Issued _____

Pink - Engineer

Inspector

Permit No. 61
 Issued 6-19-74
 By D.H. Bassalman
 Building Inspector
 Estimated Cost 3000

Fees	Base	Plus	Total
Construction			
Basement			
Detached Garage			
Plumbing			
Electrical	<u>300</u>		<u>300</u>
Heating			
Air Conditioning			
Water Tap			
Sewer Tap			
Temporary Electric			
Total			<u>300</u>

DATE	December 12, 1974 Permit No. 61-74	
PROJECT	Electrical - New 100AMP SERVICE	
LOCATION	1050 Dodd St.	
CONTRACTOR	LYNN WUCHTMANN	OWNER Don Bergstedt
WEATHER	_____	TEMP. _____ ° at _____ AM _____ ° at _____ PM
PRESENT AT SITE	Norman Howes - Elect. Inspector Tom Terranova - Bldg. Inspector Don Bergstedt - Owner	

TO Donald Bergstedt
1050 Dodd St.
Napoleon, Ohio, 43545

THE FOLLOWING WAS NOTED:

ON November 13, 1974 the following conditions or violations were observed and requires correcting and re-inspection before the City will transfer power from old service entrance to the new one:

- 1) Bonded bushings at service conduit entrance into main panel. Art. 250-72 NEC.
- 2) Identify neutral conductor. Art. 200-6 NEC.
- 3) Ground to City water line in addition to ground rod required by City. Art. 250-81 NEC.
- 4) Within ~~Main panel~~ ^{Corrected} seal conduit to service entrance. Art. 300-6 ~~NEC~~ ^{Howes}. Re-inspected 12/19/74
- 5) Will not accept bending conduit by heat.
- 6) Must provide Al/Cu spacer where copper meets Alum. within meter socket.

- Contact my office when ready for re-inspection.

~~Inspected & approved by N. Howes 12/14/74~~

~~Completed 12-19-74~~

COPIES TO Don Bergstedt and on record with bldg permit No. 61-74

FIELD REPORT
 SIGNED Tom Terranova
 City Building Inspector