

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Permit No. 449-75
 Issued 12/26/75
 By Ann W. Bravara
 Building Inspector

Valuation \$100.00

Fees	Base	Plus	Total
Construction	--	--	--
Plumbing	--	--	--
Electrical	\$3.00	\$1.15	\$4.15
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
TOTAL	\$3.00	\$1.15	\$4.15

Owner Name Walter Gathmen
 Address 1064 Dodd Street
 Builder Name Harold Bostelman Electrical Co.
 Address 613 Park St. Tel. 592-2383

Lot Information:
 Street No. 1064 Dodd St.
 Lot 10 Subdivision F.S. Dodd's lat.
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning "0" Intended use of Building: Installing in the same location of the existing service, 100AMP electrical service entrance and the distribution panel located in the basement.

Building Information:
 Single Double _____ Multiple _____ New Construction _____ Addition _____ Remodel
 Size: Length _____ Width _____ No. of Stories 2
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring 100AMP Electric Heating -- Electrical Appliances --
 Plumbing: Fixtures or Traps -- Warm Air Heating -- Hot Water Heating --

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part hereof.

Date 12-30-75 Applicant Signature Harold Bostelman
 Note: Health condition hazardous, reported by Owner - Builder - Agent
 phone to James Hoftsberry - Henry County Dept. of Health, on 1/8/76.
R.W.P.

Inspection Record:
 Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work Service & Panel Approved by Howes 1/8/76

Comments: _____

Certificate of Occupancy Issued _____

.75 1st 10 circuits
2.40 Bal of 4 circuits
4.15 Total

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

S. R.

The undersigned hereby makes application for the installation, replacement or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name WALTER GATHMAN Address 1064 DODD - ST.

Contractor's Name HAROLD BOSTELMAN Address 618 PARK Tel. 592-2383

LOT INFORMATION:

Location of Project 1064 DODD ST Lot # 10

Subdivision E.S. DODD ROAD Zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing _____ Addition _____

Replacement _____ Remodel _____ Service Change

Size: Total Square Foot Per Floor _____ No. of Stories 2

Existing 6 circuit

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only Yes (Yes or No)

Total Number of New Circuits 1 Total Number of New Circuits Excluding Appliance Circuits 1

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range Range Hood _____ Clothes Dryer Dishwasher _____

Air Conditioner Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric No (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$400.00

DATE 12-23-75


APPLICANT'S SIGNATURE HAROLD BOSTELMAN
OWNER-CONTRACTOR-AGENT

1064 DODD ST

INTRANCE - ON - SOUTH - SIDE
REPLACE - PRESENT - 60A. OUTSIDE - PANEL
TO - 100 AMP - PANEL - INSIDE - BASEMENT

1 1/4" Rigid Conduit
3 #2 THW WIRE

PANEL



100AMP-20CIR.
MAIN-BREAKER
PANEL
IN-BASEMENT

← LIB

GRD. TO ROD,
+ WATER-LINE

