

**PERMIT**

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01729 Issued 4-24-89  
date

Job Location 110 Duquesne  
address

Lot 62 Riveria Heights  
sub-div or legal discript

Issued By Eldon Huber  
building official

Owner Norman Burill 592-5701  
name tel.

Address 110 Duquesne

Agent Beck's Construction 592-8307  
builder-eng.-etc. tel.

Address 11-622 Rd. M - Napoleon, OH

Description of Use Residence

Residential 1  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. X Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 15,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	9.00	58.00	67.00
<input checked="" type="checkbox"/> ELECTRICAL	15.00	6.00	21.00
<input type="checkbox"/> PLUMBING			
<input checked="" type="checkbox"/> MECHANICAL	18.00		18.00
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$106.00
LESS MIN. FEES PAID _____			
BALANCE DUE.....			

**ZONING INFORMATION**

district <u>A</u>	lot dimensions <u>83' x 120'</u>	area <u>9960 SF</u>	front yd <u>Exist.</u>	side yds <u>32'10"L 32'2"R</u>	rear yd <u>38'8"</u>
max hgt <u>35'</u>	no pkg spaces <u>2-min.</u>	no ldg spaces	max cover <u>35%</u>	petition or appeal req'd <u>none req.</u>	date appr

**WORK INFORMATION:**

Size: Length 23 Width 18 Stories 1 Ground Floor Area 414

Height 14 Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: 2 new circuits  
brief description

Plumbing: \_\_\_\_\_  
brief description

Mechanical: 2 hot air runs.  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
type

Additional Information: Family room addition.

**PAID**

**APR 27 1989**

Date \_\_\_\_\_ Applicant Signature \_\_\_\_\_  
owner-agent





RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON  
55 West Riverview Ave.  
Napoleon, Ohio 43545  
19/592-4010

ADDENDUM TO Permit No. 01729 - (1)  
Owner NORMAN BURELL  
Contractor RECK'S CONSTRUCTION  
Location 110 DURRIS

Please note the items checked below and incorporate them into your plans as indicated:  PERMIT NOT ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL			
Provide approved smoke detector(s) as req'd.		Show size of members supporting porch roof.	
Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.		Provide double top plate for all bearing partitions and exterior walls.	
Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		Provide design data for prefab wood truss.	
Submit fully dimensioned plot plan.		Ceiling joists undersized in _____.	
Provide min. of 1-3'0" x 6'8" exit door.		Roof rafters undersized in _____.	
<input checked="" type="checkbox"/> Provide min. 22" x 30" attic access opening.		PLUMBING AND MECHANICAL	
Provide min. 18" x 24" crawl space access opening.		Terminate all exhaust systems to outside air.	
Provide approved sheathing or flashing behind masonry veneer.		<input checked="" type="checkbox"/> Insulate ducts in unheated areas.	
Provide min. 15# underlayment on roof.		Provide backflow prevention device on all hose bibs.	
Provide adequate fireplace hearth.		Terminate pressure and temperature relief valve drain in an approved manner.	
Install factory built fireplaces/stoves according to manufacturers instructions.		Provide dishwasher drain with approved air gap device.	
Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		METAL VENEERS	
LIGHT AND VENTILATION		Contact City Utilities Dept. to remove conductors and/or meter.	
Provide mechanical exhaust or window in bathroom		Provide approved system of grounding and bonding.	
<input checked="" type="checkbox"/> Provide min. <u>199</u> Sq. In. net free area attic ventilation.		ELECTRICAL	
<input checked="" type="checkbox"/> Provide min. <u>40</u> Sq. In. net free area crawl space ventilation.		Show location of service entrance panel and service equipment panel.	
FOUNDATION		G. F. C. I. req'd. on temporary electric.	
Min. depth of foundation below finished grade is 32".		<input checked="" type="checkbox"/> Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.	
Min. size of footer _____" x _____".		Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.	
Provide anchor bolts 1/2" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.		Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.	
Show size of basement columns.		INSPECTIONS	
FRAMING		The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs prior to the time the inspection is to be made.	
Show size of wood girder in _____.		<input checked="" type="checkbox"/> Footers and Setbacks.	Building sewer.
Provide design data for structural member in _____.		<input checked="" type="checkbox"/> Foundation.	<input checked="" type="checkbox"/> HVAC rough-in.
Floor joists undersized in _____.		Plumbing rough-in.	<input checked="" type="checkbox"/> Final Building
Provide double joists under parallel bearing partitions.		Plumbing final.	other,
Provide 1" x 4" let in corner bracing, approved sheathing, or equal.		Electrical service.	<input checked="" type="checkbox"/> <u>BUILDING FRAMING</u>
Show size of headers for openings over 4' wide _____.		<input checked="" type="checkbox"/> Electrical rough-in.	
		<input checked="" type="checkbox"/> Electrical final	

Additional Corrections. 2x8 CEILING RAFTERS SHALL BE #1 S.P.F @ 16" O.C.  
OR #2 S.P.F. @ 12" O.C. OR #2 S.P.F @ 16" O.C.

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01729 and made a part here-of. DATE APPROVED OR DISAPPROVED 4-25-89 Checked by ELDON HUBER Plan Examiner.

DATE RECHECKED AND APPROVED

Checked by



**APPLICATION**  
for  
**RESIDENTIAL BUILDING, ELECTRICAL, PLUMBING, MECHANICAL, PERMITS and DEMOLITION PERMIT**  
from the  
**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
255 West Riverview Ave. Napoleon, Ohio 43545 Pn. 419-592-4010

Entry No. \_\_\_\_\_

Permit No. 01729 Issued 4-24-99

Job Location 110 Duquesne

Lot 62 Riveria Hys  
sub-div. or legal disc.

Issued By 54 building official

Owner Norman Burill Pn 592-5701

Address 110 Duquesne

Agent Beck's Const Co Pn 592-8307

Address 11622 Rd M Nap. O.

Description of Use 11622 Rd M Napoleon O  
1-FAM RESIDENCE

Residential 1 no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n.  Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 15,000

**-ZONING INFORMATION**

district A lot dimensions 83' x 120' area 9960 S.F. front yd EX 157 side yds. 32'-10" C 32'-2" R rear yd 38'-8"  
max hgt 35' no pkg spaces 2-MIN no ldg spaces \_\_\_\_\_ max cover 35% petition or appeal req'd. NONE REQ. date appr \_\_\_\_\_

WORK INFORMATION:  
BUILDING: Garage Fl. Area No Basement Fl. Area No Second Floor Area No

Size: Length 23 Width 18 Stories 1 Ground Floor Area 334 414  
Height 14' Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Description of Work: FAMILY ROOM ADDITION

Chk. Permits Req.	Base	Fees Plus	Total
<input checked="" type="checkbox"/> Building	<u>9.00</u>	<u>58.00</u>	<u>67.00</u>
<input checked="" type="checkbox"/> Electrical	<u>15.00</u>	<u>6.00</u>	<u>21.00</u>
Plumbing	_____	_____	_____
<input checked="" type="checkbox"/> Mechanical	<u>18.00</u>	<u>1.00</u>	<u>19.00</u>
Demolition	_____	_____	_____
Zoning	_____	_____	_____
Sign	_____	_____	_____
Water tap	_____	_____	_____
Sewer Tap	_____	_____	_____
Temp. Water	_____	_____	_____
Temp. Elec.	_____	_____	_____
Additional struc. plan review	_____	_____	_____
Elect. review	_____	_____	_____
Total Fees.....	_____	_____	<u>106.00</u>
Less Min. Fees Pd.	_____	_____	_____
Balance Due.....	_____	_____	_____

ELECTRICAL: Electrical Contractor Same Pn. \_\_\_\_\_

Address \_\_\_\_\_ Estimated Cost \$ \_\_\_\_\_

Type of work: New \_\_\_\_\_ Service change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring  Temp. Elec. Req.

Size of service Same Underground \_\_\_\_\_ Overhead \_\_\_\_\_ No. of new circuits 2

Description of work: 2 new circuits

PLUMBING: Plumbing Contractor None Pn. \_\_\_\_\_

Address \_\_\_\_\_ Estimated Cost \$ \_\_\_\_\_

Water Tap Req. \_\_\_\_\_ Size \_\_\_\_\_ Type of Pipe \_\_\_\_\_ Water Dist. Pipe \_\_\_\_\_ type

San. Sewer Tap Req. \_\_\_\_\_ Size \_\_\_\_\_ Type of Pipe \_\_\_\_\_ Dr. Waste Vt. Pipe \_\_\_\_\_ type

St. Sewer Tap Req. \_\_\_\_\_ Size \_\_\_\_\_ Type of Pipe \_\_\_\_\_ Street to be Opened \_\_\_\_\_ yes no

Main Building Drain Size \_\_\_\_\_ Main Vent Pipe Size \_\_\_\_\_ List Number of Plumbing Fixtures Below

Water Closets \_\_\_\_\_ Bathtubs \_\_\_\_\_ Showers \_\_\_\_\_ Lavatories \_\_\_\_\_ Kitchen Sinks \_\_\_\_\_ Disposal \_\_\_\_\_ Dishwasher \_\_\_\_\_ Clothes Washer \_\_\_\_\_

Floor Drains \_\_\_\_\_ Other Fixtures: Type \_\_\_\_\_ No. \_\_\_\_\_

Description of Work: \_\_\_\_\_

MECHANICAL: Mechanical Contractor \_\_\_\_\_ Pn. \_\_\_\_\_

Address \_\_\_\_\_ Estimated Cost \_\_\_\_\_

Heating System: Forced Air \_\_\_\_\_ Gravity \_\_\_\_\_ Hot Water \_\_\_\_\_ Steam \_\_\_\_\_ Unit Heaters \_\_\_\_\_ Radiant \_\_\_\_\_ Baseboard \_\_\_\_\_

Type of Fuel: Electric \_\_\_\_\_ Natural Gas \_\_\_\_\_ Propane \_\_\_\_\_ Wood \_\_\_\_\_ Coal \_\_\_\_\_ Solar \_\_\_\_\_ Geothermal \_\_\_\_\_ Other \_\_\_\_\_

No. of Heat Zones \_\_\_\_\_ Hot Water: (One Pipe \_\_\_\_\_ Two Pipe \_\_\_\_\_ Series Loop \_\_\_\_\_) Electric Heat: (No of Circuits \_\_\_\_\_) No. of Furnaces \_\_\_\_\_

No. of Hot Air Runs 2 No. of Hot Water Radiators \_\_\_\_\_ Total Heat Loss 25,000 Rated Capacity of Furnace/Boiler 80,000

Location of Heating Units: Crawl Space \_\_\_\_\_ Floor Level  Attic \_\_\_\_\_ Suspended \_\_\_\_\_ Roof \_\_\_\_\_ Outside \_\_\_\_\_ Other \_\_\_\_\_

Description of Work En. Room 2 - HOT AIR RUNS

**DRAWINGS REQUIRED:** All Applications must be Accompanied by Two Complete sets of Drawings Including SITE PLAN, FOUNDATION PLAN, FLOOR PLANS, STRUCTURAL FRAMING PLANS, EXTERIOR ELEVATIONS, SECTIONS and DETAILS, STAIR DETAILS, ELECTRICAL LAYOUT, PLUMBING ISOMETRIC, HEATING LAYOUT ETC. All plans shall be DRAWN TO SCALE. Show all existing structures on the site plan also, show Electric Panel and Furnace Locations.

**READ AND SIGN BELOW;** The undersigned hereby makes application for a permit for all work described herein, and agrees to complete the work in strict accordance with all applicable provisions of the current edition of the C.A.B.D. Building Code, the Napoleon Building and Zoning Codes, the Napoleon Engineering Dept. Rules and Regulations, Standard Specifications and other Pertinent Sections of the Napoleon Code of Ordinances.

Date 4/20/89 Signature of Applicant Robert J. Beck Application not valid without signature