

2950 Enterprise

City of Napoleon

Fax Cover This is a confidential message, intended solely for the person to whom it is addressed. If you receive this message in error, please forward it to the correct person, or mail it back to us. Thank you.

To Ken Maag - Poggemeyer Design Group
Fax No. (419) 784-5293
From Adam C. Hoff, P.E. - City Engineer *ACH*
Date 4/5/99
Subject Mahnke Orchards RV Park
Pages 1, including this one

Per our previous conversations, we have reviewed several different issues regarding the referenced project.

1. A tap fee of approximately \$760.00 will be required. The final costs will be established on a time and materials basis. Currently the costs include a 1-1/2" meter and meter horn and two (2) hours labor for installation. Details for the required meter pit are available from my office.
2. A reduced pressure principal (RPZ) backflow preventor will be required just after the meter at the owner's expense. This RPZ must be installed above ground in a heated structure.
3. "Dry hydrants" tapped back to the proposed pond may be utilized in lieu of connecting to the proposed water service. Please note that a permit from the City will be required prior to constructing the pond.
4. The City will allow the use of the following yard hydrant models - American (models 126 & 226); Eclipse Freeze Flow Model; Murdock Accello (Sanitary Post Type); and Woodford (Model S4).
5. Preliminary conversations with the Liberty Township Trustees resulted in a verbal approval of boring or directional drilling under Interstate Drive to connect to the existing sanitary sewer. Upon completion of the final plans, we will assist in working with the Trustees for final approval.

If you have any questions or require additional information, please call me at (419) 592-4010. Thank you.

c: Jon Bisher, Jeff Marihugh, Rex Moll

255 W. Riverview Ave.
Napoleon, Ohio 43545

(419) 592-4010 Phone
(419) 599-8393 Fax



City of NAPOLEON, OHIO

255 WEST RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010
FAX (419) 599-8393

ALL INTERESTED PARTIES

This letter shall advise you that as authorized by Napoleon City Council , Ordinance No. 2-87, and in consultation with the U.S. Postmaster for the City of Napoleon, I as Building Inspector have made the following address revision

Mayor

J. Andrew Small

Members of Council

- Michael J. DeWit, President
- Terri A. Williams
- James Hershberger
- Travis B. Sheaffer
- Char Weber
- David F. Miller, Jr.
- Glenn A. Miller

City Manager

Dr. Jon A. Bisher

Finance Director

Gregory J. Heath

Law Director

David M. Grahn

City Engineer

Adam C. Hoff, P.E.

OWNER or OCCUPANT : Mahnke Orchards

ADDRESS-----: 260 Co. Rd. 12

STRUCTURE ON LOT #: N/A

SUBDIVISION NAME--: N/A

THE ABOVE STRUCTURE
HAS BEEN ASSIGNED
THE ADDRESS' (S) OF: 2950 Enterprise Avenue

DATE-----: 04/28/00

SIGNED

BUILDING INSPECTOR:

POSTMASTER-----:

COPIES TO

- Owner-----: X
- Occupant-----: X
- City of Napoleon Building Department-----: X
- City of Napoleon U.S. Post Office-----: X
- City of Napoleon Util., Elec. & Oper Dept---: X
- City of Napoleon Fire Department-----: X
- Ohio Gas Company-----: X
- Dimension Cable-----: X
- Henry County Auditors Office-----: X
- Henry County Treasurer-----: X
- Henry County Recorder-----: X
- United Telephone Company-----: X
- Henry County Sheriff Dept. 911-----: X

