



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

August 14, 1981

Mr. Eugene Hogrefe  
607 E. Riverview Ave.  
Napoleon, OH 43545

**Mayor**

Robert G. Heft

Re: Residence 410 Fair St.  
Septic Tank

**Clerk-Treasurer**

Rupert W. Schweinhagen Dear Mr. Hogrefe:

**Members of Council**

Lawrence Haase, President  
James Jackson  
William Young  
Darel Austermilller  
Darrell Fox  
James Zumfelde

An inspection of the septic tank located near the southeast corner of the property of 410 Fair St., has revealed that attention must be given to this situation.

The Van Hyning sanitary sewer has been completed for some time now, and all landowners are required to connect their sewer taps into this system.

**City Manager**

Alan E. Tandy

The septic tank on this property has been found to still be in operation. You are hereby notified that this tank shall be disconnected and plugged at both the inlet and the outlet. The tank shall then be filled with sand or crushed stone, or it may be removed entirely. The house connection shall then be made with the new tap, which is located at the stake which is also in the southeast corner of said property.

**Law Director**

Keith P. Muehlfeld

This work shall be completed within 30 days (September 14, 1981) and before disconnection, the City's Inspector shall be notified to oversee the disconnection and connection process.

Your cooperation in this matter will be appreciated.

Sincerely,

Richard G. Hayman  
Building Commissioner

RGH:dd