

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 95-79 Issued 7-16-79 date
 Job Location 1002 Fairview Drive. address
 Lot n/a sub-div or legal discript
 Issued By *R.E. Johnson* building official
 Owner Marlowe Witt name tel.
 Address 1002 Fairview Drive
 Agent Cochran Electric 592-0891 builder-eng.-etc. tel.
 Address 525 N. Perry St. Nap, Ohio
 Description of Use new electric service
 Residential one no. dwelling units
 Commercial _____ Industrial _____
 New _____ Add'n. _____ Alter _____ Remodel xx
 Mixed Occupancy _____
 Change of Occupancy _____
 Estimated Cost \$ 800.00

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$5.00	\$2.00	\$7.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$7.00
LESS MIN. FEES PAID _____ date _____			0
BALANCE DUE.....			\$7.00

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
 Height _____ Building Volume (for demo. permit) _____ cu. ft.
 Electrical: new 200 amp service & 2 circuits. brief description
 Plumbing: _____ brief description
 Mechanical: _____ brief description
 Sign: _____ type _____ Dimensions _____ Sign Area _____

Additional Information: CALL FOR FINAL & SERVICE INSPECTIONS:

Date 7-16-79 Applicant Signature *Swym Myers* owner-agent

PAID
 JUL 16 1979
 CITY OF NAPOLEON

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

95-79

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name MARLOW WITTE Address 1002 FAIRVIEW DRIVE

Contractor's Name COCHRAN ELECTRIC Address 525 N. PERRY ST. Tel. 592 0891

LOT INFORMATION:

Location of Project FAIRVIEW DRIVE Zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing _____ Addition _____

Replacement Remodel _____ Service Change

Size: Total Square Foot Per Floor _____ No. of Stories _____

DESCRIPTION OF WORK

Size of Service 200 AMP. Service Change Only YES (Yes or No)

Total Number of New Circuits 2 Total Number of New Circuits Excluding Appliance Circuits _____

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Room Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric NO (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$800.00

DATE 7-11-79 APPLICANT'S SIGNATURE [Signature]
OWNER-CONTRACTOR-AGENT

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

NORM: TRY AGAIN

9-29-79

Date ~~9-29-79~~

Permit No. 95-77

Type of Inspection SERVICE

Type of Occupancy RES.

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Project Name MARLOWE WITT

Address 1002 FAIRVIEW DR

City NAP State O

Approved

Violation

Electrical Contractor COCHRAN ELEC

Remarks:

Code Reference

Not Home No Entry

Looked over service outdoors only

1) absence of grounding into meter base 8-18-79

Hold till next time 9-15-79 N.H.

No Entry 9-29-79 N.H.

Car in drive way, but no response

12-22-79

6-20-80 complaint 15 amp breakers tripped with windows air cond on non grounded circuit R.H.

Compliance Time

Inspectors Signature W. Hovner

Copies To:

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545
(Please Print or Type)

Date ~~8-10-79~~ 9-29-79

Permit No. 95-77

Type of Inspection SERVICE

Type of Occupancy RES.

Project Name MARLOUE WITT

Address 1002 FAIRVIEW DR.

City NAP State OH

Approved

Violation

Electrical Contractor COCHRAN ELEC

Remarks:

Code Reference

Not Home No Entry	
Looked over Service outdoors only	
1) Absence of grounding into meter base 8-18-79	
Hold till next time 9-15-79 NH	
No Entry 9-29-79 NH	
Car in drive way, had no response 12-22-79	

Compliance Time

Inspectors Signature W. Houser

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

