

SEWER TAPPING PERMIT

Issued by

The City of Napoleon Engineering Dept.

255 West Riverview Ave. Napoleon, Ohio 43545 Pn. 592-4010

Entry No. \_\_\_\_\_

X Permit No. SA0165 Issued 3-12-91 Build. Permit No. \_\_\_\_\_

Job Location 1020 Fairview \_\_\_\_\_

Lot \_\_\_\_\_

Issued By BND sub div. or legal disc. \_\_\_\_\_

Owner William Rohrbaugh Pn. \_\_\_\_\_

Address 1020 Fairview Dr. \_\_\_\_\_

Agent Jerry Glanz Pn. \_\_\_\_\_

Address \_\_\_\_\_

Permit Fee \$ \_\_\_\_\_

Street Bond \$ \_\_\_\_\_

Date Paid \_\_\_\_\_

for office use only

WORK INFORMATION

Sanitary Sewer Tap \_\_\_\_\_ Size of Tap \_\_\_\_\_ Size and Type of Sewer \_\_\_\_\_ Street to be Opened \_\_\_\_\_  
yes no yes no

Storm Sewer Tap \_\_\_\_\_ Size of Tap \_\_\_\_\_ Size and Type of Sewer \_\_\_\_\_ Street to be Opened \_\_\_\_\_  
yes no yes no

Street opening Agreement Approval Date \_\_\_\_\_ Opening Bond Fee (Set by Engineer) \_\_\_\_\_

READ AND SIGN BELOW; The undersigned hereby agrees complete the work described above and to make use of said sewers only as allowed by and in strict accordance with all applicable provisions of The Napoleon Engineering Dept. Rules and Regulations, The Napoleon Standard Specification for Water Main, Sanitary Sewer and Storm Sewer Construction and other Pertinent Sections of the Napoleon Code of Ordinances.

Date 3-12-91 Signature of Applicant Jerry Glanz Permit not valid without signature


INSPECTION RECORD \_\_\_\_\_ to be completed by the Field Inspector

Date Inspection is made 3-13-91 Size and Type of Sewer 4"

Location attached Depth \_\_\_\_\_ Type of Test \_\_\_\_\_ Additional Information \_\_\_\_\_

Date 3-13-91 Inspected By Malcolm Helberg signature of inspector

Sketch Of Installation on Back or Attached



Contractor Jerry Glanz  
Owner Bill Rehebaugh

3-13-91

1020 Fairview Drive

Fairview Drive

Back of curb

44" 4" C.I.  
C.O. 24" deep  
12.0'

4' SPR 35 P.U.C.

4 to 6 Reducer & 45° bend 7.0' deep  
6" P.U.C.

10.5'

Bourne Street  
Manhole

186 Ft

8" P.U.C. Sanitary M

