

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT**

(1, 2 or 3 Family Dwelling)

Owner Name Roger Taylor

Address 419 Filmore St.

Builder Name Sherman Smith Electrical Co.

Address Pl. 2, Napoleon Tel. 592-7791

Lot Information:

Street No. 419 Filmore St.

Lot Part of 7 Subdivision Cyrus Montgomery's Addition

Lot Dimensions _____ Lot Area _____ Sq. Ft.

Yard Set Back: Front _____ Rear _____

Side _____ Side _____

Zoning "C" Intended use of Building: installing on existing building a

new 100amp. service entrance, main disconnect and new SER wiring to existing distribution panel.

Building Information:

Single Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____

Size: Length _____ Width _____ No. of Stories _____

Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____

Unfinished Attic _____ Garage _____

Foundation: Piers _____ Full Basement _____ Part Basement _____

Concrete _____ Block _____

Walls: Frame _____ Block _____ Brick _____ Other _____

Electrical: Wiring 100amp. Electric Heating _____ Electrical Appliances _____

Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 12-6-74 Applicant Signature Sherman Smith

Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____

Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____

Excavation _____ Erecting Frame _____ Roof _____

Footing _____ Electrical Work (Service) Inspected & approved by N. Howes

Comments: _____

Certificate of Occupancy Issued _____

Inspector

Permit No. 189-71

Issued 12/13/74

By Thomas W. Swanson
Building Inspector

Valuation \$150.00

Fees	Base	Plus	Total
Construction			
Plumbing			
Electrical	<u>\$3.00</u>	<u>\$2.00</u>	<u>\$5.00</u>
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
TOTAL	<u>\$3.00</u>	<u>\$2.00</u>	<u>\$5.00</u>

CITY OF NAPOLEON
Engineering Department
255 Riverview Avenue
NAPOLEON, OHIO 43545

DATE	Dec. 26, 1974	JOB NO.	Permit No. 189-74
PROJECT	Electrical Wiring		
LOCATION	419 Filmore St.		
CONTRACTOR	Sherman Smith Co.	OWNER	Roger Taylor
WEATHER	_____	TEMP.	_____° at _____ AM _____° at _____ PM
PRESENT AT SITE	Norman Howes - Elect. Inspector Tom Terranova - Bldg Inspector		

TO Sherman Smith Electrical Co.
Rt. 2,
Napoleon, Ohio, 43545

THE FOLLOWING WAS NOTED:

ON Dec. 19, 1974 during electrical inspection of the new service entrance and must be corrected before the City of Napoleon will transfer power:

1) Min. clearance for service drops 10' above finished grade. Also min. clearance of 3' above any roof with less than 4/12 slope. Art. 230-24 (a) and (b) of N.E.C.

2) Seal below Main Disconnect where S.E.R. cable enters building. Art. 300-6 N.E.C.

Condition Corrected & approved by N. Howes
11/9/75

- Please contact the Engineering Dept. when ready for re-inspection.

COPIES TO Sherman Smith and on record with permit No. 189-74

FIELD REPORT
SIGNED Tom W. Terranova
City Building Inspector



CITY OF MARIETTA, OHIO
ELECTRICAL PERMIT APPLICATION

OWNER Roger Taylor

CONTRACTOR Sherman Smith Elect

ADDRESS 419 Filmore

ADDRESS Rt 2 Nep

Part of lot 7
LOT NO. _____

TELEPHONE NO. 592 7791

ADDITION Cyrus Montgomery's Add.

PANEL INFORMATION

GROUNDING INFORMATION

SIZE IN AMPS NUMBER CIRCUITS SIZE OF SERVICE WIRE

(Sherman aware groundings to water line also required.)

No. 1 100 1 2 THW ALUM. SIZE WIRE #4 copper

No. 2 _____ GROUND ROD ONLY Existing

COST OF PERMIT FIGURED AS FOLLOWS

ELECTRIC WIRING	COST PER UNIT	NUMBER UNIT	DOLLAR VALUE
One (1) Circuit	\$1.00		
Next (9) Circuits	.75		
Each additional Circuit	.60		

(No New Circuits)

ELECTRIC HEATING	COST PER UNIT	NUMBER UNIT	DOLLAR VALUE
Each thermostatically heating zone	1.00		
Electric Furnace (See back of Sheet) Inc. & Hot Air Ducts	6.00		
Each additional duct over wire (9)	.75		

ELECTRICAL APPLIANCES	COST PER UNIT	NUMBER UNIT	DOLLAR VALUE
Electric ranges	1.00		
Range top	1.00		
Oven/Dryer	1.00		
Dishwasher	1.00		
Air Conditioner	1.00		
Attic fan blower	1.00		
Room Exhaust Fan	1.00		
Disposal	1.00		
Water Heater	1.00		
* Change Entrance (Only)	5.00	1	5.00

No Appliance Hook-up

GRAND TOTAL (Minimum \$3.00)

~~16.00~~
5.00


For each additional reinspection trip there will be a cost of \$5.00

I, the undersigned, states that I am well informed on the current NATIONAL ELECTRIC CODE (National Fire Protection Association) and agree that all wiring, fixtures and electrical appliances will meet the minimum requirements of the above mentioned Code.

Date 12-8-74

Signature Sherman Smith
(Owner or Contractor)

cost. \$ 150.00



11/2 1980

Direct Co.

Waco, Tex

12/18/80

11/18/80