

**PERMIT**

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING**  
**255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

037

Permit No. \_\_\_\_\_ Date Apr. 21, 1980

Job Location 725 Filmore Valuation \$ 1,000.00

Owner Howard Gable Address 1442 Oakdale

Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Electric Contractor Jim Speiser & Sons, Rt. 2, Napoleon, Ohio

Plumbing Contractor \_\_\_\_\_

Mechanical Contractor \_\_\_\_\_

**This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.**

**Work Information:**

Residential \_\_\_\_\_ Commercial X Industrial \_\_\_\_\_

New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel X

Brief Description of Work Service change to 200 amp and 4 circuits

ISSUED BY R. E. Johnson Building Official BN. DEPT. OF BUILDING & ZONING

**It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:**

- \_\_\_\_\_ Footing excavation prior to placing concrete.
- \_\_\_\_\_ Footing drains and foundation prior to backfill.
- \_\_\_\_\_ Prepared sub-grade prior to placing concrete floor slab.
- \_\_\_\_\_ Sanitary sewer
- \_\_\_\_\_ Rough-in electrical, plumbing and service framing prior to installing wall board.
- X Final electrical, plumbing and heating.
- \_\_\_\_\_ Final building inspection, prior to occupancy.

**Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.**

**PERMIT & FEES**

Building Permit	\$ _____
Electrical Permit	\$ <u>33.40</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
<b>TOTAL FEES</b>	<b>\$ <u>33.40</u></b>
<b>LESS FEES PAID</b>	<b>\$ <u>-0-</u></b>
<b>BALANCE DUE</b>	<b>\$ <u>33.40</u></b>

**PAID**  
**APR 25 1980**  
**CITY OF NAPOLEON**

TITEL

EMPHASIS & DURCHSETZUNG DER MAßNAHMEN ...

780

Handwritten notes and text at the top of the page, including a date '1982' and various illegible entries.

Handwritten notes in the middle section, possibly a list or summary of points.

Handwritten notes and text in the lower middle section, including a signature or name 'K. ...'.

ANMERKUNGEN

Handwritten notes on the left side, including a date '1982' and other illegible text.

Table with multiple rows and columns, containing handwritten entries and possibly numerical data.

Handwritten notes at the top of the right-hand column.

Main body of handwritten notes in the right-hand column, detailing various points or observations.

Handwritten notes at the bottom of the right-hand column, including a date '1982'.

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(please print or type)

039

~~18.00~~  
15.40  
\$ 33.40

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name HOWARD GABLE Address \_\_\_\_\_

Electrical Contractor JIM SPENCER & SONS Telephone No. 599-1946

Address RR #2 WAP, O

General Contractor NONE Telephone No. \_\_\_\_\_

Address \_\_\_\_\_

Location of Project PAVEL ST Cost of Project 1000.00

Work Information: 725 FULLMORE

Residential \_\_\_\_\_ Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. Units \_\_\_\_\_  
New \_\_\_\_\_ Service Change \_\_\_\_\_ Rewiring \_\_\_\_\_ Additional Wiring \_\_\_\_\_

Brief Description of Work: TAKE EXISTING SERVICE OFF POLE  
REPLACE ON BUILDING ADD CEILING LIGHTS

Size of proposed Service Entrance 200 Number of new Circuits 4

Type of proposed Service Entrance \_\_\_\_\_ Underground \_\_\_\_\_ Overhead X

Require Temporary Electric \_\_\_\_\_ (Yes or NO)

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Additional Information: \_\_\_\_\_

\*GROUND-FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE; AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. A.N.C. 210-8 N.E.C.

\*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 4-16-80 Applicant's Signature John P. Spencer

Commenc.  
Remodel

Descrip: Service change to 200 amp. + 4 circuits



# PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING

255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

037  
Permit No. \_\_\_\_\_ Date Apr. 21, 1980  
Job Location 725 Filmore Valuation \$ 1,000.00  
Owner Howard Gable Address 1442 Oakdale  
Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
Address \_\_\_\_\_  
Electric Contractor Jim Speiser & Sons, Rt. 2, Napoleon, Ohio  
Plumbing Contractor \_\_\_\_\_  
Mechanical Contractor \_\_\_\_\_

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

### Work Information:

Residential \_\_\_\_\_ Commercial X Industrial \_\_\_\_\_  
New Construction \_\_\_\_\_ Addition \_\_\_\_\_ Remodel X  
Brief Description of Work Service change to 200 amp and 4 circuits

ISSUED BY R. E. Johnson DEPT. OF BUILDING & ZONING  
Building Official

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- \_\_\_\_\_ Footing excavation prior to placing concrete.
- \_\_\_\_\_ Footing drains and foundation prior to backfill.
- \_\_\_\_\_ Prepared sub-grade prior to placing concrete floor slab.
- \_\_\_\_\_ Sanitary sewer
- \_\_\_\_\_ Rough-in electrical, plumbing and service framing prior to installing wall board.
- X \_\_\_\_\_ Final electrical, plumbing and heating.
- \_\_\_\_\_ Final building inspection, prior to occupancy.

### PERMIT & FEES

Building Permit	\$ _____
Electrical Permit	\$ <u>33.40</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>33.40</u>
LESS FEES PAID	\$ <u>-0-</u>
BALANCE DUE	\$ <u>33.40</u>

**PAID**  
APR 25 1980  
CITY OF NAPOLEON

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

# INSPECTION RECORD

UNDERGROUND		ROUGH-IN			FINAL	
Type	Date	By	Type	Date	By	Date
<b>PLUMBING</b>	Sewer Connection		Drainage, W. & Vent			Drainage, W. & Vent
	Building Sewer		Water Piping			Water Heater
	Water Piping		Condensate Lines			Backflow Prevention
			Indirect Waste			
<b>ELECTRICAL</b>	Floor Ducts Raceways		Rough Wiring			FINAL APPROVAL
	Conduits & Cable		Conduits/ Cable	5/19/80	RA	Electric Mtr. Clearance
	Grounding & Bonding	6/19/80	Service Panel	11	11	Signs
			Switchboard	11	11	
			Subpanels	11		
<b>MECHANICAL</b>	Refrigerant Piping		Refrigerant Piping			FINAL APPROVAL
	Ducts/ Plenums		Ducts/ Plenums			Duct Insulation
			Ventilation Supply			Chimney(s)
			Exhst.			Furnace(s)
			Wall Construction			FINAL APPROVAL
<b>BUILDING</b>	Excavation		Crawl Space			Fireplace Chimney
	Footings & Reinforcing		Floor System(s)			Attic Vent Access
	Sub-soil Drain		Roof System			Special Insp Reports Rec'd
	Foundation Walls		Fire Wall(s)			Smoke Detector
	Floor Slab		Roof Cover/ Roof Drain			Demolition (sewer cap)
						Building or Structure
FINAL APPROVAL BLDG. DEPT.		Certificate of Occupancy Issued		#		

CITY OF NAPOLEON  
DEPARTMENT OF BUILDING & ZONING  
APPLICATION FOR  
CERTIFICATE OF OCCUPANCY

Address 725 FILMORE Date JUNE 30, 1980

Zoning District I-1 INDUSTRIAL

I, Rennio L. Moser owner hereby request that a Certificate of Occupancy be issued for the above address, more particularly described as follows: WEST SIDE OF FILMORE ST., AND NORTH SIDE OF RIVERVIEW  
OF N.E. 1/4 OF SECTION 13 TOWN 5, NORTH, RANGE 6 EAST HENRY COUNTY

Building Area 31x42 24x  
15x 27x 21 Occupancy Area 4411

Prop. Parking Spaces \_\_\_\_\_ Exist. Parking Spaces \_\_\_\_\_

Reason for Request OPERATION OF A TRUCK REPAIR BUSINESS

New Residence

Change in use or type of business from Some to \_\_\_\_\_

Signed Rennio L. Moser

Date 7/10/80

Inspection Report: Electrical upgraded, cleaning  
yard areas, all buildings painted and  
clean, used for truck and auto repair and transfer  
station, with no parking over 48 hrs.

Approved 7/10/80 CO# \_\_\_\_\_ Not Approved \_\_\_\_\_

Reasons for not being approved \_\_\_\_\_

Signed Richard J. Hayward

Date 7/10/80

4/6 APR 1982

$$\begin{array}{r} 271 \\ 3 \\ \hline 81 \end{array}$$

$$\begin{array}{r} 14 \\ 2 \\ \hline 42 \end{array}$$